Manuals+ — User Manuals Simplified.

HF Protoss-PE11 RS485 to Ethernet User Manual

Contents

HF Protoss-PE11 RS485 to Ethernet

Overview of Characteristic

- Cortex-M3 MCU with 2MB Flash and 128KB SRAM
- Use FreeRTOS Operation System
- Support TCP/UDP/MQTT/HTTP/WebSocket Protocol
- Support Modbus TCP to RTU, Modbus Master Function
- Support RS485 To 10/100M Ethernet Conversion, Serial Speed Up to 460800 bps
- Support 10/100M Ethernet Auto-Negotiation
- Support Webpage Easy Configuration or PC IOTService Tool
- Support Security Protocol Such As AES/DES3
- Support Heartbeat and Resister Packet Function
- Support Webpage OTA Wireless Upgrade
- Support Industrial Temperature: -40 to +85˚ C
- Multiple Type of Different Power Input
    - Protoss-PE11-H 100 240VAC@50 60Hz
    - Protoss-PE11-M 9 48VDC@1A
- Size: 97.60 x 64.95 x 27.50 mm (L x W x H) C45 rail installation

PRODUCT OVERVIEW

General Description
The Protoss-PE11 provides a RS485 interface to TCP/IP data transfer product. The Protoss-PE11 integrate TCP/IP controller, memory, 10/100M Ethernet transceiver, RS485 and integrates a fully developed TCP/IP network stack and FreeRTOS OS. Protoss-PE11 also includes an embedded web server used to configure device.

The Protoss-PE11 using highly integrated hardware and software platform, it has been optimized for all kinds of applications in the industrial control, smart grid, personal medical application and remote control that have lower data rates, and transmit or receive data on an infrequent basis.

Device Paremeters

Table1. Protoss-PE11 Technical Specifications

Item	Parameters
System Information	
Processor/Frequency	Cortex-M3/96MHz
Flash/SDRAM	2MB/128KB
Operating System	FreeRTOS
Ethernet Port	
Port Number	1
Interface Standard	10/100 Base-T Auto-Negotiation
Transformer	Integrated
Network Protocol	IP TCP UDP DHCP DNS HTTP Server/Client ARP, AutoIP, ICMP Telnet, NTP, Modbus TCP
Security Protocol	AES 128Bit DES3
Serial Port	
Port Number	1 RS485
Data Bits	5,6,7,8
Stop Bit	1,2
Check Bit	None, Even, Odd
Baud Rate	TTL: 600 bps~460800 bps
Flow Control	No Flow Control Software Xon/ Xoff flow control
Software	
Web Pages	Http Web Configuration Customization of HTTP Web Pages
Configuration	Web CLI XML import

	Telnet
	IOTService PC Software UART Fast Config
Firmware Upgrade	Webpage, IOTService Tools
Basic Parameter	
Size	97.60mm x 64.95mm x 27.50mm
Operating Temp.	-40 ~ 85°C
Storage Temp.	-45 ~ 105°C, 5 ~ 95% RH no condensation
Input Voltage	Protoss-PE11-H 100 240VAC@50 60Hz
	Protoss-PE11-M 9 48VDC@1A
Working Current	~100mA
Power	<400mW

Key Application

The Protoss-PE11 device connects serial device to Ethernet networks using the TCP/IP protocol:

- Remote equipment monitoring
- Asset tracking and telemetry
- Security Application
- Industrial sensors and controls
- Medical devices
- ATM machines
- Data collection devices
- Universal Power Supply (UPS) management units
- Telecommunications equipment
- Data display devices
- Handheld instruments
- Modems
- Time/attendance clocks and terminals

HARDWARE INTRODUCTION

The Protoss-PE11 unit is a complete solution for serial port device connecting to network. This powerful device supports a 10/100BASE-T Ethernet connection, a reliable and proven operating system stored in flash memory, an embedded web server, a full TCP/IP protocol stack, and standards-based (AES) encryption.
Through Ethernet cable connect router with Protoss-PE11 serial server for data transfer, which makes the data transformation very simple.

Figure 1. Protoss-PE11 Appearance

Protoss-PE11 Pins Definition

Figure 2. Protoss-PE11 Interface

Table2. Protoss-PE11-H Interface Definition

Pin	Description	Net Name	Signal Type	Comment
1	AC Power Input	L	Power	100 240VAC Input
2	AC Power Input	N	Power	
5		RS485_B-	IO	RS485 B-
6	Signal GND	GND	Power	Used for RS485 GND, usually leave it unconnected
7		RS485_A+	IO	RS485 A+
RJ45	Ethernet	RJ45	I/O	
Reload	Restore to factory setting button	Reload	I	Press down for more than 3 seconds and loose to restore factory setting.
Reset	Reset button	Reset	I	Hardware reset button
Net	Network status LED	Net	O	On: Ethernet connection is OK Off: No Ethernet connection
Active	UART Data Transfer	Active	O	Off: No data transfer 0.3s Off -> 0.9s On: UART TX Output 0.3s Off -> 0.3s On: UART RX Receive On: UART bidirection.
Power	Power LED	Power	O	On: Power input OK Off: Power input NG.
Link	Server connection LED	Link	O	On: netp Socket connection OK. Off: no netp Socket connection.

Table3. Protoss-PE11-M Interface Definition

Pin	Description	Net Name	Signal Type	Comment
1	DC Power Input	VCC+	Power	9 48VDC@1A Input
2	DC Power Input	GND-	Power	
5		RS485_B-	IO	RS485 B-
6	Signal GND	GND	Power	Used for RS485 GND, usually leave it unconnected
7		RS485_A+	IO	RS485 A+
RJ45	Ethernet	RJ45	I/O	
Reload	Restore to factory setting button	Reload	I	Press down for more than 3 seconds and loose to restore factory setting.
Reset	Reset button	Reset	I	Hardware reset button
Net	Network status LED	Net	O	On: Ethernet connection is OK Off: No Ethernet connection
Active	UART Data Transfer	Active	O	Off: No data transfer 0.3s Off -> 0.9s On: UART TX Output 0.3s Off -> 0.3s On: UART RX Receive On: UART bidirection.
Power	Power LED	Power	O	On: Power input OK Off: Power input NG.
Link	Server connection LED	Link	O	On: netp Socket connection OK. Off: no netp Socket connection.

<Notes>
I — Input; O — Output; I/O: Digital I/O; Power—Power Supply

RS485 Interface
RS485 use two wire links, A(DATA+), B(DATA-). Connect A(+) to A(+), B(-) to B(-) for communication. Suggest to connect GND together when interference is very severe.
The RS485 interface support maximum 32 RS485 device. The cable maximum length is 1200 meters. Need to add 120Ohm terminal resistor for over 300 meters.

RJ45 Interface
Ethernet port is 10M/100M adaptive, support AUTO MDI/MDIX which means it support direct connecting to PC with Ethernet cable.


Figure 3.   RJ45 Pin Defination

Table4. RJ45 Interface

Pin Number	Name	Description
1	TX+	Transfer Data+
2	TX-	Transfer Data-
3	RX+	Receive Data+
4	PHY-VCC	Transformer Tap Voltage
5	PHY-VCC	Transformer Tap Voltage
6	RX-	Receive Data-
7	N.C.	None Connect
8	N.C.	None Connect

Mechanical Size

The dimensions of Protoss-PE11 are defined as following picture (mm):

Figure 4. Protoss-PE11 Mechanical Dimension

Product Installation

Figure 5.   Product Installation

Order Information

Base on customer detailed requirement, Protoss-PE11 provide different configuration version, Details as below:


Figure 6.   Protoss-PE11 Product Order Information

FUNCTION DESCRIPTION

Refer to "IOT_Device_Series_Software_Funtion" document for more detailed function.

APPENDIX A: CONTACT INFORMATION

Address: Room 1002,Building 1,No.3000,Longdong Avenue,Pudong New Area,Shanghai,China,201203
Web: **www.iotworkshop.com** or **www.hi-flying.com**
Contact:
Sales: **sales@iotworkshop.com**
Support: **support@iotworkshop.com**
Service: **service@iotworkshop.com**
Business: **business@iotworkshop.com** ————————————————————————-
—————————————-

For more information about IOTworkshop modules, applications, and solutions, please visit our web site
www.iotworkshop.com

Documents / Resources

	HF Protoss-PE11 RS485 to Ethernet [pdf] User Manual Protoss-PE11, RS485 to Ethernet, Protoss-PE11 RS485 to Ethernet

References

- 🌐 [HI-FLYING.COM](http://hi-flying.com)
- 🌐 [HI-FLYING.COM](http://hi-flying.com)
- 🌐 [HI-FLYING.COM](http://hi-flying.com)
- 🌐 [HI-FLYING.COM](http://hi-flying.com)

Manuals+,