



ALBEO ALB030 Emergency Battery Backup Module Installation Guide

[Home](#) » [Albeo](#) » ALBEO ALB030 Emergency Battery Backup Module Installation Guide 

ALBEO ALB030 Emergency Battery Backup Module



Contents

1 BEFORE YOU BEGIN

2 Optional Installation:

2.1 Dimming or Control Interface

3 Emergency Lighting Fixture Operation

4 Prepare Electrical Wiring

5 Installation of EBBM when Shipped with Fixture

6 Retrofit and Stand-Alone Installation

7 Electrical Connections

8 Customer Support

9 Documents / Resources

9.1 References

10 Related Posts



BEFORE YOU BEGIN

Read these instructions completely and carefully.

Read and follow appropriate Lumination LED Luminaire Installation Guide for fixture installation.

IMPORTANT SAFEGUARDS

WHEN USING ELECTRICAL EQUIPMENT, BASIC SAFETY PRECAUTIONS SHOULD ALWAYS BE FOLLOWED INCLUDING THE FOLLOWING:

READ AND FOLLOW ALL SAFETY INSTRUCTIONS

1. Turn power off before inspection, installation or removal.
2. To reduce the risk of electric shock, disconnect both normal and emergency power suppliers and converter connector of the emergency driver before servicing.
3. The emergency driver must be fed from the same branch circuit as the AC driver.
4. Do not attempt to service the battery. A sealed, no-maintenance battery is used that is not field replaceable. Contact the manufacturer for information on service.
5. Follow all NEC and local codes. Properly ground electrical enclosure.
6. Use only UL listed wire for input/output connections. Minimum size 18 AWG (0.75mm²).
7. Equipment should be mounted in locations and at heights where it will not readily be subjected to tampering by unauthorized personnel.
8. Do not use outdoors.
9. Do not mount near gas or electric heaters.
10. Do not use this equipment for other than intended use.
11. The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition.
12. Use caution when servicing batteries. Battery acid can cause burns to skin and eyes. If acid is spilled on skin or eyes, flush acid with fresh water and contact a physician immediately.

SAVE THESE INSTRUCTIONS

Ni-Cd Battery

The rechargeable Nickel-Cadmium battery in this product must be recycled or disposed of properly.

This equipment is not self-testing in conformance with the Life Safety Code, ANSI/NFPA 101



WARNING

RISK OF ELECTRIC SHOCK

- Turn power off before inspection, installation or removal.
- Properly ground electrical enclosure.

RISK OF FIRE

- Follow all NEC and local codes.
- Use only UL or IEC approved wire for input/output connections. Minimum size 18 AWG.

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation. CAN ICES-005 (A) /NMB-005 (A)

Note: This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to

part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment.

This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.

Optional Installation:

Dimming or Control Interface

Follow instructions from appropriate Albeo LED Luminaire Installation Instructions to install optional control interfaces.

Note: The fixture will not be controllable during emergency operation.

Emergency Lighting Fixture Operation

The emergency driver is capable of operating the LED load for a minimum of 90 minutes. The emergency driver battery recharge time is 32 hours. After installation, the battery should be allowed to charge.

This emergency lighting fixture should be tested regularly according to national and local code requirements. To test the emergency driver, remove AC power or press and hold the indicator test switch. Take standard precautions against static discharge while operating indicator test switch.

Prepare Electrical Wiring

Electrical Requirements

The LED driver must be supplied with 120-277 VAC, 50/60 Hz per product label and connected to an individual properly grounded branch circuit, protected by a 15 or 20 ampere circuit breaker.

Grounding Instructions

The grounding and bonding of the overall system shall be done in accordance with the national electric code (NEC) Article 600 and local codes.

Installation of EBBM when Shipped with Fixture


Follow appropriate Albeo LED Luminaire Installation Instructions to install the fixture. Take standard precautions against static discharge during fixture installation.

Note: As received from the manufacturer, the luminaire may be partially energized.


Note: Per UL 924 and for best results, mount emergency lighting unit at a maximum of 35 feet.

Note: Mechanical attachment of EBBM to fixture required.


1. Remove the conduit nut from the nipple adapter on the fixture.




2. Loosen two screws to remove the top cover of the EBBM unit.



3. Push fixture wires through EBBM unit side hole. Ensure ends are capped off.
Mount EBBM unit to nipple and fasten conduit nut.
Ensure that the EBBM is facing downwards.



4. Locate battery plug and push into the corresponding receptacle on the side of the charger. Proceed to the Electrical Connections section to complete.




Retrofit and Stand-Alone Installation

Note: As received from the manufacturer, the luminaire may be partially energized.


Note: Per UL 924 and for best results, mount emergency lighting unit at a maximum of 35 feet.

Note: When using a focusing optic, the installer may need to replace the installed lens with a different provided lens to meet the correct photometric requirements.


1. Loosen two screws to remove the top cover of the EMBB unit.




2. Install the provided standoff nipple adapter into the appropriate mounting hole.



3. Using the attached nipple adapter, mount the EBBM to an appropriate means of mounting (fixture, junction box, conduit, etc.). Ensure that the EBBM is facing downwards



4. Locate battery plug and push into the corresponding receptacle on the side of the charger. Proceed to the Electrical Connections section to complete




Electrical Connections

1. Follow Electrical Connections instructions from an appropriate Albeo LED Luminaire Installation Guide. Use UL listed fittings for wire protection.
2. Refer to the applicable diagram below. Using UL listed 18-14 AWG twist-on wire connectors, connect the black (unswitched line), black (switched line), and white (neutral) input wires. Connect the ground wire to the green grounding wire as provided. **Important:** Make sure the necessary branch circuit wiring is available. An

unswitched source of power is required. The emergency driver must be fed from the same branch circuit as the AC driver.


3. Check that all internal plugs are connected to the battery charge unit. If a connector is loose, plug the connector into the appropriate receptacle on the battery charge unit.
4. Seal any remaining hole in the EBBM cover with the provided plug. Reattach EBBM cover. Do not overtighten screw

Luminaire with EBBM with Two Power Drops




UL = Unswitched Line
SL = Switched Line
N = Neutral
G = Ground
B = Black
W = White
O = Wire Connector

Switched Luminaire with EBBM with One Power Drop




UL = Unswitched Line
 SL = Switched Line
 N = Neutral
 G = Ground
 B = Black
 W = White
 R = Red
 ○ = Wire Connector

Unswitched Luminaire with EBBM with One Power Drop




UL = Unswitched Line
 SL = Switched Line
 N = Neutral
 G = Ground
 B = Black
 W = White
 R = Red
 ○ = Wire Connector

Luminaire with EBBM & Motion Sensor with Two Power Drops



UL = Unswitched Line
 SL = Switched Line
 N = Neutral
 G = Ground
 B = Black
 W = White
 O = Wire Connector


Switched Luminaire with EBBM & Motion Sensor with One Power Drop



UL = Unswitched Line
 SL = Switched Line
 N = Neutral
 G = Ground


B = Black
W = White
R = Red
○ = Wire Connector

Luminaire with EBBM & Motion Sensor with Two Power Drops



UL = Unswitched Line
SL = Switched Line
N = Neutral
G = Ground
B = Black
W = White
R = Red
○ = Wire Connector

Stand-Alone EBBM



UL = Unswitched Line
 N = Neutral
 G = Ground
 B = Black
 W = White
 O = Wire Connector

Customer Support

[LED.com](https://www.led.com)

© 2023 Current Lighting Solutions, LLC. All rights reserved. Information and specifications subject to change without notice. All values are design or typical values when measured under laboratory conditions.

ALB030-Albeo-Emergency-Battery-Backup-Module-Installation-Guide_R01

Albeo®

Documents / Resources



[ALBEO ALB030 Emergency Battery Backup Module](#) [pdf] Installation Guide
 ALB030, ALB030 Emergency Battery Backup Module, Emergency Battery Backup Module, Battery Backup Module, Backup Module, Module

References

-  [guideled.com](https://www.guideled.com) - Registered at Namecheap.com
-  [LED Commercial Lighting and Lighting Controls | Current - GLI Brands](#)

Manuals+.