

[Manuals.plus](#) /

› [GE](#) /

› GE Jasco 15602 Universal Replacement Timer Tripper Instruction Manual

GE 15602

GE Jasco 15602 Universal Replacement Timer Tripper Instruction Manual

Model: 15602

1. INTRODUCTION

This manual provides instructions for the GE Jasco 15602 Universal Replacement Timer Tripper. These trippers are designed to replace existing or inoperable trippers on compatible GE mechanical time switches, enabling proper scheduling of electrical devices.

2. PRODUCT OVERVIEW

The Jasco 15602 package includes two replacement timer trippers. These components are essential for the automatic operation of mechanical time switches, allowing them to turn connected devices on or off at programmed intervals.



Figure 1: GE Jasco 15602 Universal Replacement Timer Trippers. This image shows the two metal trippers, one black and one bright, each equipped with a brass thumbscrew for secure attachment to the timer dial.

3. COMPATIBILITY

These replacement timer trippers are compatible with most GE mechanical time switches. Specifically, they are designed to fit the following GE timer models:

- GE Model 15163
- GE Model 15164
- GE Model 15306
- GE Model 15307
- GE Model 15328
- GE Model 15600
- GE Model 15601

Ensure your existing timer model is listed above for proper fit and function.

4. INSTALLATION

Installation of the replacement timer trippers is a straightforward process. Always ensure the power to the timer switch is

disconnected before handling any electrical components.

1. **Power Disconnection:** Turn off the power to the GE mechanical time switch at the circuit breaker or fuse box. Verify that the power is off before proceeding.
2. **Remove Old Trippers (if applicable):** If replacing existing trippers, carefully loosen the thumbscrews and slide the old trippers off the timer dial.
3. **Attach New Trippers:** Slide the new Jasco 15602 trippers onto the timer dial. Position them according to your desired ON/OFF schedule. Typically, one tripper is used for the "ON" event and another for the "OFF" event.
4. **Secure Trippers:** Tighten the brass thumbscrews on each tripper to secure them firmly in place on the timer dial. Do not overtighten.
5. **Restore Power:** Once the trippers are securely installed, restore power to the timer switch from the circuit breaker or fuse box.
6. **Test Operation:** Observe the timer's operation to ensure the trippers activate the ON/OFF cycles as intended.

***Safety Note:** If you are unsure about any step or uncomfortable working with electrical components, consult a qualified electrician.*

5. OPERATION

The Jasco 15602 trippers function by physically interacting with the internal mechanism of the GE mechanical time switch. When the timer's rotating dial reaches an "ON" tripper, it triggers the switch to turn on the connected electrical device. Conversely, when the dial reaches an "OFF" tripper, it triggers the switch to turn off the device. To adjust the timing, simply loosen the thumbscrew on the desired tripper, slide it to the new position on the timer dial, and retighten the thumbscrew.

6. MAINTENANCE

The Jasco 15602 timer trippers are designed for durability. Regular maintenance is minimal:

- **Cleaning:** Periodically inspect the trippers and the timer dial for dust or debris. Clean with a dry, soft cloth if necessary.
- **Inspection:** Check the trippers for any signs of wear, bending, or damage. Ensure the thumbscrews remain tight.
- **Environmental Conditions:** Avoid exposing the timer and trippers to excessive moisture or extreme temperatures, which can affect their performance and lifespan.

7. TROUBLESHOOTING

Problem	Possible Cause	Solution
Timer not turning ON/OFF at programmed times.	Trippers are loose or incorrectly positioned.	Ensure trippers are securely tightened and correctly aligned with the desired ON/OFF times on the timer dial.
Tripper appears bent or damaged.	Physical stress or material fatigue.	Replace the damaged tripper with a new one.
Timer mechanism not engaging with trippers.	Incompatible timer model or internal timer issue.	Verify timer compatibility (refer to Section 3). If compatible, the issue may be with the timer unit itself, requiring professional service or replacement.

8. SPECIFICATIONS

- **Model Number:** 15602
- **Brand:** GE (Manufactured by Jasco Products Company, LLC)
- **Material:** Metal
- **Color:** One Black Metal Tripper + One Bright Metal Tripper, Each With a Brass Thumbscrew
- **Product Dimensions:** Approximately 0.48"D x 2.1"W x 4.06"H (Package dimensions; individual tripper dimensions are smaller)
- **Item Weight:** Approximately 0.634 ounces (for the 2-pack)
- **Included Components:** 2 Trippers
- **UPC:** 043180156020
- **GTIN:** 00043180156020

9. WARRANTY AND SUPPORT

Specific warranty information for the Jasco 15602 Universal Replacement Timer Trippers was not available in the provided product data. For warranty details, technical support, or further assistance, please contact Jasco Products Company, LLC directly or refer to the documentation included with your original GE mechanical time switch. You may also visit the [GE brand page on Amazon](#) for general product information, though direct support for this accessory may be handled by Jasco.

ASK A QUESTION ABOUT THIS MANUAL

Ask about setup, troubleshooting, compatibility, parts, safety, or missing instructions. Manuals+ will review the question and use this page's manual context to help answer it.

Name

Email

After a successful submission, we securely hash the supplied account or form email before sending it to Microsoft Advertising for conversion attribution. [Privacy details](#).

Question

Details

Submit question

Open the live page

<https://manuals.plus/asin/B007BJUMWY>

More documents and user manuals: <https://manuals.plus/>