

ECG JT-008

ECG JT-008 Replacement Tip for J-040 Soldering Iron User Manual

Essential instructions for installation, use, and maintenance.

INTRODUCTION

This manual provides detailed instructions for the proper installation, operation, and maintenance of the **ECG JT-008 Replacement Soldering Iron Tip**. This tip is specifically designed for use with the **ECG J-040 Soldering Iron**. Adhering to these guidelines will ensure optimal performance and extend the lifespan of your soldering tip.

PRODUCT OVERVIEW



This image displays the ECG JT-008 replacement soldering iron tip. It features a sharp, conical point suitable for precision soldering tasks and a threaded base for secure attachment to compatible soldering irons.

The ECG JT-008 is a precision-engineered replacement tip, featuring a conical shape ideal for fine soldering work. Its robust construction ensures efficient heat transfer and durability when used with the specified ECG J-040 Soldering Iron.

SETUP AND INSTALLATION

- Ensure Safety:** Before beginning, ensure your ECG J-040 Soldering Iron is unplugged from the power source and has completely cooled down. Attempting to change a hot tip can result in severe burns.
- Remove Old Tip:** Carefully unscrew the old soldering tip from the heating element of the J-040

soldering iron. If the tip is stuck, apply gentle, steady pressure. Avoid excessive force that could damage the iron.

3. **Inspect Heating Element:** Briefly inspect the heating element for any debris or damage. Clean if necessary.
4. **Install New Tip:** Gently screw the new ECG JT-008 replacement tip onto the heating element. Tighten it securely by hand. Do not overtighten, as this can strip the threads or damage the heating element.
5. **Initial Tinning:** After installation, plug in the soldering iron and allow it to reach operating temperature. Once hot, immediately apply a small amount of solder to the tip. This process, known as 'tinning,' coats the tip with solder, preventing oxidation and ensuring efficient heat transfer.

OPERATING GUIDELINES

While the JT-008 is a replacement tip, proper operating practices are crucial for its longevity and effective soldering:

- **Maintain Tinning:** Always keep the tip tinned with a thin layer of solder, especially when the iron is hot but not in use. This protects the tip from oxidation.
- **Appropriate Temperature:** Use the lowest effective temperature for your soldering tasks. Excessive heat can accelerate tip degradation.
- **Clean Regularly:** Wipe the tip on a damp sponge or brass wool cleaner frequently during use to remove excess solder and flux residue.
- **Avoid Scraping:** Do not use the tip to scrape or pry components, as this can damage the tip's plating.

MAINTENANCE

Regular maintenance is key to maximizing the performance and lifespan of your ECG JT-008 soldering tip:

- **Tip Cleaning:** Use a damp cellulose sponge or specialized brass wool tip cleaner to remove solder and flux residue. Avoid abrasive materials.
- **Re-tinning:** If the tip becomes oxidized (dark or black), clean it thoroughly and immediately re-tin it with fresh solder. Specialized tip tinner compounds can also be used for heavily oxidized tips.
- **Storage:** When not in use, ensure the soldering iron is turned off and cooled. Store the iron with a tinned tip to prevent oxidation during storage.
- **Inspection:** Periodically inspect the tip for pitting, excessive wear, or damage to the plating. A severely worn or damaged tip should be replaced to ensure consistent soldering quality.

TROUBLESHOOTING

If you encounter issues with your soldering tip, consider the following common problems and solutions:

- **Problem: Solder does not adhere to the tip (tip appears black/dark).**
Solution: The tip is oxidized. Clean the tip thoroughly with brass wool or a damp sponge, then immediately re-tin it with fresh solder. If heavily oxidized, use a tip tinner compound. Ensure the iron is not left hot and untinned for extended periods.
- **Problem: Poor heat transfer to the solder joint.**
Solution: Ensure the tip is clean and well-tinned. Check that the tip is securely screwed into the heating element. Verify the soldering iron is reaching its set temperature. A worn tip may also have reduced heat transfer capabilities and might require replacement.
- **Problem: Tip wears out quickly.**

Solution: This can be caused by using excessively high temperatures, abrasive cleaning methods, or leaving the tip untinned. Review operating and maintenance guidelines to ensure proper usage.

SPECIFICATIONS

Model Number	JT-008
Compatibility	ECG J-040 Soldering Iron
Manufacturer	NTE ELECTRONICS

WARRANTY INFORMATION

Specific warranty details for the ECG JT-008 Replacement Tip are typically provided by the retailer at the time of purchase or by the manufacturer, NTE ELECTRONICS. Please retain your proof of purchase for any warranty claims. For detailed warranty terms and conditions, refer to the documentation included with your original purchase or contact NTE ELECTRONICS directly.

SUPPORT

For technical assistance, questions regarding the ECG JT-008 Replacement Tip, or inquiries about the ECG J-040 Soldering Iron, please contact the manufacturer, NTE ELECTRONICS, or your authorized dealer. Ensure you have the model number (JT-008) and any relevant purchase information available when seeking support.

Related Documents - JT-008

	ECG ET 32303: Návod k obsluze a bezpečnostní pokyny pro elektrickou troubu s plotýnkami Kompletní uživatelský manuál pro elektrickou troubu ECG ET 32303 s plotýnkami. Obsahuje podrobné informace o bezpečném používání, funkcích, údržbě a technických specifikacích spotřebiče ECG.
	ECG MHT 1661 Pressione Nuovo Multifunctional Pressure Cooker Instruction Manual User manual and safety instructions for the ECG MHT 1661 Pressione Nuovo multifunctional pressure cooker. Learn how to safely operate, maintain, and troubleshoot your appliance.

 Forza 6600 Metallo STAVBA PŘÍPRAVA PŘÍPRAVA PŘÍPRAVA	ECG Forza 6600 Metallo Stand Mixer Instruction Manual Comprehensive instruction manual for the ECG Forza 6600 Metallo stand mixer, detailing safety, operation, assembly, troubleshooting, and maintenance for optimal kitchen performance.
 S 299 3in1 1. VÝROBA 2. PŘÍPRAVA 3. PŘÍPRAVA 4. PŘÍPRAVA 5. PŘÍPRAVA 6. PŘÍPRAVA 7. PŘÍPRAVA 8. PŘÍPRAVA 9. PŘÍPRAVA 10. PŘÍPRAVA	ECG S 299 3in1: Návod k obsluze Podrobný návod k obsluze pro sendvičovač ECG S 299 3in1. Zjistěte, jak bezpečně používat, čistit a udržovat váš nový přístroj pro přípravu lahodných sendvičů, vafelí a grilovaných pokrmů.
 ZH 1321 1. VÝROBA 2. PŘÍPRAVA 3. PŘÍPRAVA 4. PŘÍPRAVA 5. PŘÍPRAVA 6. PŘÍPRAVA 7. PŘÍPRAVA 8. PŘÍPRAVA 9. PŘÍPRAVA 10. PŘÍPRAVA	ECG ZH 1321 Beard Trimmer Instruction Manual User manual and safety instructions for the ECG ZH 1321 Beard Trimmer. Learn how to use, clean, and maintain your device safely.
 VP S 1050 Charles 1. VÝROBA 2. PŘÍPRAVA 3. PŘÍPRAVA 4. PŘÍPRAVA 5. PŘÍPRAVA 6. PŘÍPRAVA 7. PŘÍPRAVA 8. PŘÍPRAVA 9. PŘÍPRAVA 10. PŘÍPRAVA	ECG VP S 1050 Charles Vacuum Cleaner Instruction Manual Comprehensive instruction manual for the ECG VP S 1050 Charles vacuum cleaner. Learn about safety, operation, maintenance, troubleshooting, and technical specifications for optimal use.

Documents - ECG – JT-008

9 Dec 2022

ECG® BRAND ELECTRIC REPLACEMENT SOLDERING IRON TIPS

Photo	Description
	ECG-JT-008 Replacement tip for ECG-J-040
	ECG-JT-009 Replacement tip for ECG-J-060VT 1 conical, 1 chisel, and 1 needle tip per pkg.
	ECG-JT-010 Replacement tip for ECG-J-2040SS 2 tips per pkg.
	ECG-JT-011 Replacement tip for ECG-J-010 ECG-J-020

[pdf]

Tom Parkinson ECG Soldering Iron Tips 9Dec2022 74 KB Products JT 008 Replacement DX Engineering ecg j 012 static dxengineering global images technicalarticles |||

9 Dec 2022 ECG BRAND ELECTRIC REPLACEMENT SOLDERING IRON TIPS

Photo Description ECG-**JT-008** Replacement tip for ECG-J-040 ECG-JT-009 Replacement tips for ECG-J-060VT 1 conical, 1 chisel, and 1 needle tip per pkg. ECG-JT-010 Replacement tips for ECG-J-2040SS 2 tips per pkg. ECG-JT-011 Replacement...

lang:da score:27 filesize: 74.44 K page_count: 4 document date: 2022-12-09



[pdf] Flyer Warranty Accessories Borchure

ECG Soldering Heat Products Flyer NTE Electronics Brochure allspectrum store manuals

www.nteinc.com SOLDERING HEAT PRODUCTS NEW NEW NEW NEW NEW NEW

J-2040SS J-060VT J-012 J-020 J-025 J-040 J-060 J-315 Series J-050KT J-080KT J-700KT J-035 J-305 J-600 J-100 J-300 JT-004 J-310L J-220 J-045-DS **JT-008** JT-035 JT-006 JT-001 JT-002 JT-005 JT-103 JT-101 JT-003 JT...

lang:en score:26 filesize: 3.2 M page_count: 6 document date: 2010-03-24



[pdf] Datasheet Flyer Warranty Accessories

ECG Soldering Heat Products Flyer NTE Electronics 2006130 farnell datasheets

www.nteinc.com SOLDERING HEAT PRODUCTS NEW NEW NEW NEW NEW NEW

J-2040SS J-012 J-020 J-315 Series J-050KT J-080KT J-025 J-040 J-060 J-700KT J-035 J-060VT J-305 J-600 J-100 J-300 JT-004 J-310L J-220 J-045-DS **JT-008** JT-035 JT-006 JT-001 JT-002 JT-005 JT-103 JT-101 JT-003 JT...

lang:en score:17 filesize: 3.12 M page_count: 6 document date: 2011-05-19

lang:en score:11 filesize: 53.08 K page count: 1 document date: 2018-10-17