Noma Ion Exchange Replacement Filter

NOMA Ion Exchange Replacement Filter User Manual

Model: Ion Exchange Replacement Filter

1. Product Overview

The NOMA Ion Exchange Replacement Filter is designed to enhance the performance of compatible NOMA ultrasonic humidifiers. Its primary function is to reduce the accumulation of white dust and calcification, which are common issues in areas with hard water. This filter contributes to easier maintenance of your humidifier and helps maintain optimal mist output.

This filter is compatible with the NOMA 4 L Warm And Cool Mist Ultrasonic Humidifier and the NOMA 3.5 L Cool Mist Ultrasonic Humidifier.





Figure 1: The NOMA Ion Exchange Replacement Filter. This image displays the cylindrical filter unit, which is grey in color with a perforated top section and a threaded base for installation into a humidifier.

2. Installation Instructions

Follow these steps to install the NOMA Ion Exchange Replacement Filter into your compatible NOMA ultrasonic humidifier:

1. **Unplug the Humidifier:** Before beginning, ensure your humidifier is unplugged from the power outlet to prevent electrical hazards.
2. **Remove Water Tank:** Carefully lift and remove the water tank from the humidifier base.
3. **Empty Water Tank:** If there is any water remaining in the tank, empty it completely.
4. **Locate Filter Cap:** Turn the water tank upside down. The filter cap is typically located at the bottom of the water tank.

5. **Remove Old Filter (if applicable):** Unscrew the existing filter or filter cap by turning it counter-clockwise. Dispose of the old filter responsibly.
6. **Install New Filter:** Take the new NOMA Ion Exchange Replacement Filter. Screw it into the designated opening on the bottom of the water tank by turning it clockwise until it is securely fastened. Do not overtighten.
7. **Refill Water Tank:** Fill the water tank with clean, cool tap water.
8. **Replace Water Tank:** Place the filled water tank back onto the humidifier base, ensuring it is seated correctly.
9. **Plug In and Operate:** Plug the humidifier back into the power outlet and resume normal operation.

Note: Refer to your specific NOMA humidifier's instruction manual for detailed diagrams or additional installation steps.

3. Operating Principles

The NOMA Ion Exchange Replacement Filter operates by utilizing ion exchange resin to remove minerals from the water before it is dispersed as mist. This process helps to reduce the mineral content in the water, which is responsible for the white dust often seen around ultrasonic humidifiers, particularly in hard water areas. By reducing calcification, the filter also contributes to the longevity and efficiency of the humidifier's internal components.

4. Maintenance and Replacement

To ensure optimal performance and air quality, regular maintenance and timely replacement of the filter are crucial.

- **Filter Lifespan:** The lifespan of the ion exchange filter depends on the hardness of your water and the frequency of humidifier use. As a general guideline, it is recommended to replace the filter every 2-3 months, or when you notice an increase in white dust around your humidifier.
- **Signs of Replacement:**
  - Increased white dust accumulation on surfaces near the humidifier.
  - Reduced mist output from the humidifier.
  - Visible mineral buildup on the humidifier's transducer or water tank.
- **Disposal:** Dispose of used filters according to local waste disposal guidelines.

5. Troubleshooting

This section addresses common issues related to the filter's function.

Problem	Possible Cause	Solution
Excessive white dust despite using the filter.	Filter is old or saturated with minerals.	Replace the ion exchange filter with a new one. Consider using distilled or demineralized water if white dust persists.
Humidifier not producing mist effectively.	Filter may be clogged or incorrectly installed.	Check filter installation. If the filter is old, replace it. Clean the humidifier's transducer as per its manual.

6. Specifications

- **Product Type:** Ion Exchange Replacement Filter
- **Brand:** NOMA

- **Compatible Devices:** NOMA 4 L Warm And Cool Mist Ultrasonic Humidifier, NOMA 3.5 L Cool Mist Ultrasonic Humidifier
- **Material:** Polyester (filter media)
- **Item Weight:** Approximately 0.05 Pounds (0.02 kg)
- **Number of Items:** 1
- **Global Trade Identification Number (GTIN):** 04897074550311
- **Date First Available:** October 10, 2019

7. Warranty and Support

Specific warranty information for the NOMA Ion Exchange Replacement Filter is not provided in this manual. For details regarding warranty coverage, product support, or to purchase additional replacement filters, please refer to the documentation included with your NOMA humidifier or visit the official NOMA website.
For customer service inquiries, please contact NOMA customer support through their official channels.

Ask a question about this manual

Ask about setup, troubleshooting, compatibility, parts, safety, or missing instructions. Manuals+ will review the question and use this page's manual context to help answer it.

Name

Anonymous

Email

you@example.com

After a successful submission, we securely hash the supplied account or form email before sending it to Microsoft Advertising for conversion attribution. Privacy details.

Question

Example: How do I reset this device or fix this error?

Details

Model number, symptoms, what you tried, or the section of the manual you are using.

Submit question