

[Manuals.plus](#) /

› [ClimaTek](#) /

› ClimaTek KMSAH012C43 OEM Upgraded Blower Motor Module Instruction Manual

ClimaTek KMSAH012C43

ClimaTek KMSAH012C43 Blower Motor Module Instruction Manual

Model: KMSAH012C43 | Brand: ClimaTek

PRODUCT OVERVIEW

This manual provides essential information for the installation, operation, and maintenance of the **ClimaTek KMSAH012C43 OEM Upgraded 3/4 HP Blower Motor Module**. Please read this manual thoroughly before use to ensure proper function and safety.



An image showing the ClimaTek KMSAH012C43 OEM Upgraded 3/4 HP Blower Motor Module. It features a circular design with internal electronic components visible through a protective cage, and a multi-pin connector with colored wires extending from one side.

SAFETY INFORMATION

Always observe the following safety precautions to prevent injury or damage to the product:

- Ensure power is disconnected before installation or maintenance.
- Only qualified personnel should perform installation and repairs.
- Wear appropriate personal protective equipment (PPE) during handling.
- Do not operate the unit if it is damaged.

SETUP AND INSTALLATION

Follow these steps for proper installation of the blower motor module:

1. **Preparation:** Disconnect power to the HVAC unit at the circuit breaker.
2. **Access:** Locate and open the access panel to the blower motor assembly.
3. **Removal of Old Module:** Carefully disconnect all wiring from the existing blower motor module. Note the position of each wire for reinstallation. Remove any mounting screws or clips securing the old module.
4. **Installation of New Module:** Position the new ClimaTek KMSAH012C43 module in the same location as the old one. Secure it with the appropriate mounting hardware.
5. **Wiring:** Reconnect all wiring to the new module, ensuring each connection is secure and matches the original configuration. Refer to the wiring diagram if available.
6. **Closure:** Close and secure the access panel.

Note: This module is an OEM upgraded replacement for Zhongshan Broad-Ocean units. Ensure compatibility before installation.

OPERATING INSTRUCTIONS

Once installed, the blower motor module operates in conjunction with your HVAC system's control board. No direct user operation is required for the module itself.

- **Power On:** Restore power to the HVAC unit at the circuit breaker.
- **System Test:** Initiate a test cycle on your HVAC thermostat to verify proper operation of the blower fan. Listen for unusual noises and check for consistent airflow.
- **Normal Operation:** The module will automatically control the blower motor speed based on the demands of your thermostat and HVAC system.

MAINTENANCE

Regular maintenance helps ensure the longevity and efficiency of your blower motor module and HVAC system.

- **Annual Inspection:** Have a qualified HVAC technician inspect the blower motor and module annually for signs of wear, loose connections, or dust accumulation.
- **Cleaning:** Ensure the area around the blower motor is free from dust and debris. A clean environment reduces strain on the motor and module.
- **Filter Replacement:** Regularly replace or clean your HVAC system's air filter as recommended by the system manufacturer. A clogged filter can cause the blower motor to work harder, potentially shortening its lifespan.

TROUBLESHOOTING

If you experience issues with your blower motor, refer to the following common problems and solutions:

Problem	Possible Cause	Solution
Blower motor not running	No power to unit; Faulty thermostat; Wiring issue; Module failure	Check circuit breaker; Verify thermostat settings; Inspect wiring connections; Consult a technician for module diagnosis.
Weak airflow	Clogged air filter; Obstruction in ductwork; Motor running at low speed; Module issue	Replace/clean air filter; Check ducts for blockages; Consult technician for motor speed or module check.
Unusual noises from blower	Loose components; Debris in blower; Worn motor bearings; Module malfunction	Inspect for loose parts; Clean blower assembly; Motor or module may need replacement by a professional.

If troubleshooting steps do not resolve the issue, contact a certified HVAC technician. Do not attempt repairs beyond your skill level.

SPECIFICATIONS

- Model:** KMSAH012C43
- Brand:** ClimaTek
- Type:** OEM Upgraded Blower Motor Module
- Horsepower:** 3/4 HP (0.75 hp)
- Replaces:** Zhongshan Broad-Ocean modules
- Product Dimensions:** 9 x 21 x 10 inches
- Item Weight:** 14.06 Pounds

WARRANTY INFORMATION

This ClimaTek product is covered by a manufacturer's warranty against defects in materials and workmanship. For specific warranty terms and conditions, please refer to the documentation provided with your purchase or contact ClimaTek customer support.
Please retain your proof of purchase for warranty claims.

CUSTOMER SUPPORT

- For technical assistance, troubleshooting, or warranty inquiries, please contact ClimaTek customer support:
- Website:** [Visit the ClimaTek Store on Amazon](#)
 - Email:** Refer to product packaging or official website for contact email.
 - Phone:** Refer to product packaging or official website for contact phone number.

When contacting support, please have your product model number (KMSAH012C43) and purchase date available.

ASK A QUESTION ABOUT THIS MANUAL

Ask about setup, troubleshooting, compatibility, parts, safety, or missing instructions. Manuals+ will review the question and use this page's manual context to help answer it.

Name

Anonymous

Email

you@example.com

After a successful submission, we securely hash the supplied account or form email before sending it to Microsoft Advertising for conversion attribution. [Privacy details](#).

Question

Example: How do I reset this device or fix this error?

Details

Model number, symptoms, what you tried, or the section of the manual you are using.

Submit question