

## WEBANG WPF15

# WEBANG Pop Up Floor Outlet with 15 Amp GFCI Receptacle - Instruction Manual

Model: WPF15

## 1. INTRODUCTION

This manual provides detailed instructions for the installation, operation, and maintenance of your WEBANG Pop Up Floor Outlet with a 15 Amp GFCI Tamper Resistant Receptacle. This product is designed to provide convenient and safe power access in various indoor residential and commercial settings.

The WEBANG Pop Up Floor Outlet features a sleek, hidden design that integrates seamlessly into your flooring or countertop when closed, and provides easy access to power when needed. It is ETL listed and designed for durability and safety.

## 2. IMPORTANT SAFETY INFORMATION

**WARNING:** To avoid the risk of fire, electric shock, and/or death, always turn power OFF at the circuit breaker or fuse before installation or maintenance. Always test that the power is OFF before wiring.

- This device must be installed and used in accordance with appropriate electrical codes and regulations.
- Prohibition of children under 18 years of age from handling installation.
- If you are unsure or uncomfortable with performing the installation, consult a qualified electrician.
- Do not expose the unit to excessive moisture or liquids when open. The waterproof gasket provides protection when the unit is closed.

## 3. PRODUCT OVERVIEW

The WEBANG Pop Up Floor Outlet is a compact and robust electrical solution. It includes a stainless steel cover, a 15 Amp GFCI duplex tamper-resistant receptacle, and a galvanized steel junction box.

### Key Features:

- **15 Amp GFCI Power:** Features two 15 amp GFCI (Ground Fault Circuit Interrupter) power receptacles for enhanced safety.
- **Tamper Resistant:** All receptacles are tamper-resistant, preventing insertion of foreign objects.
- **Waterproof Design:** Equipped with a waterproof gasket (IP44 rated protection) to prevent water spray ingress when closed.
- **Soft Pop-Up Mechanism:** The unit pops up slowly at a 45-degree angle with a damped spring structure for secure and convenient access.
- **Durable Construction:** Stainless steel cover and galvanized steel junction box ensure longevity.

### Components:

- Stainless steel pop-up cover with twisting lock
- 15 Amp GFCI duplex tamper-resistant receptacle
- Galvanized steel junction box with 12 side and bottom knockouts



Image 1: The WEBANG Pop Up Floor Outlet in its open position, revealing the two 15 Amp GFCI tamper-resistant receptacles. The unit is black with a silver receptacle face.



Image 2: The WEBANG Pop Up Floor Outlet in its closed position, showcasing the flush black stainless steel cover.

#### 4. SPECIFICATIONS

Attribute	Value
Manufacturer	WEBANG
Part Number	112A
Item Model Number	WPFGF15
Item Weight	1.96 pounds
Product Dimensions (Overall)	4.75" L x 4.75" W x 3.5" H
Cover Length	4.75"
Cover Width	4.75"
Cover Height (closed)	2.7"
Cover Height (raised)	2"
Junction Box Length	4"

Attribute	Value
Junction Box Width	4"
Junction Box Height	3.15"
Size	15 Amp
Color	Black
Style	GFCI Outlet
Finish	Stainless Steel, Steel, Wood
Material	Stainless Steel
Installation Method	Freestanding (requires floor cutout)
Item Package Quantity	1
Certification	ETL Listed
Included Components	112A Floor Outlet



Image 3: Dimensional diagram of the WEBANG Pop Up Floor Outlet, indicating measurements for the cover and junction box.

## 5. SETUP AND INSTALLATION

---

**Note:** Floor boxes should be installed by a qualified professional. Standard instructions are provided with each unit. Ensure to check the wiring of your location to confirm compatibility with a 15 Amp GFCI outlet.

### Installation Steps (General Guidance):

1. **Turn Off Power:** Locate the circuit breaker controlling the installation area and turn off the power. Verify power is off using a voltage tester.
2. **Prepare Opening:** Carefully measure and cut an appropriate opening in your flooring or countertop according to the product dimensions (refer to Section 4: Specifications and Image 3). The junction box requires a 4" x 4" opening with a depth of 3.15".
3. **Route Wiring:** Route the electrical wiring into the junction box through one of the 12 available knockouts.
4. **Connect Wiring:** Connect the electrical wires to the 15 Amp GFCI duplex tamper-resistant receptacle according to local electrical codes and the wiring diagram provided with the unit. Ensure proper grounding.
5. **Secure Junction Box:** Insert the junction box into the prepared opening and secure it in place.
6. **Install Outlet Assembly:** Mount the GFCI receptacle and pop-up cover assembly onto the junction box, ensuring a snug fit.
7. **Test GFCI:** Once installed, restore power and test the GFCI outlet by pressing the 'TEST' button. The 'RESET' button should pop out. Press 'RESET' to restore power.

This product is suitable for hard wood, carpet, tile flooring applications, and granite/marble kitchen countertops. It is ideal for residential homes, boardrooms, lobbies, waiting rooms, and hospital rooms.

## 6. OPERATING INSTRUCTIONS

---

### To Open the Outlet:

- When the unit is closed, a small button is visible on the cover.
- Press this button firmly. The cover will slowly tilt open to a 45-degree angle, revealing the two 15 Amp GFCI receptacles. The damped spring structure ensures a smooth, controlled pop-up action.
- Once open, the receptacles are ready for use.

## Soft Pop-Up

The WEBANG floor box can pop up slowly in 45 degrees with damped spring structure, have better security and convenience.



Image 4: An illustration demonstrating the soft pop-up mechanism, showing the cover slowly opening to reveal the outlets.

### To Close the Outlet:

- Ensure no plugs are inserted into the receptacles.
- Press the button again to release the locking mechanism.
- Gently push the cover down until it is flush with the surface and securely latched. The waterproof gasket will engage, protecting the internal components from dust and water.

## 7. MAINTENANCE

### Cleaning:

- Regularly wipe the stainless steel cover with a soft, damp cloth to remove dust and smudges.
- Avoid using abrasive cleaners or solvents, as these can damage the finish.
- Ensure the unit is closed and dry before cleaning.

### GFCI Testing:

- It is recommended to test the GFCI outlet monthly to ensure proper function.
- To test, press the 'TEST' button on the GFCI receptacle. The 'RESET' button should pop out, and power to the connected devices should be interrupted.

- To restore power, press the 'RESET' button. If the GFCI does not reset, or if it trips frequently, consult a qualified electrician.



Image 5: The WEBANG Pop Up Floor Outlet highlighting its waterproof design, ETL listing, upgraded version features, sponge gasket, and damping design.

## 8. TROUBLESHOOTING

If you encounter issues with your WEBANG Pop Up Floor Outlet, refer to the following common troubleshooting steps:

- **Outlet Not Popping Up Smoothly:** Ensure there is no obstruction around the cover. Check for debris in the mechanism. If the issue persists, the damping spring might require inspection by a professional.
- **GFCI Trips Frequently:** This indicates a ground fault. Unplug all devices from the outlet and try to reset the GFCI. If it still trips, there may be an issue with the wiring or the GFCI unit itself. Consult a qualified electrician.
- **No Power to Outlet:** Check your circuit breaker panel to ensure the breaker for the outlet is not tripped. If the GFCI has tripped, press the 'RESET' button. If power is still absent, verify wiring connections (with power off) or contact an electrician.
- **Cover Not Closing Flush:** Check for any obstructions preventing the cover from fully closing. Ensure the locking mechanism is not jammed.

## 9. WARRANTY AND SUPPORT

---

WEBANG is committed to providing quality products and services. If you have any questions about your product, require technical assistance, or need to inquire about warranty information, please contact WEBANG customer support. We aim to answer your questions within 24 hours.

For support, please refer to the contact information provided with your purchase or visit the official WEBANG website.