



Beghelli Infinita LED X5 CabLECom Emergency Luminaires Instruction Manual

[Home](#) » [Beghelli](#) » Beghelli Infinita LED X5 CabLECom Emergency Luminaires Instruction Manual 

Beghelli Infinita LED X5 CabLECom Emergency Luminaires Instruction Manual



Contents

[1 INSTALLATION](#)

[2 AUTOMATIC TESTS](#)


[PERIODICITY:](#)

[3 Documents / Resources](#)

[3.1 References](#)

[4 Related Posts](#)

INSTALLATION



AUTOMATIC TESTS PERIODICITY:

FUNCTIONAL TEST (30 sec)= every 28 days
 AUTONOMY TEST (1h)= every 26 weeks

Even lamps carry out the autonomy test 1 week after the odd lamps. (0,2,...,8,A,C,E)= even; (1,3,...,9,B,D,F)= odd. To perform the functions shown on the diagrams turn on and off the power when the red LED is lit.

LED SIGNALS

FIXED GREEN: BATTERY CHARGED

FLASHING GREEN: BATTERY CHARGING

ONE RED FLASH: BATTERY ERROR DURATION

Documents / Resources

	Beghelli Infinita LED X5 CabLECom Emergency Luminaires [pdf] Instruction Manual Infinita LED X5 CabLECom Emergency Luminaires, LED X5 CabLECom Emergency Luminaires, CabLECom Emergency Luminaires, Emergency Luminaires, Luminaires
	Beghelli Infinita LED X5 CableCom Emergency Luminaires [pdf] Instruction Manual Infinita LED X5 CableCom Emergency Luminaires, Infinita LED X5 CableCom, Emergency Luminares, Luminaires

References

-  [Lighting, LED, security systems](#)

Manuals+.