

Beijer
ELECTRONICS
Beijer
ELECTRONICS
GT-4524
Analog Output
Module



Beijer ELECTRONICS GT-4524 Analog Output Module User Manual


[Home](#) » [Beijer ELECTRONICS](#) » Beijer ELECTRONICS GT-4524 Analog Output Module User Manual 

Contents

- [1 Beijer ELECTRONICS GT-4524 Analog Output Module](#)
- [2 About This Manual](#)
- [3 Safety](#)
- [4 About the G-series System](#)
- [5 Specifications](#)
- [6 Wiring Diagram](#)
- [7 LED Indicator](#)
- [8 Data Value / Current](#)
- [9 Mapping Data From the Image Table](#)
- [10 Parameter Data](#)
- [11 Hardware Setup](#)
- [12 FAQ](#)
- [13 Documents / Resources](#)
 - [13.1 References](#)
- [14 Related Posts](#)

Beijer
ELECTRONICS

Beijer ELECTRONICS GT-4524 Analog Output Module



About This Manual

This manual contains information on the software and hardware features of the Beijer Electronics High Speed Counter Module. It provides in-depth specifications, guidance on installation, setup, and usage of the product.

Symbols Used in This Manual

This publication includes Warning, Caution, Note and Important icons where appropriate, to point out safety-related, or other important information. The corresponding symbols should be interpreted as follows:



WARNING

The Warning icon indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury, and major damage to the product.



CAUTION

The Caution icon indicates a potentially hazardous situation which, if not avoided, could result in minor or moderate injury, and moderate damage to the product.



NOTE

The Note icon alerts the reader to relevant facts and conditions.



IMPORTANT

The Important icon highlights important information

Safety

Before using this product, please read this manual and other relevant manuals carefully. Pay full attention to safety instructions!

In no event will Beijer Electronics be responsible or liable for damages resulting from the use of this product.

The images, examples and diagrams in this manual are included for illustrative purposes. Because of the many variables and requirements associated with any particular installation, Beijer Electronics cannot take responsibility or liability for actual use based on the examples and diagrams.

Product Certifications

The product has the following product certifications.



General Safety Requirements


WARNING

- Do not assemble the products and wires with power connected to the system. Doing so cause an “arc flash”, which can result in unexpected dangerous events (burns, fire, flying objects, blast pressure, sound blast, heat).
- Do not touch terminal blocks or IO modules when the system is running. Doing so may cause electric shock, short circuit or malfunction of the device.
- Never let external metallic objects touch the product when the system is running. Doing so may cause electric shock, short circuit or malfunction of the device.
- Do not place the product near inflammable material. Doing so may cause a fire.
- All wiring work should be performed by an electrical engineer.
- When handling the modules, ensure that all persons, the workplace and the packing are well grounded. Avoid touching conductive components, the modules contain electronic components that may be destroyed by electrostatic discharge.

CAUTION

- Never use the product in environments with temperature over 60°C. Avoid placing the product in direct sunlight.
- Never use the product in environments with over 90% humidity.
- Always use the product in environments with pollution degree 1 or 2.
- Use standard cables for wiring.

About the G-series System




System overview

- **Network Adapter Module** – The network adapter module forms the link between the field bus and the field devices with the expansion modules. The connection to different field bus systems can be established by each of the corresponding network adapter module, e.g., for MODBUS TCP, Ethernet IP, EtherCAT, PROFINET, CC-Link IE Field, PROFIBUS, CANopen, DeviceNet, CC-Link, MODBUS/Serial etc.
- **Expansion Module** – Expansion module types: Digital IO, Analog IO, and Special modules.
- **Messaging** – The system uses two types of messaging: Service messaging and IO messaging.

IO Process Data Mapping

An expansion module has three types of data: IO data, configuration parameter, and memory register. The data exchange between the network adapter and the expansion modules is made via IO process image data by internal protocol.



Data flow between network adapter (63 slots) and expansion modules

The input and output image data depend on the slot position and the data type of the expansion slot. The ordering of input and output process image data is based on the expansion slot position. Calculations for this arrangement are included in the manuals for network adapter and programmable IO modules.

Valid parameter data depends on the modules in use. For example, analog modules have settings of either 0-20 mA or 4-20 mA, and temperature modules have settings such as PT100, PT200, and PT500. The documentation for each module provides a description of the parameter data.

Specifications


Environmental Specifications

Operating temperature	-20°C – 60°C
UL temperature	-20°C – 60°C
Storage temperature	-40°C – 85°C
Relative humidity	5% – 90% non-condensing
Mounting	DIN rail
Shock operating	IEC 60068-2-27 (15G)
Vibration resistance	IEC 60068-2-6 (4 g)
Industrial emissions	EN 61000-6-4: 2019
Industrial immunity	EN 61000-6-2: 2019
Installation position	Vertical and horizontal
Product certifications	CE, FCC, UL, cUL

General Specifications

Power dissipation	Max. 70 mA @ 5 VDC
Isolation	I/O to logic: Photocoupler isolation
UL field power	Supply voltage: 24 VDC nominal, Class 2
Field power	Not used. Field power bypass to next expansion module
Wiring	IO cable max. 2.0 mm ² (AWG 14)
Torque	0.8 Nm (7 lb-in)
Weight	60 g
Module size	12 mm x 99 mm x 70 mm

Dimensions




Module dimensions (mm)

Output Specifications


Output per module	4 channels single ended, non-isolated between channel
Indicators (logic side)	4 green output status
Resolution in ranges	12 bits: 4.88 $\mu\text{V}/\text{Bit}$
Output range	-10 – 10 V
Data format	16 bits integer (2' compliment)
Module error	$\pm 0.1\%$ full scale @ 25 °C $\pm 0.3\%$ full scale @ -40 °C, 60 °C
Load resistance	Min 4 k Ω
Diagnostic	Field power off: LED blinking Field power on: No output LED off Field power on: Output LED on
Conversion time	0.2 ms / all channels
Calibration	Not required
Common type	4 channels / 4 common

Wiring Diagram



Pin no.	Signal description
0	Analog output channel 0
1	Analog output channel 1
2	Analog output channel 2
3	Analog output channel 3
4	Output channel common (AGND)
5	Output channel common (AGND)
6	Output channel common (AGND)
7	Output channel common (AGND)
8	Frame ground
9	Frame ground

LED Indicator



LED no.	LED function / description	LED color
0	OUTPUT channel 0	Green
1	OUTPUT channel 1	Green
2	OUTPUT channel 2	Green
3	OUTPUT channel 3	Green


LED Channel Status

Status	LED	Indication
Normal operation	Green	Normal operation
Field power error	All channels repeat green and off	Field power is unconnected

Data Value / Current

Current range: 4 – 20 mA

Current	4.0 mA	8.0 mA	12.0 mA	20.0 mA
Data(Hex)	H0000	H0400	H0800	H0FFF



Mapping Data From the Image Table

Output image value

Bit no.	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
Byte 0	Analog output Ch 0 low byte							
Byte 1	Analog output Ch 0 high byte							
Byte 2	Analog output Ch 1 low byte							
Byte 3	Analog output Ch 1 high byte							
Byte 4	Analog output Ch 2 low byte							
Byte 5	Analog output Ch 2 high byte							
Byte 6	Analog output Ch 3 low byte							
Byte 7	Analog output Ch 3 high byte							

Output module data – 8 byte output data

Analog output Ch 0
Analog output Ch 1
Analog output Ch 2
Analog output Ch 3

Parameter Data

Valid parameter length: 4 bytes

Bit no.	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
Byte 0	Fault action for channel 3		Fault action for channel 2		Fault action for channel 1		Fault action for channel 0	
	00: Fault value / 01: Hold last state / 10: Low limit / 11: High limit							
Byte 1	Not used							
Byte 2	Fault value low byte							
Byte 3	Not used				Fault value high byte			

Hardware Setup

CAUTION


- Always read this chapter before installing the module!
- Hot surface! The surface of the housing can become hot during operation. If the device is used in high ambient temperatures, always let the device cool down before touching it.
- Working on energized devices can damage the equipment! Always turn off the power supply before working on the device.

Space Requirements


The following drawings show the space requirements when installing the G-series modules. The spacing creates space for ventilation, and prevents conducted electromagnetic interference from influencing the operation. Installation position is valid vertical and horizontal. The drawings are illustrative and may be out of proportion.

CAUTION

NOT following the space requirements may result in damaging the product.



Vertical and horizontal space requirements



Required distance to door

Mount Module to DIN Rail

The following chapters describe how to mount the module to the DIN rail.

CAUTION

The module must be fixed to the DIN rail with the locking levers.

Mount GL-9XXX or GT-XXXX Module

The following instructions apply to these module types:

- GL-9XXX
- GT-1XXX
- GT-2XXX
- GT-3XXX
- GT-4XXX
- GT-5XXX
- GT-7XXX

GN-9XXX modules have three locking levers, one at the bottom and two on the side. For mounting instructions, refer to Mount GN-9XXX Module.




Mount to DIN rail




Dismount from DIN rail

Mount GN-9XXX Module

To mount or dismount a network adapter or programmable IO module with the product name GN-9XXX, for example GN-9251 or GN-9371, see the following instruction




Mount to DIN rail



Dismount from DIN rail

Mount Removable Terminal Block

To mount or dismount a removable terminal block (RTB), see the instructions below.




Connect Cables to Removable Terminal Block


To connect/disconnect cables to/from the removable terminal block (RTB), see the instructions below.

WARNING

Always use the recommended supply voltage and frequency to prevent damage to the equipment and ensure optimal performance.



Connect cable




Remove cable

Field Power and Data Pins

Communication between the G-series network adapter and the expansion module, as well as system / field power supply of the bus modules is carried out via the internal bus. It is comprised of 2 Field Power Pins and 6 Data Pins.

WARNING

Do not touch the data and field power pins! Touching can result in soiling and damage by ESD noise.



Pin no.	Name	Description
P1	System VCC	System supply voltage (5 VDC)
P2	System GND	System ground
P3	Token output	Token output port of processor module
P4	Serial output	Transmitter output port of processor module
P5	Serial input	Receiver input port of processor module
P6	Reserved	Reserved for bypass token
P7	Field GND	Field ground
P8	Field VCC	Field supply voltage (24 VDC)

FAQ


- **Q: What should I do if the LED indicator does not light up?**

A: Check the power supply and wiring connections to ensure proper installation. If the issue persists, contact customer support for further assistance.

- **Q: Can I use this module in outdoor environments?**

A: The environmental specifications recommend using the module in indoor environments to prevent damage from exposure to extreme weather conditions.

Documents / Resources

	<p>Bejer ELECTRONICS GT-4524 Analog Output Module [pdf] User Manual GT-4524 Analog Output Module, GT-4524, Analog Output Module, Output Module, Module</p>
--	--

References

- [User Manual](#)

[Manuals+](#), [Privacy Policy](#)

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.