



CALYPSO CMI1018 Ultra Low Power Ultrasonic STD Wind Meter User Manual

[Home](#) » [CALYPSO](#) » CALYPSO CMI1018 Ultra Low Power Ultrasonic STD Wind Meter User Manual 

Contents

- [1 CALYPSO CMI1018 Ultra Low Power Ultrasonic STD Wind Meter](#)
- [2 Product Information](#)
- [3 Product Package Content](#)
- [4 Product Technical Specifications](#)
- [5 Product Usage](#)
- [6 Product overview](#)
- [7 Package content](#)
- [8 Technical specifications](#)
- [9 Configuration Options](#)
- [10 Communication Protocols](#)
- [11 General information](#)
- [12 Warranty](#)
- [13 Documents / Resources](#)
 - [13.1 References](#)
- [14 Related Posts](#)



CALYPSO CMI1018 Ultra Low Power Ultrasonic STD Wind Meter



Product Information

The Calypso Ultra-Low-Power Ultrasonic STD (ULP STD) Wind Meter is a portable device that measures wind speed and direction. It has been designed to be reliable and easy to use, with no mechanical parts that require maintenance. The device uses ultrasonic transducers to communicate wind information and has a sample rate of 0.1 Hz to 10 Hz. The ULP STD has a weight of 210 grams and can be powered with 3.3-18V. The device is available with different data interface options and can be mounted on various surfaces with different accessories.

Product Package Content

- Calypso Ultra-Low-Power Ultrasonic STD Wind Meter
- User Manual (English Version 1.0)


Product Technical Specifications

Technical Specification	Value
Dimensions	65mm
Weight	210 grams (7.4 ounces)
Power Consumption	Ultra-Low-Power (RS485 NMEA0183) : 0,25mA @5V, 1Hz / (MODBUS) : 1 mA @5V, 1 Hz. Ultra-Low-Power (UART / I2C) : 0,15 mA @5V, 1Hz. Ultra-Low-Power NMEA 2000: 20 mA @115.200 bauds, 12V.
Transducers	Ultrasonic transducers (4x)
Sample Rate	0.1 Hz to 10 Hz

Product Usage

1. Mount the ULP STD on a flat surface or a tube with the provided screws.
2. Make sure the north mark is perfectly aligned with the north.
3. Connect the device to a power source with the correct voltage range.
4. Select the desired data interface and configure it according to your needs.
5. The ULP STD will start measuring wind speed and direction automatically.

Symbols



Product overview

Thank you for choosing the ULP STD wind meter from Calypso Instruments. This is the first model of our generation II, representing an important technology breakthrough condensing an extensive R+D investment:

- Both shape and firmware have been enhanced for an improved rain performance. This is key for static applications such as weather stations.
- Mechanical design has been revamped making the unit more robust and dependable.
- We feel very proud to release a unit that requires under 0.4 mA of power at 5V, sampling at 1Hz.
- Different output options available: RS485, UART-TTL, MODBUS and NMEA 2000.

Applications for the ULP STD are the following: Weather Stations | Drones
Temporary Scaffolding and construction | Infra-structures and building | Cranes
Spraying | Irrigation | Fertilizing | Precision Agriculture
Smart Cities | Wild fires | Shooting | Scientific Sailing.



Package content

The package contains the following:

- Ultrasonic ULP STD Wind Instrument plus 2 meter (6.5 ft) cable for connection*
- Serial number reference on the side of the packa-ging.
- A quick user guide on the back of the packaging and some more useful information for the custo-mer.
- M4 headless screw (x6) *
- M4 screw (x3)*

*Non applicable to the ULP NMEA 2000 model.

Technical specifications

The ULP has the following technical specifications:

Dimensions

- **Diameter:** 68 mm (2.68 in.)
- **Height:** 65 mm (2.56 in.)



Weight

210 grams (7.4 ounces)

Power

- 3.3-1 VDC
- 6-15VDC (NMEA 2000)

The ULP STD has to be connected as shown in this section.



RS485/MODBUS RTU Output:

White GND (Power -)	Yellow DATA (B -)
Brown VCC (Power +)	Green DATA (A +)

RS485/MODBUS RTU Output:

White GND (Power -)	Yellow DATA Rx
Brown VCC (Power +)	Green DATA Tx

Data interface	1Autotransmit 2-POLL telegram 3-MODBUS
Data format	NMEA0183
Baudrate	2400 to 115200 bauds
Voltage range	3.3-18V

Power consumption:

- **Ultra-Low-Power (RS485 NMEA0183)** : 0,25mA @5V, 1Hz / (MODBUS) : 1 mA @5V,1 Hz.
- **Ultra-Low-Power (UART / I2C)**: 0,15 mA @5V, 1Hz.
- **Ultra-Low-Power NMEA 2000**: 20 mA @115.200 bauds, 12V.

The ULP has been designed to avoid any mechanical parts to maximize reliability and minimize maintenance. The transducers communicate between themselves two by two using ultrasonic range waves. Each pair of transducers calculates the signal delay and get information about both wind direction and wind speed.

Wind Information

- Wind speed
- Wind direction

Sample rate: 1 Hz

Wind Speed

- **Range :** Range: 0 to 45 m/s (1.12 to 100 mph)
- **Accuracy:** ± 0.1 m/s at 10m/s (0.22 at 22.4 mph)
- **Threshold:** 1 m/s (2.24 mph)

Wind direction

- **Range:** 0 – 359°
- **Accuracy:** $\pm 1^\circ$


Easy mount

- 3 x M4 lateral female tripod thread
- 3 x M4 base female tripod thread UNC 1/4" – 20

It can be mounted either on a plate (inferior screws) or on a tube (lateral screws).

Noth mark position

Make sure the north mark is perfectly aligned to the north.



Mounting accessories

A wide range of accessories can be used with the device.

The ULP STD can be mounted on a flat surface and screwed on to different sizes of poles. It can also be used with an adaptor for poles of 39 mm.

* Please, visit our website and check all the accessories available and their possible combinations.



*Non applicable to the ULP NMEA 2000 model.



*Non applicable to the ULP NMEA 2000 model.



Firmware

- Upgradable via RS485, MODBUS , UART/TTL or NMEA 2000.

Product Material

The ULP STD is engineered to be a robust device with minimal downtime. This new shape has been designed for optimum water spillage which implies lower probability of ice formation. Frost might affect measurements if it blocks the wave path. The input wires are protected by Transient Voltage Suppression (TVS) diodes. The instrument body is built with Polyamide.

Quality Control

Every single unit is calibrated with accuracy, following the same calibration standards for each one in a wind tunnel.

A Q/C report for both wind speed and direction is generated and kept in our files. Standard deviation is checked to guarantee that each unit has been calibrated to the highest standards.

Configuration Options

*Non applicable to the ULP NMEA 2000 model.

The ULP STD can be set up by using a special configuration app made by Calypso Instruments.

In order to use the app, you should download the configurator from our website at


www.calypsoinstruments.com.

To configure your device, connect the ULP via either a USB to RS485 converter cable (in case of the ULP RS485 or the ULP Modbus) or via a USB to UART converter cable (in case of the ULP UART). Connect all the ULP cables except for the brown cable to the converter. Insert the USB into the computer, open the configurator app, select the configuration wanted and follow the instructions on the screen to finish the configuration.

For more information, please watch the following video. <https://bit.ly/3DuA7IM>

*USB converter cables available on calypsoinstruments.com.

- **baudrate:** 2400 to 115200 (8n1) bauds
- **output rate:** 0.1 to 10 Hertz
- **output units:** m/sec., knots or km/h



Communication Protocols

*Non applicable to the ULP NMEA 2000 model.

Modbus Registers

- DIR_BASE_LA1 30001
- SYSTEM_STATUS DIR_BASE_LA1 + 200
- WIND_SPEED DIR_BASE_LA1 + 201
- WIND_DIRECTION DIR_BASE_LA1 + 202
- TWO_MIN_AVG_WS DIR_BASE_LA1 + 203
- TWO_MIN_AVG_WD DIR_BASE_LA1 + 204
- TEN_MIN_AVG_WS DIR_BASE_LA1 + 205
- TEN_MIN_AVG_WD DIR_BASE_LA1 + 206
- WIND_GUST_SPEED DIR_BASE_LA1 + 207
- WIND_GUST_DIR DIR_BASE_LA1 + 208
- FIVE_MIN_AVG_WS DIR_BASE_LA1 + 210
- FIVE_MIN_AVG_WD DIR_BASE_LA1 + 211
- FIVE_WIND_GUST_SPEED DIR_BASE_LA1 + 212
- FIVE_WIND_GUST_DIR DIR_BASE_LA1 + 213

RS485 and UART Sentences

MWV Wind Speed and Angle

1 2 3 4 5

|||||

\$-MWV,x.x,a,x.x,a*hh

1. Wind Angle, 0 to 360 degrees
2. Reference, R = Relative, T = True
3. Wind Speed
4. Wind Speed Units, K/M/N
5. Status, A = Data Valid
6. Checksum

MWV Sentence 38400bps 8N1

The connection is straightforward with no configuration required.

The hardware interface is RS485, 4800bps, 8N1. The logical interface NMEA0183 has MWV ASCII simple phrases with direction and wind speed being the following:

- \$IIMWV,316,R,06.9,N,A*18
- \$IIMWV,316,R,06.9,N,A*18
- \$IIMWV,316,R,06.8,N,A*19
- \$IIMWV,316,R,06.8,N,A*19
- \$IIMWV,316,R,06.8,N,A*19

I2C Sentences

General Options

Address I2C- 0x15 (21 decimal)

Frequency -100kHz – 400kHz

SDA -TX (Yellow)

SCL – RX (Green)

Write Register

In order to write about the register it is necessary to write

Write Register (continuation)

2 bytes, the I2C bus direction and the register you need to check.

I2C Address (1 Byte) + Register Address (1 Byte)

Address -0x15 (21 decimal)

Available Registers:

- Wind Raw Stat – 0x10
- Wind 2 Min Stat – 0x12
- Wind 5 Min Stat – 0x15
- Wind 10 Min Stat – 0x1A
- Wind Full Stats – 0x1F

Read Register

For the read register we need to take into account how many bytes is the system giving us back and what bytes we need to read in order to obtain the value we need.

Data are under big-endian criteria. The first byte, the more valuable one to be represented.

E.g. If 2 bytes are read, byte 0 and byte 1, we will read the first byte as 0x05 and second byte 0x0A.



The first byte is marked in orange. The more valuable one. The second byte is marked in blue (less significant one LSB).

Write Wind Raw Register Return 7 Bytes

- Bytes 0 – 1 – Unused
- Bytes 2 – 3 – Wind Speed * 100
- Bytes 4 – 5 – Wind Direction * 100
- Byte 6 – Checksum

Write Wind 2 Min Stat Register Return 11 Bytes

- Bytes 0 – 1 – Unused
- Bytes 2 – 3 – Wind Speed * 100
- Bytes 4 – 5 – Wind Direction * 100
- Bytes 6 – 7 – Wind Speed Gust * 100
- Bytes 8 – 9 – Wind Direction Gust * 100
- Byte 10 – Checksum

Write Wind 5 Min Stat Register Return 11 Bytes

- Bytes 0 – 1 – Unused
- Bytes 2 – 3 – Wind Speed * 100
- Bytes 4 – 5 – Wind Direction * 100
- Bytes 6 – 7 – Wind Speed Gust * 100
- Bytes 8 – 9 – Wind Direction Gust * 100
- Byte 10 – Checksum

Write Wind 10 Min Stat Register Return 11 Bytes

- Bytes 0 – 1 – Unused
- Bytes 2 – 3 – Wind Speed * 100
- Bytes 4 – 5 – Wind Direction * 100
- Bytes 6 – 7 – Wind Speed Gust * 100
- Bytes 8 – 9 – Wind Direction Gust * 100
- Byte 10 – Checksum

Write Wind Full Stat Register Return 31 Bytes

- Bytes 0 – 1 – Unused

- Bytes 2 – 3 – Wind Speed Raw * 100
- Bytes 4 – 5 – Wind Direction Raw * 100
- Bytes 6 – 7 – Wind Speed 2 Min Stat * 100
- Bytes 8 – 9 – Wind Direction 2 Min Stat * 100
- Bytes 10 – 11 – Wind Speed Gust 2 Min Stat * 100
- Bytes 12 – 13 – Wind Direction Gust 2 Min Stat * 100
- Bytes 14 – 15 – Wind Speed 5 Min Stat * 100
- Bytes 16 – 17 – Wind Direction 5 Min Stat * 100
- Bytes 18 – 19 – Wind Speed Gust 5 Min Stat * 100
- Bytes 20 – 21 – Wind Direction Gust 5 Min Stat * 100
- Bytes 22 – 23 – Wind Speed 10 Min Stat * 100
- Bytes 24 – 25 – Wind Direction 10 Min Stat * 100
- Bytes 26 – 27 – Wind Speed Gust 10 Min Stat * 100
- Bytes 28 – 29 – Wind Direction Gust 10 Min Stat * 100
- Byte 30 – Checksum

General information

General recommendations

Wind Speed Gust is that value that measures abrupt and sudden change in wind speed.

Regarding mounting the unit, align the north mark of the ULP towards the north.

Regarding mounting the unit, the mast head has to be prepared for the mechanical installation. Align the North mark of the Ultrasonic Ultra-Low-Power to the north. Make sure to install the sensor in a location free from wind perturbation, usually on the mast head.

Make sure to install the sensor in a location free from anything that obstructs the flow of wind to the sensors within a 2 meter radius, for example, the mast head on a boat.

Other important aspects:

- Do not attempt to access the transducers area with your fingers;
- Do not attempt any modification to the unit;
- Never paint any part of the unit or alter its surface in any way.
- NOT allow to be submerged fully or partially in water.

If you have any questions or doubts, please contact us directly.

Maintenance and repair

- The ULP does not require great maintenance thanks to the lack of the moving parts in this new design.
- Transducers must be kept clean and aligned. Impacts or incorrect impulsive handling may lead to transducers misalignment.

Maintenance and repair (continuation)

- The space around the transducers must be empty and clean. Dust, frost, water, etc... will make the unit's top working.
- The ULP can be wiped clean with a damp cloth being careful to not touch the transducers.

Warranty

This warranty covers the defects resulting from defective parts, materials and manufacturing, if such defects are revealed during the 24 months after the purchase date.

Warranty is void in case of non-following the instructions of use, repair or maintenance without written authorisation.

Any wrongful use given by the user will not incur in any responsibility on part of Calypso Instruments. Therefore, any harm caused to the ULP by a mistake will not be covered by the warranty. Using assembly elements different from those delivered with the product will void the guarantee.

by the warranty. Using assembly elements different from those delivered with the product will void the guarantee. Changes on transducers position/alignment will avoid any warranty.

For further information please contact Calypso Technical Support through sales@calypsoinstruments.com or visit www.calypsoinstruments.com.

MODBUS Sensor Data Requests

Measurements all have a resolution of 0.1 but are reported as 10*. 8.2 m/s is returned as a value 82. The user must /10 in order to reinsert the decimal precision.


Address	Register	Access Type	Response Range	Data Type	Description
200	201	Read	0 to 15†	16-bit Signed Int	System Status†
201	202	Read	0 to 500*	16-bit Signed Int	Wind speed (m/s) (3 second moving average)
202	203	Read	0 to 3599*	16-bit Signed Int	Wind direction (°) (3 second moving average)
203	204	Read	0 to 500*	16-bit Signed Int	2 min avg wind speed
204	205	Read	0 to 3599*	16-bit Signed Int	2 min avg wind direction
205	206	Read	0 to 500*	16-bit Signed Int	10 min avg wind speed
206	207	Read	0 to 3599*	16-bit Signed Int	10 min avg wind direction
207	208	Read	0 to 500*	16-bit Signed Int	Wind gust speed
208	209	Read	0 to 3599*	16-bit Signed Int	Wind gust direction
210	211	Read	0 to 500*	16-bit Signed Int	5 min avg wind speed
211	212	Read	0 to 3599*	16-bit Signed Int	5 min avg wind direction
212	213	Read	0 to 500*	16-bit Signed Int	5 min Wind gust speed
213	214	Read	0 to 3599*	16-bit Signed Int	5 min Wind gust direction

If not applicable to ULP-M, the register should report a value of zero (0).* See Data Format section for numeric conversions.

Ultra-Low-Power Ultrasonic wind meter STD (ULP STD)
User manual English version 2.0

www.calypsoinstruments.com

Documents / Resources

 <p>CALYPSO ULTRA-LOW-POWER ULTRASONIC STD (ULP STD) 000401-147100 User Manual</p> <p>CE</p>	<p>CALYPSO CMI1018 Ultra Low Power Ultrasonic STD Wind Meter [pdf] User Manual</p> <p>ULP STD, CMI1018 Ultra Low Power Ultrasonic STD Wind Meter, CMI1018, Ultra Low Power Ultrasonic STD Wind Meter, Ultrasonic STD Wind Meter, STD Wind Meter, Wind Meter, Meter</p>
---	---

References

- [!\[\]\(36f8637baaa56c4be44b454435949289_img.jpg\) Calypso Instruments](#)
- [!\[\]\(b556e0ef1e10ccfc32976edb6416074f_img.jpg\) YouTube](#)