


CERBERUS MM-35 System 3 Meter Module Owner's Manual

Home » CERBERUS » CERBERUS MM-35 System 3 Meter Module Owner's Manual



MM-35 System 3™ Accessory Module



Contents

- 1 ENGINEER AND ARCHITECT SPECIFICATIONS
- 2 Description
- **3 Electrical Information**
- 4 Documents / Resources
 - 4.1 References
- **5 Related Posts**

ENGINEER AND ARCHITECT SPECIFICATIONS

Meter Module

- Voltmeter
- Ammeter
- Listed and ULC Listed
- NYMEA, CSFM and FM Approved

Description

The Cerberus Piezotronics Meter Module, Model MM-35, is designed to provide visual indication of both battery voltage and charging current. It is used in conjunction with Battery Charger Modules, Models BC-35, BE-35 and in systems fitted with emergency standby power.

Both a voltmeter and an ammeter are contained in the MM-35. The voltmeter provides a voltage reading value of the battery at all times while the ammeter shows the charging current.

The Model MM-35 is placement supervised, providing a system trouble signal upon removal from the system.

The Model MM-35 is Underwriters Laboratories, Inc. listed.

Engineer and Architect Specifications

Two meters shall be provided, mounted in a single module assembly for the purpose of indicating the battery voltage and the battery charging current. This module, Cerberus Piezotronics Meter Module Model MM-35, shall be system interconnected by a plug and harness assembly and shall be operable with the main control panel.

The Meter Module, Model MM-35, shall only be used in conjunction with the Battery Charger Module, Model BC-35 and BE-35.

The Model MM-35 shall be placement supervised and shall be Underwriters Laboratories, Inc. listed.


Electrical Information

Current Requirement: Normal — None

Ordering Information

Model No.	Description	Shipping Wt.
MM-35	Meter Module	1 lb. (.45 kg.)

Typical Wiring





IntoLINK SYSTEMS: SERVICES

Cerberus Piezotronics
8 Ridgedale Avenue
Cedar Knolls, NJ 07927
Tel: (201) 267-1300
FAX: (201) 397-7008
Cerberus Piezotronics
50 East Pearce Street
Richmond Hill, Ontario
L4B, 1B7 CN
Tel: (905) 764-8384
FAX: (905) 731-9182
4/96 10M CPY-IG
Printed in U.S.A.

April 1995

Supersedes sheet dated 5/95

firealarmresources.com

Documents / Resources



<u>CERBERUS MM-35 System 3 Meter Module</u> [pdf] Owner's Manual MM-35, MM-35 System 3 Meter Module, System 3 Meter Module, Module

References

• <u>Fire Alarm Resources</u> Download fire alarm documents

Manuals+,