#### **Danfoss 1C Electronic Superheat Controller**





# **Danfoss 1C Electronic Superheat Controller Instruction Manual**

Home » Danfoss » Danfoss 1C Electronic Superheat Controller Instruction Manual



#### **Contents**

- 1 Danfoss 1C Electronic Superheat Controller
- **2 Product Information**
- 3 Introduction
- **4 Applications And Dimensions**
- **5 TECHNICAL SPECIFICATIONS**
- **6 GENERAL FEATURES AND WARNINGS**
- 7 DIN rail mounting / demounting
- **8 Connection Overview**
- 9 Sensor Mounting
- 9.1 Cable And Wiring
- 10 Valve Cable Connection
- 11 LED indication
- 12 USER INTERFACE
- 13 Danfoss MMIGRS2 display
  - 13.1 Setup wizard via MMIGRS2 display
- 14 Quick guide for parameter selection
- 15 EKE 1C Commonly used parameter identification
- **16 Related Products**
- 17 Documents / Resources
  - 17.1 References



**Danfoss 1C Electronic Superheat Controller** 



## **Product Information**

# **Technical Specifications**

- I/O Type: Analog inputs, Voltage Current NTC, Pt 1000
- Auxiliary Supplies: Digital inputs, Voltage free contacts, Digital output
- Communication: RS-485 RTU Communication, CAN
- Max. 15 V input voltage: Do not connect voltage sources to unpowered units without limiting the current to analog inputs (overall 80 mA).

## **FAQ**

- Q: What is the maximum drive voltage for stepper valves?
  - A: The maximum drive voltage for stepper valves is 40 V.

### Introduction

Superheat controller EKE 1C is for use where superheat must be accurately controlled, typically in commercial air conditioning, heat pumps, commercial refrigeration, food retailing and industrial applications.

Compatible valves: Danfoss ETS 6, ETS 8M (Bipolar) / ETS / ETS Colibri® / ETS L, KVS / KVS Colibri® and


CCM / CCMT / CCMT L / CTR valves.

Reference: For details please see EKE data sheet.


# **Applications And Dimensions**

# **Applications**


Superheat controller: standalone / network



# Valve driver



**Dimensions EKE 1C** 



• Weight: 190 gram

# **TECHNICAL SPECIFICATIONS**

# **POWER SUPPLY**

- EKE has galvanic isolation by switch-mode power supply.
- 24 V AC  $\pm$  20 %, 50/60 Hz. Maximum power consumption: 18 VA.
- Input voltage rating (DC): 24 V DC  $\pm$  20%, 15 W.

I/O	ТҮРЕ	NUMBE R	SPECIFICATION
			Max. 15 V input voltage
			Do not connect voltage sources to unpowered units without limiting the current to analog inputs (overall 80 mA).
			Open circuit HW diagnostics available for voltage input on: Al3 and Al4
			AI3, AI4
	Voltage		0 – 5 V, 0 – 5 V ratiometric, 0 – 10 V
		2	AI3, AI4
	Current	_	0 – 20 mA
	NTC		Al1 (S3/S4), Al2 (S2), Al5 (S3/S4)
			NTC temperature probes, 10 k0 at 25 °C
	Pt 1000	3	Al1 (S3/S4), Al2 (S2)
			Accuracy: ≤ 0.5 K Resolution: 0.1 K.
Analog in			Range: 723 0 to 1684 0
puts			5 V +
		1	Sensor supply: 5 VDC / 50 mA, overload protection approximately 150 mA
	Auxiliary Supplies	1	15 V +
			Sensor supply: 15 VDC / 30 mA, overload protection approximately 200 mA
			DI1, DI2
Digital in	Voltage free c ontacts		Steady current minimum 1mA Cleaning current 100mA at 15 V DC On: RIL < = 300 0
puts		2	Off: RIH > = 3.5 k 0

Digital ou tput	Relay	1	C1-NO1  Normally Open: 3 A General purpose, 250 V AC, 100 k cycle Normally Open: 3 A Inductive (AC-15), 250 V AC, 100 k cycle Normally Closed: 2 A General purpose, 250 V AC, 100 k cycle
Stepper	Bipolar / unipolar	1	Stepper valves: A1, A2, A3, A4  Bipolar stepper motor output:  - Danfoss ETS 6 / ETS 8M (Bipolar) / ETS C / ETS L / KVS / KVS C / CC MT 2 - CCMT 42 / CCMT L / CTR Valves  Other Valves:  - speed 10 - 400 pps  - drive mode 1/8 microstep  - max. peak phase current: 1.2 A (848 mA RMS)  - max. drive voltage 40 V  - max. output power 12 W
Battery b ackup		1	<ul> <li>VBATT: 18 – 24 V DC (24 V DC recommended):</li> <li>max. battery current: 850 mA at 18 V</li> <li>battery alarm will be activated below 16 V DC and above 27 V DC</li> </ul>
Communi	RS-485 RTU	1	RS485 Galvanic isolation. No Built-in termination.
- cation	CAN	1	CAN – RJ  RJ connector to directly connect and supply a MMI.

# **GENERAL FEATURES AND WARNINGS**

# **PLASTIC HOUSING FEATURES**

- DIN rail mounting complying with EN 50022
- Self-extinguishing V0 according to IEC 60695-11-10 and glowing/hot wire test at 960 °C according to IEC 60695-2-12
- Ball test: 125 °C according to IEC 60730-1. Leakage current: ≥ 250 V according to IEC 60112

# **OTHER FEATURES**

- Operating conditions CE: -20T60, 90% RH non-condensing
- Storage conditions: -30T80, 90% RH non-condensing
- To be integrated in Class I and/or II appliances
- Index of protection: IP 20 on product and IP40 only on the front cover
- Period of electric stress across insulating parts: long
- · Suitable for using in a normal pollution environment
- Category of resistance to heat and fire: D
- Immunity against voltage surges: category II
- Software class and structure: class A

#### **CE COMPLIANCE**

This product is designed to comply with the following EU standards:

- Low voltage guideline: 2014/35/EU
- Electromagnetic compatibility EMC: 2014/30/EU and with the following norms:
- EN61000-6-1, EN61000-6-3 (immunity for residential, commercial and light-industrial environments)
- EN61000-6-2, EN61000-6-4 (immunity and emission standard for industrial environments)
- EN60730 (Automatic electrical controls for household and similar use)

### **GENERAL WARNINGS**

- Every use that is not described in this manual is considered incorrect and is not authorized by the manufacturer
- Verify that the installation and operating conditions of the device respect those specified in the manual, especially concerning the supply voltage and environmental conditions
- This device contains live electrical components. All service and maintenance operations must therefore be performed by qualified personnel
- The device must not be used as a safety device
- · Liability for injury or damage caused by the incorrect use of the device lies solely with the user

### **INSTALLATION WARNINGS**

- · Recommended mounting position: vertical
- Installation must comply with local standards and legislation
- Before working on the electrical connections, disconnect the device from the main power supply
- Before carrying out any maintenance operations on the device, disconnect all electrical connections
- For safety reasons the appliance must be fitted inside an electrical panel with no live parts accessible
- Do not expose the device to continuous water sprays or to a relative humidity greater than 90%.
- Avoid exposure to corrosive or pollutant gases, natural elements, environments where explosives or mixes of
  flammable gases are present, dust, strong vibrations or shock, large and rapid fluctuations in ambient
  temperature that might cause condensation in combination with high humidity, strong magnetic and/or radio
  interference (e.g. transmitting antennae)
- · When connecting loads be aware of the maximum current for each relay and connector
- Use cable ends suitable for the corresponding connectors. After tightening connector screws, tug the cables

- gently to check their tightness
- Use appropriate data communication cables. Refer to the EKE data sheet for the kind of cable to be used and setup recommendations
- Minimize the length of probe and digital input cables as much as possible, and avoid spiral routes around power devices. Separate from inductive loads and power cables to avoid possible electromagnetic noises
- Avoid touching or nearly touching the electronic components fitted on the board to avoid electrostatic discharges

# **PRODUCT WARNINGS**



- Use a class II category transformer for 24 V AC power supply.
- Connecting any EKE inputs to mains voltage will permanently damage the controller.
- Battery Backup terminals does not generate power to recharge a device connected.
- Battery backup the voltage will close the stepper motor valves if the controller loses its supply voltage.
- Do not connect an external power supply to the digital input DI terminals to avoid damaging the controller.

# DIN rail mounting / demounting







- The unit can be mounted onto a 35 mm DIN rail simply by snapping it into place and securing it with a stopper to prevent sliding.
- It is demounted by gently pulling the stirrup located in the base of the housing.

# **Connection Overview**


**Connection Overview: EKE 1C** 



**EKE 1C – Front board connection overview** 





EKE 1C - Back board connection overview



# **Sensor Mounting**

Sensor mounting: Temperature sensor






- Mount the sensor on a clean paint-free surface.
- Remember to use heat conducting paste and insulate the sensor.
- For precise measurements, mount the sensor max. 5 cm from the outlet of the evaporator.

## **Pressure transmitter**

- Installation of the pressure transmitter is less critical. However, the pressure transmitter should be closer to the temperature sensor, right after the evaporator and with its head upright. It is a good practice to select a pressure transmitter with an average load of 40 60% of full scale.
- Pressure transmitter values can be shared with multiple EKE 1C via CANbus.

# **Power supply**



- Power sharing is allowed in EKE controller.
- It is a good practice not to reverse the polarity of the power connection cables. Selection of the common power supply depends on the total number of sharings and the valve in use.

### **Relay Outputs**

## EKE 1C has 1 relay output:

- Type SPDT relay. Digital Output can be used to connect either a solenoid valve or an alarm.
- The relays cannot be used for the direct connection of capacitive loads such as LEDs and ON/OFF control of EC motors. All loads with a switch-mode power supply must be connected with a suitable contactor or similar.

### Cable length

EKE controller supports the following max. cable length.

	Cable length	Wire size min. / max.	
	[m]	[mm2]	
Analog inputs (Voltage)	max. 10	0.14 / 1.5	
Temperature sensor	max. 10 *)	_	
Stepper valve connection	max. 30	0.14 / 1.5	
Power supply	max. 5	0.2 / 2.5	
Digital input	max. 10	0.14 / 1.5	
Digital output	_	0.2 / 2.5	
Digital MMI	max. 3 over CAN RJ	_	
Communication bus	max. 1000	0.14 / 1.5	

### **Cable And Wiring**

## Cable and wiring \*)

- The max. cable distance between the controller and the valve depends on many factors like shielded/ unshielded cable, the wire size used in the cable, the output power for the controller and EMC.
- Keep controller and sensor wiring well separated from mains wiring.
- Connecting sensors by wires more than the specified length may decrease the accuracy of measured values.


### Warning

Separate the sensor and digital input cables as much as possible (at least 10 cm) from the power cables to theloads to avoid possible electromagnetic disturbance. Never lay power cables and probe cables in the same conduits (including those in the electrical panels).

# **Connecting Modbus**

- For the MODbus cable, it is best to use 24 AWG shielded twisted-pair cable with a shunt capacitance of 16 pF/ft and  $100\Omega$  impedance.
- The controller provides an insulated RS485 communication interface which is connected to the RS485 terminals (see connection overview).
- The max. permissible number of devices simultaneously connected to RS485 cable output is 32.
- The RS485 cable is of impedance  $120\Omega$  with maximum length of 1000 m.
- Terminal resistors  $120\Omega$  for terminal devices are recommended at both ends.
- The EKE communication frequency (baud rate) can be one of the following: 9600, 19200 or 38400 baud, default 19200 8 E 1.
- The default unit address is 1, which can be changed using parameter "G001 Controller adr.".

#### **Modbus**



### For a detailed explanation of Modbus installation and setting software parameters, see:

Data sheet for "EKE Superheat controller" and "EKD EIM Data Communication Modbus RS485 RTU".

# **Stepper Motor Output**

- All valves are driven in a bipolar mode with a 24V supply chopped to control the current (Current driver).
- The stepper motor is connected to the "Stepper Valve" terminals (see terminal assignment) with a standard M12 connection cable.
- To configure stepper motor valves other than Danfoss stepper motor valves, the correct valve parameters must be set as described in the Valve configuration section (see manual for details).
- The default valve setting in EKE 1C is: none.
- The correct valve must be defined in "Valve configuration", i.e. parameter 1067. An overview of valve types is given in the "Parameter identification" section.

# **Valve Cable Connection**

Stepper valve connector	ETS/KVS/CCM/ CCMT/CTR/ CCMT L (Using Danfoss M12 Cable)	ETS 8M Bipola	ETS 6
A1	White	Orange	Orange
A2	Black	Yellow	Yellow
B1	Red	Red	Red
B2	Green	Black	Black
Not connected	_	_	Grey

# Warning

- All valves are driven in a bipolar mode with a 24 V supply chopped to control the current (Current driver).
- The stepper motor is connected to the "Stepper Valve" terminals (see terminal assignment) with a standard M12 connection cable.
- To configure stepper motor valves other than Danfoss stepper motor valves, the correct valve parameters must be set as described in the Valve configuration section by selecting user defined valve.

# Guideline for long M12 cables on Danfoss stepper motor valves

- Long cables will lead to degradation of performance.
- You can overcome this degradation by changing the settings for the valve driver. This guideline is based on the cable type being the same type as the standard Danfoss stepper motor cable.


# Recommended wire size and cable distance between EKE controller and stepper motor valve

Cable length	1 m – 15 m	15 m – 30 m
Wire diameter	0.52 / 0.33 mm2 (20 / 22 AWG)	0.33 mm2 (20 AWG)

# Parameter setting for long M12 cable

	0 m – 15 m cable 15 m – 30 m cable				
Product	Update following parameter				
ETS 12C – ETS 100C KVS 2C – KVS 5C	Use default values I028 Valve drive current= 925 mA pe				
ETS 12.5 – ETS 400					
KVS 15 – KVS 42					
CTR 20					
CCMT 2 – CCMT 8	Use default values	I028 Valve drive current= 200 mA peak			
CCM 10 – CCMT 40					
ETS 6	Use default values	I028 Valve drive current= 270 mA peak			
CCMT 0	Use default values	I028 Valve drive current= 270 mA peak			
CCMT 1	Use default values	I028 Valve drive current= 400 mA peak			
CCMT 16 – CCMT 42	Use default values	I028 Valve drive current= 450 mA peak			

# **LED** indication



- (A) Two status LEDs to indicate operational status
  - Steady green = power ON
  - Flashing green = data transmission / initialization
  - Flashing red = alarm / error condition
- (B) Two status LEDs to indicate valve operation

- Flashing red = valve closing
- Steady red = valve fully closed
- Flashing green = valve opening
- Steady green = valve fully open
- Both green and red flashing = valve-related alarm

### **USER INTERFACE**


EKE 1C can be setup using one of the following user interfaces:

- 1. Danfoss KoolProg software
- 2. Danfoss MMIGRS external display.
- 3. Communication bus: Modbus RS485 RTU

### **KoolProg**



KoolProg is a software tool for quickly and easily configuring EKE controllers. It enables you to make online changes to parameter configuration, copy settings to multiple controllers, monitor the live status of input/outputs, and quickly analyze controller behavior and program patterns with a graphical trending tool.



- KoolProg Software is available for download free of charge at <a href="http://koolprog.danfoss.com">http://koolprog.danfoss.com</a>.
- KoolProg requires a Gateway (code 080G9711) to connect to the PC.
- Always use latest KoolProg version and create program based on the product and software version of EKE.


## Important note!

To guarantee a reliable USB connection to a host device (e.g. industrial PC), you must:

- Connect terminals R and H on MMIMYK CAN port using a termination wire.
- Place cable holder close to MMIMYK to keep USB connector firmly in place.
- Keep USB cable length < 1 m.
- Place MMIMYK and route USB cable far from noise sources (inverter, motors, contactors etc.)

# **Danfoss MMIGRS2 display**

### Connecting external MMIGRS2 display




MMIGRS2 display can be used to set up EKE 1C. The display can be used not only for setting up the necessary parameters, but also as an external display during operation to show important parameters, e.g. degree of opening of valve, superheat, etc.

### Important note:

- Max. distance between controller and display is 3 m over CAN RJ.
- CANbus requires termination in both ends of the cable by a 120 Ohm resistor to ensure reliable communication.
- On EKE 1C and MMI, the termination must be included by shorting CAN R and CAN H with a wire.
- No external power supply for MMIGRS2 is needed while using CAN RJ connector.

### MMIGRS2 (Back view)



# MMIGRS2 (Front view)



**Note:** Setup and service menu requires login with the default password 100 (daily use), 200 (service use) or 300 (commissioning use). Long press Enter key to access login menu.

# Setup wizard via MMIGRS2 display

- When all connections to the controller have been made, after the power is switched on, the Danfoss logo will appear for 5 seconds, then the Home screen will be displayed.
- To access the Wizard: press and hold enter to access the Login screen, the commissioning password is 300, scroll down the Setup and service menu and select "Setup wizard".

• The Wizard workflow is: a. Language selection; b. Application selection; c. Input configuration; and d.

# Output configuration.

When using the Setup Wizard, repeat the following sequence for all parameter settings:

- From Setup wizard, select relevant parameters.
- Press ENTER to highlight 1st option
- Scroll with UP / DOWN to your desired option
- If the selected default value is acceptable, press DOWN to get to the next settings. Otherwise, press ENTER to set your choice
- Scroll with DOWN to the next parameter (repeat sequence a. to e.)


### Note:

- If you do not have sufficient information to complete the Wizard, leave settings on their default values. To generate the requested info, you can use Danfoss Coolselector2 software to calculate operating conditions and valve OD for the same operating point.
- Setup Wizard only covers the most important parameters. If other features are to be enabled (e.g. Alarm settings, MOP/LOP, etc.), they must be congured separately once the Setup Wizard is done.

Setup Wizard is also available in KoolProg PC tool.


The workflow process is the same as that described above for MMIGRS2 display.

For details, please refer to EKE data sheet.



# Quick guide for parameter selection

Apart from wizard setup, users can also use the following section which describes quick parameter settings for general applications.



# EKE 1C - Commonly used parameter identification

**PNU** – equivalent to the Modbus register no. (Modbus address +1). Actual value are read/written as 16-bit integer values without decimals. This is the default value as read via Modbus.

Parameter	PNU	Defaul t	Description
R012 Main switch	3001	0	0 = regulation Off   1 = regulation On

R102 Operation mode	3002	0	0 = Superheat control   1 = Valve driver		
O002 DI1 configuration	3101	1	0 = Bus->Start/Stop   1 = Main Switch		
1033 Driver reference configur ation	3131	0	0 = Voltage to OD   1 = Modbus to OD   2 = Modbus to steps   3 = Current to OD		
1034 Ext ref. voltage low	3130	0	Range 0 – 10 V. To be used with <b>1033</b>		
1035 Ext ref. voltage high	3129	10	Range 0 – 10 V. To be used with <b>I033</b>		
1036 Ext ref. current low	3128	4	Range 0 – 20 mA. To be used with <b>I033</b>		
1037 Ext ref. current high	3127	20	Range 4 – 20 mA. To be used with <b>I033</b>		
			0 = no valve, 1 = UserDef		
			<b>2</b> = ETS 12C, <b>3</b> = ETS 24C, <b>4</b> = ETS 25C, <b>5</b> = ETS 50C, <b>6</b> = E TC 100C		
			<b>7</b> = ETS 6, <b>8</b> = ETS 12.5, <b>9</b> = ETS 25, <b>10</b> = ETS 50, <b>11</b> = ETS 100,		
			<b>12</b> = ETS 250, <b>13</b> = ETS 400		
			<b>14</b> = KVS 2C, <b>15</b> = KVS 3C, <b>16</b> = KVS 5C		
			<b>17</b> = KVS 15, <b>18</b> = KVS 42		
			<b>19</b> = CCMT 0, <b>20</b> = CCMT 1		
			<b>21</b> = CCMT 2, <b>22</b> = CCMT 4, <b>23</b> = CCMT 8, <b>24</b> = CCMT 16, <b>2 5</b> = CCMT 24,		
			<b>26</b> = CCMT 30, <b>27</b> = CCMT 42		
			<b>28</b> = CCM 10, <b>29</b> = CCM 20, <b>30</b> = CCM 30, <b>31</b> = CCM 40		
<b>I067</b> Valve configuration	3132	0	<b>32</b> = CTR 20		
valve comiguration	3132	0	<b>33</b> = CCMT 3L, <b>34</b> = CCMT 5L, <b>35</b> = CCMT 8L, <b>36</b> = CCMT 1 0L,		
			<b>37</b> = ETS 175L, <b>38</b> = ETS 175L OFHT, <b>39</b> = ETS 250L,		
			<b>40</b> = ETS 250L OFHT, <b>41</b> = ETS 400L, <b>42</b> = ETS 400L OFHT,		
			<b>43</b> = ETS 500L, <b>44</b> = ETS 500L OFHT, <b>45</b> = ETS 8M Bipolar		

			0 = Und ef	10 = R50 3	20 = R40 7C	30 = R417 A	40 = 448A
			1 = R12	11 = R11 4	21 = R40 7A	31 = R422 A	41 = 449A
			2 = R22	12 = R14 2b	22 = R40 7B	32 = R413 A	42 = 452A
			3 = R13 4A	13 = R Us er	23 = R41 0A	33 = R422 D	43 = R450A
			4 = R50 2	14 = R32	24 = R17 0	34 = 427A	44 = R452B
			5 = R71 7	15 = R22 7	25 = R29 0	35 = R438 A	45 = R454B
			6 = R13	16 = R40 1A	26 = R60 0	36 = R513 A	46 = R1233 zdE
O030 Refrigerant	3017	0	7 = R13 b1	17 = R50 7	27 = R60 0a	37 = R407 F	47 = R1234 zeZ
			8 = R23	18 = R40 2A	28 = R74 4	38 = R123 4ze	48 = R449B
			9 = R50 0	19 = R40 4A	29 = R12 70	39 = R123 4yf	49 = R407H
			50 = R4 69A				
I040 S2 sensor configuration	3105	0	T 153 10K		·		C10K   3 = MB
I041 S3 sensor configuration	3106	0	T 153 10K	•	·		C10K   3 = MB
<b>I042</b> S4 sensor configuration	3107	0	0 = Not defined   1 = EKS 221   2 = ACCPBT NTC10K   3 = M T 153 10K   4 = 112CP   5 = Bus Shared   6 = AKS			C10K   3 = MB	

		1	7
I043 Pe transmitter configuration	3108	0	0 = Not defined   1 = AKS 32R   2 = ACCPBP Ratio   3 = 112C P    4 = OEM Ratio   5 = NSK   6 = AKS 32 1 - 5V   7 = OEM Voltag e    8 = Bus shared   9 = AKS 32 1 - 6V   10 = AKS 32 0 - 10V   11 = AKS 33    12 = XSK   13 = ACCPBP Current   14 = OEM Current, 15=DS T P110
O020 Pe transmitter min. (in bar g)	3115	-1	Define pressure range in bar gauge
O021 Pe transmitter max. (in bar g)	3116	12	Define pressure range in bar gauge
I044 Pc transmitter setup	3117	0	0 = Not defined   1 = AKS 32R   2 = ACCPBP Ratio   3 = 112CP   4 = OEM Ratio   5 = NSK   6 = AKS 32 1 - 5V   7 = OEM Voltage   8 = Bus shared   9 = AKS 32 1 - 6V   10 = AKS 32 0 - 10V   11 = AKS 33   12 = XSK   13 = ACCPBP Current   14 = OEM Current
<b>O047</b> Pc transmitter min. (in bar g)	3124	-1	Define pressure range in bar gauge
O048 Pc transmitter max. (in bar g)	3125	34	Define pressure range in bar gauge

N021 SH reference mode	3027	2	0 = Fixed SH   1 = Loadap   2 = MSS   3 = Delta temp
N107 SH fixed setpoint ( K)	3028	7	Range 2 K – 40 K
<b>N009</b> SH max. ( K)	3029	9	Range 4 K – 40 K
<b>N010</b> SH min. ( K)	3030	4	Range 2 K – 9 K
N116 SH ref. delta temp. fact or (%)	3035	65	Range 20 – 100

For a detailed parameter list and explanation, please check the EKE data sheet.

# **Related Products**

MMIGRS2 Display	Power Supply	MMIMYK Gateway
Leaving Water  COMMON A  P  P  P  P  P  P  P  P  P  P  P  P  P		MAK
User interface module MMIGRS2 Displa y	AK-PS Input: 100 – 240 V AC, 45 – 65 Hz Output: 24 V DC: available with 18 VA, 36 VA and 60 VA	MMIMYK device is used as a g ateway to connect EKEs and th e PC tool i.e KoolProg software for parameter setting or data lo gging.
	ACCTRD  Input: 230 V AC, 50 – 60 Hz  Output: 24 V AC, available with 12 VA, 22 VA and 35 VA	

Pressure Transducer	Temperature Sensor
	10 1 8 5 0 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
	PT 1000
	AKS is a High precision temp. sensor AKS 11 (pref erred), AKS 12, AKS 21 ACCPBT PT1000
AKS Pressure Tranducer	
Available with ratiometric and 4 – 20 mA.	NTC sensors
	EKS 221 ( NTC-10 Kohm) MBT 153
	ACCPBT
	NTC Temp probe (IP 67 /68)

ACCCBI Cable	Stepper motor valves	M12 cable
ACCCBI cables for MMI display and gate way.	EKE is compatible with Danfoss st epper motor valves i.e Danfoss ET S 6, ETS, KVS, ETS Colibri®, KVS colibri®, CTR, CCMT	M12 Angle cable to connect Da nfoss stepper motor valve and EKE controller

Any information, including, but not limited to information on the selection of product, its application or use, product design, weight, dimensions, capacity or any other technical data in product manuals, catalogues descriptions, advertisements, etc. and whether made available in writing, orally, electronically, online or via download, shall be considered informative and is only binding if and to the extent, explicit reference is made in a quotation or order confirmation. Danfoss cannot accept any responsibility for possible errors in catalogues, brochures, videos and other material.

Danfoss reserves the right to alter its products without notice. This also applies to products ordered but not delivered provided that such alterations can be made without changes to form, fit or function of the product. All trademarks in this material are property of Danfoss A/S or Danfoss group companies. Danfoss and the

Danfoss logo are trademarks of Danfoss A/S. All rights reserved.

#### More info



© Danfoss | Climate Solutions | 2023.10

Info for UK customers only: Danfoss Ltd., 22 Wycombe End, HP9 1NB, GB



### **Documents / Resources**



<u>Danfoss 1C Electronic Superheat Controller</u> [pdf] Instruction Manual 1C Electronic Superheat Controller, Electronic Superheat Controller, Superheat Controller, Controller

#### References

• User Manual

Manuals+, Privacy Policy

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.