



Danfoss COM 10C Oil Level Regulator Installation Guide

[Home](#) » [Danfoss](#) » Danfoss COM 10C Oil Level Regulator Installation Guide 

Danfoss COM 10C Oil Level Regulator



Contents


- [1 Technical Specification](#)
- [2 Installation](#)
- [3 Electrical connection](#)
- [4 General safety and warning](#)
- [5 Documents / Resources](#)
- [6 Related Posts](#)

Technical Specification

Model	COM 10C	COM 20C
Compatible Refrigerant	HFC, CO ₂ , HC	HFC, CO ₂ , HC
Compatible Oils	Mineral, Synthetic, Ester oils	Mineral, Synthetic, Ester oils
Max Operating pressure	60 bar / 870 psi	130 bar / 1885 psi
Test Pressure	66 bar / 957 psi	143 bar / 2074 psi
Burst Pressure	180 bar / 2610 psi	390 bar / 5656 psi
Maximum Opening Differential Pressure	40 bar / 580 psi	80 bar / 1160 psi (100 bar at nominal voltage)
Supply Voltage	24V AC 50Hz +10/-15%, 0.4A 230V AC 50Hz +10/-15% 0,04A	24V AC 50Hz +10/-15%, 0.4A 230V AC 50Hz +10/-15% 0,04A
Media Temperature range	-40 to +80°C / -40 to +176°F	-40°C to +80°C / -40 to +176°F
Ambient/Storage Temperature range	-40 to +50°C / -40 to +122°F (static)	-40 to +50°C / -40 to +122°F (static)
Humidity	0-80% RH (none condensing)	0-80% RH (none condensing)
Alarm contact	Max 3A,230V AC dry contact	Max 3A,230V AC dry contact
Protection class	IP65	IP65
Sight glass	11SMnPb37 Ni plated Pb< 0,035%	11SMnPb37 Ni plated Pb< 0,035%
Oil connection	Brass CW 617N 7/16"-20 UNF male	Brass CW 617N 7/16"-20 UNF male
Filter	100 micron mesh 80	100 micron mesh 80
Vibration resistance (EN 60068-2-6)	max. 4g, 10... 250Hz	max. 4g, 10... 250Hz

Installation



BOM diagram/part identification




1. Screws (3 pcs.)
2. Sight glass
3. O-ring
4. Body
5. O-ring
6. Adapter
7. Flange ring
8. O-ring

For installation of the product the refrigerant circuit area must be depressurized. Please note that the test pressure is not exceeded. Check parts for completeness. Sealing surfaces must be clean. Align the product horizontally (tol. $\pm 1^\circ$). Remove transport lock before installation. The device is ready to install, do not disassemble prior to installation.

1. Remove the sight glass from compressor.
2. Place appropriate gasket or O-ring as per the adapter used.
3. Use appropriate tightening torque as specified by compressor manufacture and the mounting adaptor used.




3



COM AD -118-18/034-14/241

4



COM AD-118-18 Danfoss MLZ


Electrical connection

Ensure country specific regulations. The operating voltage range must not be exceeded.

In case of line length > 6m the signal must be evaluated for interference and EMC. Further anti-interference measures may be required.

Signal lines must not run parallel to power lines. No moisture may penetrate the device. Wire the product as per

the below diagram.



Service

The devices are maintenance-free when used under the conditions mentioned in this manual. In case of a defect, please replace the device.

Maintenance

Clean the filter in oil connection or replace the oil connection.

Disassembly

For the disassembly of the product the refrigerant circuit area must be depressurized. Switch off system Power. Remove product in reverse order of installation.


Disposal

Both the device as well as the transport packaging mainly consist of recyclable raw materials. Please dispose both according to the applicable legal regulations. Drain oil from the device and dispose safely.

General safety and warning

Safety and operational instructions

- Everybody in charge of the device's installation, first operation, maintenance and repair, must have read and understood the installation manual as well as the safety relevant information.
- The installation of the products may only be carried out by educated and trained professional experts.
- The products may not be modified without permission. Every modification voids our liability for any damage caused by such modification.
- Only put the installation in operation once the product has been securely fitted and it is gas-proof.
- Please make sure that the test pressure is not exceeded.
- If the permissible operating temperatures are exceeded, the product may stop functioning or become defective.
- It is recommended that the product should remain permanently switched on (even if the compressor is shut down).
- Make sure that at all times oil is upstream of the regulator (no discharge gas)
- The coil becomes hot during operation.



- Before restart of compressors after a long period of standstill the oil level has to be checked on the sight glass


of product.

- Do not remove plug from coil when device is powered on.
- Working on CO2 refrigeration Systems require a specific skill and training in handling CO2 as a refrigerant. The qualification and expert knowledge of the refrigerant personnel must conform to the respectively valid guidelines.
- Observe the high-pressure levels of CO2 refrigerants (critical temperature 31.06°C and 73,6 bar). At still stand the pressure in the system will rise and there is a risk of bursting. Installation of safety| pressure relief valves should be carried out acc. EN 378 and EN 13136. Take measures to prevent relief valve blockage due to dry ice during venting. Do not install pipe work to the outlet of the pressure relief valves.
- The product may be utilized exclusively for refrigeration and heat-pump applications. For this purpose, the limitations listed on the label as well as in the “Technical Data” must be observed. Any other use is considered improper. The product may only be utilized with the media listed on the manual. Application with other media is only allowed upon approval by Danfoss.
- Liability for injury or damage caused by the incorrect use of the device lies solely with the user.

Any information, including, but not limited to information on selection of product, its application or use, product design, weight, dimensions, capacity or any other technical data in product manuals, catalogues descriptions, advertisements, etc. and whether made available in writing, orally, electronically, online or via download, shall be considered informative, and is only binding if and to the extent, explicit reference is made in a quotation or order confirmation. Danfoss cannot accept any responsibility for possible errors in catalogues, brochures, videos and other material.

Danfoss reserves the right to alter its products without notice. This also applies to products ordered but not delivered provided that such alterations can be made without changes to form, fit or function of the product. All trademarks in this material are property of Danfoss A/S or Danfoss group companies. Danfoss and the Danfoss logo are trademarks of Danfoss A/S. All rights reserved.

Documents / Resources



[Danfoss COM 10C Oil Level Regulator](#) [pdf] Installation Guide
COM 10C, COM 20C, COM 10C Oil Level Regulator, Oil Level Regulator, Regulator