



**NXIP54FR4 VACON
NXP Air Cooled**



Danfoss NXIP54FR4 VACON NXP Air Cooled Installation Guide

[Home](#) » [Danfoss](#) » Danfoss NXIP54FR4 VACON NXP Air Cooled Installation Guide 

Contents

- [1 Danfoss NXIP54FR4 VACON NXP Air Cooled](#)
- [2 GENERAL](#)
- [3 VACON IP54 KIT CONTENTS](#)
- [4 INSTALLATION](#)
- [5 Frequently Asked Questions](#)
- [6 Documents / Resources](#)
 - [6.1 References](#)
- [7 Related Posts](#)



Danfoss NXIP54FR4 VACON NXP Air Cooled



GENERAL

Using these instructions, you can enhance the enclosure protection class of your IP21 class frequency converter to IP54. Such a higher protection level may be necessary when the frequency converter is used in such ambient conditions that might constitute a risk for the proper functioning of the converter (moist, dust). According to standard IEC 60529 (EN 60 529), the IP54 frequency converter enclosure provides protection against dust and water sprayed from all directions. Limited ingress of both is permitted.

VACON IP54 KIT CONTENTS

NOTE: An IP54 enclosure does not protect the frequency converter against strong jets of water or the effects of immersion.

The contents of the IP54 kits for different frames are shown in the following pictures.

FR4 (Type designation code: NXIP54FR4)




Figure 1. Contents of IP54 kit for FR4

Figure 1. Contents of IP54 kit for FR4

1. IP54 enclosure for FR4
2. IP54 cable cover with fan
3. Cable entry flange with rubber grommets
4. Cable extension for fan
5. Plastic sealing
6. Screws (4×10)
7. Warning sticker

FR5 (Type designation code: NXIP54FR5)




Figure 2. Contents of IP54 kit for FR5

1. IP54 enclosure for FR5
2. IP54 cable cover with fan
3. Cable entry flange with rubber grommets
4. Cable extension for fan
5. Rubber sealings

6. Screws (4×10)
7. Warning sticker

FR6 (Type designation code: NXIP54FR6)



Figure 3. Contents of IP54 kit for FR6


1. IP54 enclosure for FR5
2. IP54 lid with fan
3. Cable entry flange with rubber grommets
4. Cable extension for fan
5. Rubber sealings
6. Screws (4×10)
7. Warning sticker

INSTALLATION


These instructions guide you through the installation of the IP54 kit that you have purchased for your FR4, FR5 or FR6 size frequency converter enclosure class IP21.

NOTE: If you have purchased your converter before March 2004, follow the installation instructions under Error! Reference source not found.. Please note the white triangles in the lower left corners of the installation pictures. They designate the frame(s) the picture applies to. If no triangles exist, the step is applicable to all frames.


Installation instructions #1




1. Detach the fan.
2. Insert the plastic sealing (#4).
 1. Insert the rubber sealing




3. Carefully reinstall the fan ,ensuring that the connector clip fits accurately. **DO NOT SLAM, DO NOT FORCE!!**
4. Remove the plastic cover of the frequency converter and open the small lid on the power unit cover. Leave the opening uncovered.
 - Remove the plastic cover of the frequency converter and open the small lid on the power unit cover.




5. Seal the air inlets with the rubber sealings (#4). Leave the opening uncovered.
6. Fix the IP54 lid with fan (#2) on the power unit cover.
7. Open the control cable cover and remove the cable entry flange.





8. Remove the power cable cover and detach the grounding rack
9. Take the IP54 cable cover and connect the fan power cable to the connector marked with 'FAN'
10. Use the attached screws to fix the IP54 cable cover with fan and the grounding rack.



11. Open the cover of the FR6 power unit.
12. Connect the other end of the fan cable extension to the +24V terminal on the power board.
13. Push the other end of the extension cable through the cover, fix the cover and connect finally the fan power cable to its extension.



14. Fix the IP54 cable entry flange by placing it with the old grommets down and the new ones up. Fix the lower side with screws from the old flange.
15. Fit the IP54 cover in its place. Keypad end first, then the cable end.
16. Use the attached screws (#5) to fix the IP54 cover on the upper end of the converter.



17. Then fix the screws (4×10) on the lower end of the converter. Note the different fixing places for different frames.
 1. 17b. Tighten the four screws on the IP54 cover to fix it in its place.
18. Attach the warning sticker (#6/ #7) on the IP54 cover.

Information sticker

Each IP54 upgrade kit delivered by the factory includes a sticker (shown below). Please check IP54/Collar (1) and mark the installation date (2) on the sticker. Finally, attach the sticker on your drive.

Drive modified:			
<input type="checkbox"/>	Option board:	NXOPT.....	Date:.....
	in slot:	A B C D E	
<input checked="" type="checkbox"/>	IP54 upgrade/ Collar		Date:.....
<input type="checkbox"/>	EMC level modified:	H to T / T to H	Date:.....

24-hour support +358 (0)201 212 575

- Email: vacon@vacon.com
- www.danfoss.com

Vacon Ltd

Member of the Danfoss Group Runsorintie 7 65380 Vaasa Finland

Frequently Asked Questions


Q: What is the purpose of enhancing the enclosure protection class to IP54?

A: Enhancing to IP54 provides protection against dust and water sprayed from all directions, suitable for environments with moisture and dust that could affect the converter's operation.

Q: Can the IP54 enclosure protect against strong jets of water or immersion?

A: No, the IP54 enclosure does not protect against strong jets of water or immersion, so caution is advised in such conditions.

Documents / Resources

	<p>Danfoss NXIP54FR4 VACON NXP Air Cooled [pdf] Installation Guide NXIP54FR4, NXIP54FR5, NXIP54FR6, NXIP54FR4 VACON NXP Air Cooled, NXIP54FR4, VACON NXP Air Cooled, NXP Air Cooled, Air Cooled</p>
---	---

References

- [User Manual](#)

Manuals+, Privacy Policy

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.