



## e2S IS-mA1 Intrinsically Safe Round Sounder Instruction Manual

[Home](#) » [e2S](#) » e2S IS-mA1 Intrinsically Safe Round Sounder Instruction Manual 



INSTRUCTION MANUAL  
IS-mA1 Minialarm  
Intrinsically Safe Round Sounder



## Contents

- [1 IS-mA1 Intrinsically Safe Round Sounder](#)
- [2 Introduction](#)
- [3 Description](#)
- [4 Supply Voltage](#)
- [5 Intrinsic Safety Certification](#)
- [6 Installation](#)
- [7 Electrical System Design For Installation In Hazardous Areas Using Zener Barriers](#)
- [8 Cable Parameters](#)
- [9 Maintenance](#)
- [10 IECEx Approval](#)
- [11 EU Declaration of Conformity](#)
- [12 Documents / Resources](#)
  - [12.1 References](#)
- [13 Related Posts](#)

## IS-mA1 Intrinsically Safe Round Sounder

The IS-mA1 sounder is CE marked for compliance with the European Explosive Atmospheres Directive 2014/34/EU and the European EMC Directive 2014/30/EU

### Introduction

The IS-mA1 mini alarm is an ATEX, IECEx and UKEX certified intrinsically safe sounder which produces a loud warning signal in a hazardous area. Forty-nine first stage alarm sounds can be selected by internal switches and each one can be externally changed to a second or third stage alarm sound. The sounder may be used in all gas groups IIA IIB and IIC.

### Description

Fig 1 shows a simplified block diagram of an IS-mA1 mini-alarm sounder. The device operates immediately power is applied to the + and – terminals which are duplicated to allow a second sounder to be connected in parallel, or for an end of line monitoring resistor to be installed. The output tone is defined by the positions of the six internal switches and this tone can be changed to a second or third stage alarm tone by connecting terminals S2 or S3 to 0V. The tone generator is crystal controlled to ensure that when two sounders connected to the same power supply are started at the same time the output tones remain synchronized.

### Supply Voltage

The IS-mA1 mini alarm sounder has been designed to operate in a hazardous area from a 24V dc supply via 28V 93 mA resistive ATEX and IECEx certified Zenger Barriers or Galvanic Isolators. The sounders may be tested or used in safe areas without a Zener Barrier or Galvanic Isolator, but at supply voltages above 16V the internal current limit will function and therefore it is recommended that they are not operated continuously with a direct supply greater than 16V.




Fig 1 Simplified block diagram

## Intrinsic Safety Certification

### 4.1 ATEX certificate

The IS-mA1 mini alarm sounder complies with the following standards:-

EN IEC 60079-0:2018

EN 60079-11:2012


EN 60079-26:2014



II 1G Ex ia IIC T4 Ga (-40°C ≤ Ta ≤ +60°C)

The EC-Type Examination Certificate SIRA 05ATEX2084X has been issued by the Notified Body Sira. This confirms compliance with the European ATEX Directive 2014/34/EU for Group II, Category 1G equipment. The sounder carries the Community Mark and subject to local codes of practice, may be installed in any of the EEA member countries. This instruction sheet describes installations which conform to EN60079: Part 14: 2008 Electrical Installation in Hazardous Areas. When designing systems for installation outside the UK, the local Code of Practice should be consulted.

1. The certification marking is as follows:



- The equipment may be used in zones 0, 1 and 2 with flammable gases and vapours with apparatus groups IIA, IIB & IIC and with temperature classes T1, T2, T3 and T4.
- The equipment is only certified for use in ambient temperatures in the range -40°C to +60°C and should not be used outside this range.
- The certificate number has an 'X' suffix, which indicates that the certificate contains one of more special conditions for safe use. Those installing or inspecting the equipment should refer to this section of the

certificate.

5. The equipment has not been assessed as a safety related device (as referred to by Directive 2014/34/EU Annex II, clause 1.5).
6. Installation of this equipment shall be carried out by suitably-trained personnel in accordance with the applicable code of practice.
7. Repair of this equipment shall only be carried out by the manufacturer or in accordance with the applicable code of practice.
8. The certification of this equipment relies on the following materials used in its construction:

Enclosure: ABS Plastic

If the equipment is likely to come into contact with aggressive substances, then it is the responsibility of the user to take suitable precautions that prevent it from being adversely affected, thus ensuring that the type of protection is not compromised.

“Aggressive substances” – e.g. acidic liquids or gases that may attack metals, or solvents that may affect polymeric materials.

“Suitable precautions” – e.g. regular checks as part of routine inspections or establishing from the material's data sheet that it is resistant to specific chemicals.

SPECIAL CONDITIONS FOR SAFE USE (as stated in the EC Type Examination Certificate SIRA 05ATEX2084X)

#### **Conditions for IS-mAI Sounder**

The equipment has an ingress protection rating of IP65. However, if it has been supplied without cable entry devices, then the user shall ensure that the devices that are fitted will provide an ingress protection that is appropriate to the environment in which it is installed i.e. IP20 or better. If only one of the two cable entries are used, then the unused entry ‘knockout’ shall be left intact or fitted with a blanking device that ensures ingress protection appropriate to the environment in which it is installed i.e. IP20 or better.

The total capacitance connected to terminals + wrt – (i.e. the capacitance of the cable plus any other capacitance) shall not exceed 83nF.

The enclosure is non-conducting and may generate an ignition-capable level of electrostatic charges under certain extreme conditions. The user should ensure that the equipment is not installed in a location where it may be subjected to external conditions that might cause a build-up of electrostatic charges on non-conducting surfaces, additionally, cleaning of the equipment should be done only with a damp cloth.

The equipment shall only be supplied via Terminals + w.r.t.

Terminals – from a barrier having a maximum open circuit voltage So that is < 28V and a maximum short circuit current  $I_o$  that is < 93 mA, where  $I_o$  is restively limited. The barrier shall be ATEX certified by a notified body.

#### **4.2 Zones, Gas Groups and Temperature Classification**

The IS-mA1 mini alarm sounder has been certified Ex ia IIC T4. When connected to an approved system it may be installed in:

Zone 0 explosive gas air mixture continuously present.

Zone 1 explosive gas air mixture likely to occur in normal operation.

Zone 2 explosive gas air mixture not likely to occur, and if it does, it will only exist for a short time.

#### **Be used with gases in groups:**

Group A propane

Group B ethylene

Group C hydrogen

#### **Having a temperature classification of:**

T1	450°C
T2	300°C
T3	200°C
T4	135°C

#### **4.3 Terminals + and –**

Power is supplied to the sounder via the + and – terminals which have the following input safety parameters:

$U_i = 28V$   
 $I_i = 93mA$   
 $P_i = 660mW$   
 $C_i = 0$   $L_i = 0$

The IS-mA1 sounder may be powered from an ATEX certified Zener barrier or galvanic isolator which have output parameters equal to or less than 28V, 93mA and 660mW, where  $I_o$  is restively limited. The cable parameters stated on the selected Zener barrier or galvanic isolator certificate must be observed.

Up to three IS-mA1 sounders can be connected in parallel and powered from a common barrier or isolator. Connecting two sounders in parallel will reduce the output from each by about 3dB. Three sounders should only be powered from a common supply when the maximum supply voltage is available.

#### 4.4 Terminals S2 and S3

When terminals S2 or S3 are connected to 0V (- terminal) the sounder output tone changes to the second or third stage alarm respectively. The input safety parameters for these terminals are:

$U_i = 28V$   
 $I_i = 0mA$


Because the permitted input current is zero, these terminals may only be connected to a diode return barrier, an intrinsically safe relay or a galvanic isolator, all of which must have been certified by an EC Notified Body. Only diode return barriers with a voltage drop of less than 0.9V may be used. Alternatively, these terminals may be connected directly to a mechanically activated switch within the hazardous area.

**Tone Selection** – To select the required first stage tone set the tone switches 1 to 6 (see Fig 2) to the tone setting shown in the table below. The table also shows which 2nd and 3rd stage tones are available for use with the selected first stage tone if more than one tone output stage is required.

Tone Number	Tone Description	Switch Settings 1 2 3 4 5 6	Second Stage Alarm	Third Stage alarm
Tone 1	Continuous 340Hz	0 0 0 0 0 0	Tone 2	Tone 5
Tone 2	Alternating 800/1000Hz @ 0.25s intervals	1 0 0 0 0 0	Tone 17	Tone 5
Tone 3	Slow whoop 500/1200Hz @ 0.3Hz with 0.5s gap repeated	0 1 0 0 0 0	Tone 2	Tone 5
Tone 4	Sweeping 500/1000Hz @ 1Hz	1 1 0 0 0 0	Tone 6	Tone 5
Tone 5	Continuous 2400Hz	0 0 1 0 0 0	Tone 3	Tone 20
Tone 6	Sweeping 2400/2900Hz @ 7Hz	1 0 1 0 0 0	Tone 7	Tone 5
Tone 7	Sweeping 2400/2900Hz @ 1Hz	0 1 1 0 0 0	Tone 10	Tone 5
Tone 8	Siren 500/1200/500Hz @ 0.3Hz	1 1 1 0 0 0	Tone 2	Tone 5
Tone 9	Saw tooth 1200/500Hz @ 1Hz – D.I.N.	0 0 0 1 0 0	Tone 15	Tone 2
Tone 10	Alternating 2400/2900Hz @ 2Hz	1 0 0 1 0 0	Tone 7	Tone 5
Tone 11	Intermittent 1000Hz @ 1Hz	0 1 0 1 0 0	Tone 2	Tone 5

Tone 12	Alternating 800/1000Hz @ 0.875Hz	1 1 0 1 0 0	Tone 4	Tone 5
Tone 13	Intermittent 2400Hz @ 1Hz	0 0 1 1 0 0	Tone 15	Tone 5
Tone 14	Intermittent 800Hz 0.25s ON, 1s OFF	1 0 1 1 0 0	Tone 4	Tone 5
Tone 15	Continuous 800Hz	0 1 1 1 0 0	Tone 2	Tone 5
Tone 16	Intermittent 660Hz 150Ns ON, 150ms OFF	1 1 1 1 0 0	Tone 18	Tone 5
Tone 17	Alternating 544Hz (100ms) / 440Hz (400ms) – NFS 32-001	0 0 0 0 1 0	Tone 2	Tone 27
Tone 18	Intermittent 660Hz 1.8s ON, 1.8s OFF	1 0 0 0 1 0	Tone 2	Tone 5
Tone 19	Sweep 1400Hz to 1600Hz up 1s 1600Hz to 1400Hz down 0.5s	0 1 0 0 1 0	Tone 2	Tone 5
Tone 20	Continuous 660Hz	1 1 0 0 1 0	Tone 2	Tone 5
Tone 21	Alternating 554/440Hz @ 1Hz	0 0 1 0 1 0	Tone 2	Tone 5
Tone 22	Intermittent 544Hz @ 0.875Hz	1 0 1 0 1 0	Tone 2	Tone 5
Tone 23	Intermittent 800Hz @ 2Hz	0 1 1 0 1 0	Tone 6	Tone 5
Tone 24	Sweeping 800/1000Hz @ 50Hz	1 1 1 0 1 0	Tone 29	Tone 5
Tone 25	Sweeping 2400/2900Hz @ 50Hz	0 0 0 1 1 0	Tone 29	Tone 5
Tone 26	Simulated bell	1 0 0 1 1 0	Tone 2	Tone 15
Tone 27	Continuous 554Hz	0 1 0 1 1 0	Tone 26	Tone 5
Tone 28	Continuous 440Hz	1 1 0 1 1 0	Tone 2	Tone 5
Tone 29	Sweeping 800/1000Hz @ 7Hz	0 0 1 1 1 0	Tone 7	Tone 5
Tone 30	Continuous 300Hz	1 0 1 1 1 0	Tone 2	Tone 5
Tone 31	Sweeping 660/1200 @ 1Hz	0 1 1 1 1 0	Tone 26	Tone 5
Tone 32	Two Tone Chime	1 1 1 1 1 0	Tone 26	Tone 15

Tone 33	Intermittent 745Hz	0 0 0 0 0 1	Tone 2	Tone 5
Tone 34	Alternating 1000/2000Hz @ 0.5s – Singapore	1 0 0 0 0 1	Tone 38	Tone 45
Tone 35	420Hz @ 0.625s – Australian Alert	0 1 0 0 0 1	Tone 36	Tone 5
Tone 36	500-1200Hz 3.75s / 0.25s – Australian Evacuate	1 1 0 0 0 1	Tone 35	Tone 5
Tone 37	Continuous 1000Hz	0 0 1 0 0 1	Tone 9	Tone 45
Tone 38	Continuous 2000Hz	1 0 1 0 0 1	Tone 34	Tone 45
Tone 39	Intermittent 800Hz 0.25s ON 1s OFF	0 1 1 0 0 1	Tone 23	Tone 17
Tone 40	Alternating 544Hz (100ms) / 440Hz (400ms) – NFS 32-001	1 1 1 0 0 1	Tone 31	Tone 27
Tone 41	Motor Siren – Slow rise to 1200Hz	0 0 0 1 0 1	Tone 2	Tone 5
Tone 42	Motor Siren – Slow rise to 800Hz	1 0 0 1 0 1	Tone 2	Tone 5
Tone 43	Continuous 1200Hz	0 1 0 1 0 1	Tone 2	Tone 5
Tone 44	Motor Siren – Slow rise to 2400Hz	1 1 0 1 0 1	Tone 2	Tone 5
Tone 45	Intermittent 1000Hz 1s ON, 1s OFF	0 0 1 1 0 1	Tone 38	Tone 34
Tone 46	Saw tooth 1200/500Hz @ 1Hz – D.I.N. (PFEER P.T.A.P)	1 0 1 1 0 1	Tone 47	Tone 37
Tone 47	Intermittent 1000Hz 1s ON, 1s OFF – PFEER General Alarm	0 1 1 1 0 1	Tone 46	Tone 37
Tone 48	420Hz @ 0.625s – Australian Alert	1 1 1 1 0 1	Tone 49	Tone 5
Tone 49	500-1200Hz 3.75s / 0.25s – Australian Evacuate	0 0 0 0 1 1	Tone 26	Tone 37



**Fig 2 Location of field terminals and controls.**

#### **4.5 Other intrinsic safety certifications**

Please contact European Safety Systems Ltd. for details of non-European intrinsic safety approvals.

### **Installation**

IS-mA1 minialarm sounders should only be installed by trained competent personnel.

#### **5.1 Mounting**

The IS-mA1 minialarm sounder may be secured to any flat surface by inserting two mounting screws through the back of the round base (see figure 3). The enclosure provides IP65 protection and is suitable for installation in exterior locations provided that the area around the two mounting screws through the back of the base moulding has been sealed and that suitable cable glands with the required IP rating have been used.

#### **5.2 Installation procedure**

a. Unscrew the sounder unit security screw and remove the sounder section from the base by turning it anticlockwise.

Ensure that the 'O' ring seal remains in place.

b. Remove the required 20mm knockout section(s) depending on system wiring and mount the base to a flat surface by inserting two screws through the back of the base.

c. Fit the required number of 20mm cable glands or conduit entries into the base and connect the field wiring to the appropriate sounder terminals as shown in section 6 and fig 2 of this manual. The power supply terminals + and – are duplicated so that sounders may be connected in parallel, or an end of line monitoring resistor may be fitted.

d. Select the required output tone by positioning the six switches as shown in Table 1 and Fig 2.

e. Apply power to the sounder and adjust the internal volume control to provide the required sound level.

f. Check that the 'O' ring seal is correctly located on the sounder section (see Fig. 2) and insert the sounder section into the base. Push it fully home and turn it clockwise to align the mouldings before tightening the security screw.






Fig 3 Mounting Sounder Base.

## Electrical System Design For Installation In Hazardous Areas Using Zener Barriers

### 6.1 Single stage alarm

If the control switch is in the positive supply, or the power supply is being turned on and off, only a single channel Zener barrier is required as shown in Fig 4. This circuit may also be used if the sounder is being controlled by a mechanically activated switch on the hazardous area side of the barrier.




Fig 4 Single stage alarm using single channel barrier.

If the control switch must be in the negative supply, the circuit shown in Fig 5 may be used. Any diode return barrier certified Ex ia by a EC Notified Body may be used, providing its voltage drop is less than 0.9V.




Fig 5 Single stage alarm using two channel barrier.

## 6.2 Multi-stage alarm

Connecting terminal S2 to 0V activates the second stage alarm, and similarly terminal S3 for the third stage alarm. Fig 6 shows how the diode return barriers may be used. If only two stages of alarm are required the third stage barrier should be omitted, the 28V 93mA barrier and the single diode return channel may then be contained in one package.




Fig 6 Multi stage alarm using Zener barriers.

## Electrical System Design For Installation In Hazardous Areas Using Galvanic Isolators

Galvanic violators do not require a high integrity earth connection. For small systems where a high integrity earth is not already available, the use of galvanic violators often reduces the overall installation cost and simplifies design.

### 7.1 Single stage alarm

The IS-mA1 minialarm sounder may be powered by any galvanic isolator having output parameters within the limits specified in section 4.3, which has been certified Ex ia by an EC Notified Body. The sounder may be controlled by turning the galvanic isolator on and off, or by a mechanically activated switch on the hazardous area side of the isolator.




Fig 7 Single stage alarm using galvanic isolator.

### 7.2 Multi stage alarm

The IS-mA1 sounder second and third stages may be activated by using Galvanic ally Isolated Relays that have output parameters within the limits specified in section 4.4. which have been certified Ex ia by an EC Notified Body.




Fig 8 Multi stage alarm using galvanic isolated relays

### Cable Parameters

The maximum permitted cable parameters are as specified on the certificate of the Zener barrier or galvanic isolator that has been selected for the installation. Normally the limits are not restrictive, but care should be taken not to exceed a capacitive limit of 83nF for installations when very long cables are used.

### Volume Control

The output level of the IS-mA1 sounder can be set by adjusting the volume control potentiometer (see Fig 2).

### Maintenance

The sounder should be regularly inspected to ensure that it has not been damaged. Frequency of inspection depends upon environmental conditions, but initially we recommend that this should be done annually.

No attempt should be made to repair a faulty ISmA1 sounder. Suspect sounders must be returned to European Safety Systems Ltd. or to your local agent for repair.

### Guarantee

Sounders that fail within the guarantee period should be returned to European safety Systems Ltd. It is helpful if a brief description of the fault symptoms is provided.

### Customer Comments

European Safety Systems Ltd. is always pleased to receive comments from customers about our products and services. All communications are acknowledged and whenever possible, suggestions are implemented.

## IECEX Approval

The IS-mA1 Sounder has also been approved to the IECEx scheme.

The installation requirements for IS-mA1 sounders approved to the IECEx scheme are the same as the installation requirements for IS-mA1 sounders approved to the ATEX directive.

Certificate No.

IECEX SIR 06.0045X

### Marking:

Ex ia IIC T4 Ga (Ta = -40°C to +60°C)

### Standards:

IEC 60079-0:2017

IEC 60079-11:2011

IEC 60079-26:2014-10

CONDITIONS OF CERTIFICATION (as stated on the IECEx Certificate of Conformity IECEx SIR 06.0045X)

- The equipment has an ingress protection rating of IP65. However, if it has been supplied without a cable entry device, then the user shall ensure that the devices that are fitted will provide an ingress protection that is appropriate to the environment in which it is installed i.e. IP20 or better. If only one of the two cable entries are used, then the unused entry 'knockout' shall be left intact or fitted with a blanking device that ensures ingress protection appropriate to the environment in which it is installed i.e. IP20 or better.
- The total capacitance connected to terminals + w.r.t. terminals – (i.e. the capacitance of the cable plus any other capacitance) shall not exceed 83nF.
- The enclosure is non-conducting and may generate an ignition-capable level of electrostatic charges under certain extreme conditions. The user should ensure that the equipment is not installed in a location where it may be subjected to external conditions that might cause a build-up of electrostatic charges on non-conducting surfaces, additionally, cleaning of the equipment should be done only with a damp cloth.
- The equipment shall only be supplied via terminal + w.r.t. terminal – from a barrier having a maximum open circuit voltage  $U_o$  that is  $\leq 28V$  and a maximum short circuit current  $I_o$  that is  $\leq 93mA$ , where  $I_o$  is restively limited.

The IS-mA1 sounders are marked with the certification requirements for the ATEX and IECEx and approvals.

### IS-mA1 Sounder



II 1G Ex ia IIC T4 Ga (-40°C  $\leq$  Ta  $\leq$  +60°C)

$U_i = 28V$   $I_i = 93mA$   $P_i = 660mW$   $C_i = 0$   $L_i = 0$  Terminal + w.r.t. Terminal  $U_i = 28V$   $I_i = 0mA$

Terminals S2&S3 w.r.t. Terminal – Year / Serial No. 09 / 1MA000001



2813

### VdS

EN54-3

Type B

0786-CPD-20338

SIRA 05ATEX2084X

IECEX SIR 06.0045X

**WARNING:** TO AVOID A POSSIBLE ELECTROSTATIC CHARGE ONLY CLEAN WITH A DAMP CLOTH

### e2S

European safety systems ltd.

London W3 7QH UK

[www.e2s.com](http://www.e2s.com)

### UKEX Approval

The IS-mA1 Sounder has also been approved to the UKEX scheme.

The installation requirements for IS-mA1 sounders approved to the UKEX scheme are the same as the installation requirements for IS-mA1 sounders approved to the ATEX directive.

Certificate No. CSAE 21UKEX2553X

Marking:


Ex ia IIC T4 Ga (Ta = -40°C to +60°C)

Standards: EN IEC 60079-0:2018

EN 60079-11:2012

EN 60079-26:2014

The IS-mA1 sounders are marked with the certification requirements for the UKEX approval.



[www.e2s.com](http://www.e2s.com)

### FM Approval

The IS-mA1 Sounder has also been FM Listed.

Marking: IS Class I, Zone 0, AEx ia IIC T4 IS Class I, Division 1, Groups A, B, C, D See the Control Drawings D 5035 Sheets 1 and 2 for installation details and entity parameters.

### IS-mA1 Sounder

#### FM

#### APPROVED

IS Class I, Division 1, Groups A, B, C, D

IS Class I, Zone 0, AEx ia IIC T4 (-40°C ≤ Ta ≤ +60°C)

Control Drawing D 5035

Year / Serial No. 09 / 1MA000001

**WARNINGS:** Substitution of components may impair safety To prevent ignition of flammable or combustible atmospheres, disconnect power before servicing TO AVOID A POSSIBLE ELECTROSTATIC CHARGE ONLY CLEAN WITH A DAMP CLOTH

**e2S** european safety systems ltd.

London W3 7QH UK

[www.e2s.com](http://www.e2s.com)

### CPD Directive 89/106/EEC

The IS-mA1 Sounder is compliant with the requirements of the Construction Products Directive 89/106/EEC.


EN54-3

Type B

IP65

Voltage Range 18 – 28V DC via a safety barrier (see sections 6 and 7).





Manufacturer:	European Safety Systems Ltd. Impress House, Mansell Road, Acton London, W3 7QH United Kingdom
Authorised Representative:	E2S Warnsignaltechnik UG Charlottenstrasse 45-51 72764 Reutlingen Germany
Equipment Type:	IS-mA1, IS-mA2, IS-mA3, IS-mB1, IS-mC1, IS-mA1M

Notified Body for EU type Examination (Module B):	Sira Certification Service Notified Body No.: 2813 CSA Group Netherlands B.V, Utrechtseweg 310, 6812 AR, Arnhem, Netherlands
EU-type Examination Certificate (Module B):	SIRA 05ATEX2084X
Notified Body for Quality Assurance Notification / Conformity to EU-type based on quality assurance of the production process (Module D):	Sira Certification Service Notified Body No.: 2813 CSA Group Netherlands B.V, Utrechtseweg 310, 6812 AR, Arnhem, Netherlands
Quality Assurance Notification (Module D):	SIRA 05 ATEX M342
Provisions fulfilled by the equipment:	II 1 G Ex ia IIC T4 Ga (-40 °C ≤ Ta ≤ +60 °C) or I M1 Ex ia I Ma (-40 °C ≤ Ta ≤ +60 °C)
Standards applied:	EN IEC 60079-0:2018 EN 60079-11:2012 IEC 60079-26:2014

Regulation EU No. 305/2011: Construction Products Regulation (CPR) – IS-mA1 (tones 2, 3, 9, 15, 16, 17) only

Notified Product Certification Body for Certificate of Constancy of Performance or EC Type Examination Certificate and continuous surveillance, assessment and evaluation of factory production control:	VdS Schadensverhütung GmbH Notified Body No.: 0786 Amsterdamer Str 172-174, 50735 Köln, Germany
Certificate of Constancy of Performance or EC Type Examination Certificate:	0786-CPD-20338
Standards applied:	EN 54-3:2001 + A1:2002 + A2:2006

Directive 2014/30/EU: Electromagnetic Compatibility Directive (EMC)

**Standards applied:**

- EN 61000-6-1:2007
- EN 61000-6-2:2005
- EN 61000-6-3:2007 / A1:2011 / AC: 2012
- EN 61000-6-4:2007 / A1: 2011

Directive 2011/65/EU: Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)

The product and all the components contained within it are in accordance with the restriction of the use of hazardous substances in electrical and electronic equipment, including amendment by Directive 2015/863/EU.



Regulation (EC) 1907/2006: Registration, Evaluation, Authorisation and Restriction of Chemicals (REACH)  
The product and all the components contained within it are free from substances of very high concern.

#### **Other Standards and Regulations**

EN 60529:1992+A2: 2013 – Degrees of protection provided by enclosures (IP code) – enclosure rated IP65

#### **EU Declaration of Conformity**

On behalf of European Safety Systems Ltd., I declare that, on the date the equipment accompanied by this declaration is placed on the market, the equipment conforms with all technical and regulatory requirements of the above listed directives, regulations and standards.

This Declaration is issued under the sole responsibility of the manufacturer.



#### **UKCA Declaration of Conformity**

##### **Manufacturer:**

European Safety Systems Ltd.  
Impress House, Mansell Road, Acton  
London, W3 7QH  
United Kingdom

##### **Equipment Type:**

IS-mA1, IS-mA2, IS-mA3, IS-mB1, IS-mC1, IS-mA1M

Directive UKSI 2016:1107 (as amended by UKSI 2019:696) – Schedule 3A, Part 1 : Product or Protective System  
Intended for use in Potentially Explosive Atmospheres (UKCA)

Notified Body for UK type Examination (Module B):	Sira Certification Service Notified Body No.: 0518 Rake Lane, Ecclesiastes, Chester CH4 9JN, UK
UK-type Examination Certificate (Module B):	CSAE 21UKEX2553X
Notified Body for Quality Assurance Notification / Conformity to EU-type based on quality assurance of the production process (Module D):	Sira Certification Service Notified Body No.: 0518 Rake Lane, Ecclesiastes, Chester CH4 9JN, UK
Quality Assurance Notification (Module D):	CSAE 22UKQAN0046
Provisions fulfilled by the equipment:	II 1 G Ex ia IIC T4 Ga (-40 °C ≤ Ta ≤ +60 °C) or I M1 Ex ia I Ma (-40 °C ≤ Ta ≤ +60 °C)
Standards applied:	EN IEC 60079-0:2018 EN 60079-11:2012 IEC 60079-26:2014

Regulation EU No. 305/2011: Construction Products Regulation (CPR) – IS-mA1 (tones 2, 3, 9, 15, 16, 17) only

Notified Product Certification Body for Certificate of Constancy of Performance or EC Type Examination Certificate and continuous surveillance, assessment and evaluation of factory production control:	VdS Schadenfreude GmbH Notified Body No.: 0786 Amsterdam-er Str 172-174, 50735 Köln, Germany
Certificate of Constancy of Performance or EC Type Examination Certificate:	0786-CPD-20338
Standards applied:	EN 54-3:2001 + A1:2002 + A2:2006

Directive 2014/30/EU: Electromagnetic Compatibility Directive (EMC)

**Standards applied:**

EN 61000-6-1:2007

EN 61000-6-2:2005

EN 61000-6-3:2007 / A1:2011 / AC: 2012

EN 61000-6-4:2007 / A1: 2011

Directive 2011/65/EU: Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)

The product and all the components contained within it are in accordance with the restriction of the use of hazardous substances in electrical and electronic equipment, including amendment by Directive 2015/863/EU.

Regulation (EC) 1907/2006: Registration, Evaluation, Authorisation and Restriction of Chemicals (REACH)

The product and all the components contained within it are free from substances of very high concern.

Other Standards and Regulations

EN 60529:1992+A2: 2013 – Degrees of protection provided by enclosures (IP code) – enclosure rated IP65

**UKCA Declaration of Conformity**

On behalf of European Safety Systems Ltd., I declare that, on the date the equipment accompanied by this declaration is placed on the market, the equipment conforms with all technical and regulatory requirements of the above listed directives, regulations and standards.

This Declaration is issued under the sole responsibility of the manufacturer.

Martin Streetz

Quality Assurance Manager

Document No.: DC-088\_Issue\_A

Date and Place of Issue: London, 04/02/2022

E2S Telephone: +44 (0)20 8743 8880

Fax: +44 (0)20 8740 4200

Email: [sales@e2s.com](mailto:sales@e2s.com)

[www.e2s.com](http://www.e2s.com)

DC-088\_Issue\_A (IS-Mini) – Page 2 of 2 – QAF\_252\_Issue\_5

**Documents / Resources**

	<p><a href="#">e2S IS-mA1 Intrinsically Safe Round Sounder</a> [pdf] Instruction Manual</p> <p>IS-mA1 Intrinsically Safe Round Sounder, IS-mA1, Intrinsically Safe Round Sounder, Safe Round Sounder, Round Sounder, Sounder</p>
--	--

**References**

- [E2S Warning Signals - Signalling devices for hazardous areas, fire and industrial environments, marine, onshore and offshore applications and wide area sirens and alarms.](#)