



Electrodepot 9SS1 Start-Stop Output Module Instructions

[Home](#) » [Electrodepot](#) » Electrodepot 9SS1 Start-Stop Output Module Instructions 



9SS1 Start-Stop Output Module Instruction Manual


Contents

- [1 Typical wiring diagram](#)
- [2 Documents / Resources](#)
 - [2.1 References](#)
- [3 Related Posts](#)

Typical wiring diagram

Application

Start Stop or High Low Level Set Mode to: One Burst Transmission ON ON



Installation an setup manuals at:

<https://electrodepot.com/manuals/9SS1> Start/Stop Output Module

Two input from the receiver relay


One output to energize the external contactor

Transmitter send a momentary pulse via Channel

One (1) to START; the Receiver Control Module


Output turns ON

It will stay ON Until the transmitter sends the STOP signal via Channel Two (2) to turn the Receiver Output OFF



Radio control equipment is not to be used in life safety.
Installations shall be performed by a certified professional

Documents / Resources



[Electrodepot 9SS1 Start-Stop Output Module \[pdf\] Instructions](#)

9SS1 Start-Stop Output Module, 9SS1, Start-Stop Output Module, Stop Output Module, Output Module, Module

References

-  [154 Manuals Migro Wireless Controls](#)