

EMERSON IS-WEBRT3 Liebert Card



EMERSON IS-WEBRT3 Liebert Card Instruction Manual

[Home](#) » [Emerson](#) » EMERSON IS-WEBRT3 Liebert Card Instruction Manual 

Contents

- [1 EMERSON IS-WEBRT3 Liebert Card](#)
- [2 Product Information](#)
- [3 Product Usage Instructions](#)
- [4 INSTALL](#)
- [5 SET LIEBERT IS-WEBRT 3 CARD PASSWORD](#)
- [6 User Manual](#)
- [7 Documents / Resources](#)
 - [7.1 References](#)



EMERSON IS-WEBRT3 Liebert Card



Product Information

Specifications

- **Product Name:** Liebert IS-WEBRT3 Card
- **Web Support:** Yes
- **Liebert MultiLink™ Support:** Yes
- **SNMP Support:** Yes
- **Liebert Nform Support:** Yes
- **Technical Support/Service:** Available

Product Usage Instructions

Installation

1. Connect the Liebert IS-WEBRT3 Card to the corresponding port on your Liebert equipment using the provided cable.

Set Liebert IS-WEBRT3 Card Password

To set a password for the Liebert IS-WEBRT3 Card:

1. Access the Web management interface of the card by entering its IP address in a web browser.
2. Locate the password settings section and enter a desired password.

3. Save the password and remember to keep it in a safe place.

Control Functions

The Liebert IS-WEBRT3 Card provides various control functions:

- **Status Information:** All users on your network can view status information of the connected Liebert equipment.
- **Control and Configuration:** Access to control and configuration capabilities is protected by a username and password combination.
- **Password Change:** You can change the password from the Web management interface or using the DeskPro-Net Utility.

Liebert MultiLink™ Support

To download the Liebert MultiLink software:

1. Visit multilink.liebert.com.
2. Download the software from the website.

SNMP Support

The Liebert IS-WEBRT3 Card enables SNMP management of Liebert PSI equipment. To integrate the card into your SNMP implementation:

1. Compile the UPS MIB (Management Information Base) on your network management station (NMS).
2. The UPS MIB is included in this package on CD-ROM and supports both Windows and Unix file formats.

Liebert Nform Support

Liebert Nform can centrally manage alarm notifications and provide an easy interface to access critical system information. To download the Liebert Nform software:

1. Visit nform.liebert.com.
2. Download the software from the website.

Technical Support/Service

If you require technical support or service:

- **Web Site:** www.liebert.com
- **Monitoring:** 800-222-5877 (US), 614-841-6755 (Outside US)
- **Email:** monitoring@emersonnetworkpower.com

Locations

- **United States:** 1050 Dearborn Drive, P.O. Box 29186, Columbus, OH 43229
- **Europe:** Via Leonardo Da Vinci 8, Zona Industriale Tognana, 35028 Piove Di Sacco (PD), Italy
- **Asia:** 7/F, Dah Sing Financial Centre, 108 Gloucester Road, Wanchai, Hong Kong

FAQ

Q: Where can I find the full user manual for the Liebert IS-WEBRT3 Card?

A: The full user manual (SL-52665) is available online at www.liebert.com. We recommend consulting the user manual for detailed instructions.

INSTALL




- Locate the Liebert IntelliSlot bay on your Liebert equipment. You might need to remove a plastic cover.
- Insert the Liebert IS-WEBRT3 Card into the bay.
- Secure the card with the supplied screws.
- Connect the card to your network with a CAT5 Ethernet cable.

SET LIEBERT IS-WEBRT 3 CARD PASSWORD

- Insert the Liebert PSI-RT3 Software CD and install Liebert DeskPro-Net Utility on your computer.
- Start Liebert DeskPro-Net Utility by clicking on Start>Programs>NetAgent>DeskPro-Net Utility. The software will automatically find and list available Liebert IS-WEBRT3 cards.
- Double-click on a card in the list to launch it.
- Enter an Account (login name) and Password—Record the login and password and save them in a safe place.

Control functions



Device	Hardware	Firmware	IP Address
3925934085	HSMP01	1.5.SMP.m...	192.168.0.168
3926030532	HCP504	2.39.CP50...	192.168.0.167
3926120052	HCV73	2.55.CV73	192.168.0.169
3926181499	HCV73	2.55.CV73	192.168.0.175
3927000016	HCV91	3.3.CV91.8...	192.168.0.31
3927000114	HCV91	3.3.CV91.8...	192.168.0.30
3927030053	HCV91	3.3.CV91.I...	192.168.0.172
3927030067	HCV92	3.3.CV92.8...	192.168.0.166

Liebert IS-WEBRT3 cards found

CONFIGURE LIEBERT IS-WEBRT3 CARD

- Highlight the card in the list and click Configure to change the card's IP address, subnet mask, and gateway settings (see your network administrator for the settings). The Liebert IS-WEBRT3 card can be used with DHCP or BOOTP, where the system assigns an address, but this makes troubleshooting difficult.
- Liebert MultiLink™ will communicate with the Liebert IS-WEBRT3 card. The software can be configured to shut down a computer system in response to utility power failure and the UPS' battery backup time.

User Manual

This Quick Start Guide is designed to give you the information you need to install and configure the Liebert ISWEBRT3 Card. A full user manual, SL-52665, is available online at www.liebert.com. Liebert recommends that new users consult the user manual.

Web Support

The IS-WEBRT3 Card delivers Web management and control to Liebert equipment. All users on your network will be able to view status information. Control and configuration capabilities are protected by a username and password combination. You can change the password from the Web or from DeskPro-Net Utility.

Liebert MultiLink™ Support

Liebert MultiLink software, can be downloaded at multilink.liebert.com.

SNMP Support

The Liebert IS-WEBRT3 Card enables SNMP management of Liebert PSI equipment. To integrate the card into your SNMP implementation, you will need to compile the UPS MIB on your network management station (NMS). The UPS MIB is included in this package on CD-ROM and supports both Windows and Unix file formats.

Liebert Nform Support

Utilizing the SNMP and Web technologies built into each of the Intellislot Web cards, Liebert Nform will centrally manage alarm notifications to provide you with an easy interface to access critical system information.

A downloadable edition is available online at nform.liebert.com.

Technical Support/Service

Web Site

www.liebert.com

Monitoring

800-222-5877

monitoring@emersonnetworkpower.com

Outside the US: 614-841-6755

Locations

United States

1050 Dearborn Drive

P.O. Box 29186

Columbus, OH 43229

Locations

- **Europe**

Via Leonardo Da Vinci 8

Zona Industriale Tognana

35028 Piove Di Sacco (PD) Italy

+39 049 9719 111

Fax: +39 049 5841 257


- **Asia**

7/F, Dah Sing Financial Centre


108 Gloucester Road, Wanchai

- **Hong Kong**
852 25722201
Fax: 852 28029250

Documents / Resources

	<p>EMERSON IS-WEBRT3 Liebert Card [pdf] Instruction Manual IS-WEBRT3 Liebert Card, IS-WEBRT3, Liebert Card, Card</p>
---	--

References

-  [Monitoring Software | Vertiv Critical Infrastructure Solutions](#)
-  [Liebert® Nform | Centralized Monitoring Software](#)
-  [Liebert Thermal and Power Systems | Vertiv Brands](#)
-  [Manual-Hub.com - Free PDF manuals!](#)
- [User Manual](#)

[Manuals+.](#) [Privacy Policy](#)

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.