



ems kontrol OT-301 Oxygen O2 Transmitter User Manual

[Home](#) » [ems kontrol](#) » ems kontrol OT-301 Oxygen O2 Transmitter User Manual 

Contents

- [1 ems kontrol OT-301 Oxygen O2 Transmitter](#)
- [2 Specifications](#)
- [3 GENERAL FEATURES](#)
- [4 AREAS OF USE](#)
- [5 Installation](#)
- [6 CALIBRATION](#)
- [7 DECLARATION OF CONFORMITY](#)
- [8 FAQs](#)
- [9 Documents / Resources](#)
 - [9.1 References](#)



ems kontrol OT-301 Oxygen O2 Transmitter



Specifications

Technical Data	
Product Name:	Oxygen O2 Transmitter
Supply Voltage:	12-24 V DC
Output:	0-10 V / 4-20 mA / Modbus
Measurement Range:	0-25 % Vol
Precision:	± 0,1 % Vol
Accuracy:	± 1 % Vol
Operating Temperature:	(-10°C) – (+55°C)
Storage Temperature:	(-20°C) – (+60°C)
Protection Class:	IP 67 (Excluding Sensor)

Product Usage Instructions

Product Code	Output Signal
OT-301	0-10 V
OT-341	4-20 mA
OT-361	Modbus RTU

WHAT IS IT?

Oxygen transmitter measures the oxygen value precisely and outputs as analog.

HOW DOES IT WORK?

It can operate with a supply between 12 V DC and 24 V DC. Measurement values are taken from the analog output terminals and transferred to the desired location..

GENERAL FEATURES


- Accurate and Precise Measuring
- Analog Output,
- Durable and Handy Design
- 2 Years Sensor
- Operating Life
- Easy Replaceable Sensor
- Easy Assembling
- IP 67 Plastic Case (Excluding Sensor)

AREAS OF USE

- HVAC Applications
- Poultry Automation and Poultry
- Farms
- Cold Storage
- Incubation Rooms
- Food
- Storage
- Air Conditioning Cabinets
- Clean Rooms and Laboratories.


RULES TO BE CONSIDERED FOR SAFETY

1. Always read the user manual before using the device and its apparatus.
2. Damages caused by opening, breaking or misuse of the plastic parts of the device and its apparatus are considered out of warranty.
3. Keep the device and its apparatus away from external influences such as liquid, high dust, high temperature, etc. and protect them.
4. Do not expose the device cables to any jamming and pressure.
5. Disconnect the electrical power when your device is not used for a long time.
6. Our devices and apparatus should be used by paying attention to the points in the user manual. In case of damages and malfunctions arising from external use (liquid contact, falling to the ground, etc.) ask for help from the service.
7. Failures due to electrical connection errors and electrical voltage or current errors are not covered by the warranty.



Installation

1. Unpack the product and open the top cover.
2. Make cable connections accordingly.



3. If the product will be mounted on the wall, you can use the screws and dowels in the package.
4. It starts measuring 30 seconds after the product is energized. It is recommended that the product remains in the environment for at least 5 minutes to get healthy measurement values.
5. It is recommended to use shielded cable as communication cable as it will prevent communication signals from being affected by external influences.
6. Since the communication cable will create resistance, check the measurement values again after cable installation.

Modbus RTU Communication Structure



RS485 Baud rate value in Modbus communication is 9600 by default. Stop bit: 1, Parity: NONE. Default Slave ID is 85. Oxygen values are kept in the holding register at address 2 (40003).

Register Map and Default Values Table:

Register Address	Default Value	Read/Write	Min. Value	Max. Value
40001	85	R/W	1	247
40002	3	R/W	0	–
40003	–	R	–	–

To change Slave ID or Baud rate via Modbus communication, write the desired values to the corresponding registers as instructed in the manual.

Press and hold the “Calibration” button to reset the changes made to the Slave Id or Baud rate to the default values. Wait until the Status (green) LED turns off (approx. 30 seconds). After the LED turns off, the button is released. Thus, Slave ID and Baud rate are returned to their default values.

LED Meanings		
Power (Red)	On	Normal Operating
	Off	No Energy (Error)
Status (Green)	 On	Measurement Preparation
	 On	Normal Measurement
	Off	Error - Fault

Before Calibration

1. The product is sold as calibrated. Please do not calibrate unless necessary.
2. Perform calibration only when it is certain that the product is measuring incorrectly.
3. Calibration is only for carbon dioxide.
4. If the device measures values outside the range of 350 ppm – 450 ppm in clean and open air, calibration can be performed.

CALIBRATION

1. A clean and open area away from any carbon dioxide source should be selected for carbon dioxide calibration.
2. The amount of carbon dioxide in the clan and the open area varies between 350 ppm – 450 ppm. When calibration is done, the product takes the value at the time of calibration as 400 ppm.
3. When the up and down buttons on the product are pressed for 3 seconds together, the 15 minute countdown starts, after the countdown is over, the calibration process is completed.
4. If the calibration process was started by mistake, press and hold the up and down buttons on the device together for 3 seconds. In this way, you can cancel the calibration process that you have started by mistake.

DECLARATION OF CONFORMITY

Headquarters and place of production, Halkapinar Mah. 1376 Sok. Boran Plaza No:1/L Konak / IZMIR – TURKIYE, EMS KONTROL ELEKTRONIK VE MAKINE SAN. TIC. A.Ş. declares that the product marked with CE, whose name and specifications are given below, covers the specified directives and provisions.

- **Brand:** EMS KONTROL
- **Product Name:** OT-301
- **Product Type:** Humidity & Carbon Dioxide Control Device
- **Compatible Directives:** Elektromagnetic Compatibility Directive 2014/30/EU (EMC EN 61000-6-3: 2007 + A1: 2011, EN 61000-6-1: 2007)
- **Low Voltage Directive** 2014/35/EU (LVD EN 60730-2-9:2010, EN 60730-1:2011)
- **Additional information:** This product can be used in combination with other devices and compliance with the directives covers only the product. EMS KONTROL is not responsible for the compliance of the entire system with the directives.

This declaration is not valid if the product is modified without our approval.

**EMS KONTROL ELEKTRONİK
VE MAKİNE SAN. TİC. A.Ş.**
Halkapınar Mahallesi 1378 Sk.Boran Plaza
No:11/ KÖNÜK /İZ MİR
EGE V D. 334 104 4628
Mersis No 033410446280001

WARRANTY TERMS

1. The warranty period of the devices and apparatus starts from the invoice date and is guaranteed for 2 years against manufacturing defects.
2. Devices and apparatus are delivered to the customer in working condition in our company. On-site commissioning is subject to service fee.
3. The repair of the devices and apparatus under warranty s carried out in our company as a result of sending them with the transportation company contracted by our company. In on-site services, transportation and accommodation expenses of the service personnel belong to the customer.
4. The cost of the working time spent on the road is added to the service fee and the collection is made in advance.
5. Maintenance of devices and apparatus is done in our company. Transportation and transportation fees of the devices and apparatus to and from our company for maintenance belong to the customer.
6. In case of malfunction of the devices and apparatus whose warranty period continues, whether the malfunction is caused by the fault of the customer or the manufacturer, is tested in our company, and a report is issued by our company.
7. In case of detection of manufacturer-induced faults of the devices and apparatus whose warranty period continues, the customer may request a replacement or may request that the repair costs of the devices and apparatus be fully covered by the manufacturer, provided that it does not exceed the product price.
8. If the faults of the devices and apparatus whose warranty period continues are determined to be caused by the customer, all costs belong to the customer.
9. If the customer does not indicate that he/she is aware of the defects in the devices and apparatus from the date the warranty period starts or in cases where he/she is expected to be aware, he/she cannot benefit from Article 6.
10. Failures arising from the use of devices and apparatus contrary to the points in the user manual are not covered by the warranty.
11. Devices and apparatus are not covered by the warranty if they are beaten, broken or scratched by the customer.

12. Damages caused by the use of devices and apparatus of other brands and models without the approval of the manufacturer are not covered by the warranty.
13. Errors caused by rusting, oxidation, and liquid contact due to working in acidic/humid environments are not covered by the warranty.
14. Damages that may occur during transportation of devices and apparatus are not covered by the warranty. If the customer wishes, he/she can have transportation insurance.
15. Damages caused by mains voltage / faulty electrical installation are not covered by the warranty.
16. Devices and apparatus are not covered by the warranty in case of malfunctions caused by force majeure such as fire, flood, earthquake, etc.
17. All parts of the devices and apparatus, including all parts, are covered by our company's warranty.
18. If the devices and apparatus malfunction within the warranty period, the time spent in repair shall be added to the warranty period.
19. The repair period of the goods shall not exceed 20 working days. This period starts from the date of notification of the malfunction of the goods to the service station, in the absence of a service station, to the seller, dealer, dealer, agent, representative, importer or manufacturer – manufacturer of the goods. The consumer can notify the malfunction by telephone, fax, e-mail, registered letter with return receipt or similar means. However, in case of dispute, the burden of proof belongs to the consumer. If the malfunction of the goods is not resolved within 20 business days, the manufacturer, manufacturer or importer; until the repair of the goods is completed, another good with similar characteristics must be allocated to the use of the consumer.
20. Despite the consumer's right to repair the goods; -Provided that it is within the warranty period from the date of delivery to the consumer, it fails at least four times within a year or six times within the warranty period determined by the manufacturer-manufacturer and/or importer, as well as the fact that these failures make the inability to benefit from the goods continuous,
 - Exceeding the maximum time required for repair,
 - If it is determined that it is not possible to repair the malfunction with the report to be issued by the service station of the company's service station, if the service station is not available, respectively by one of its dealer, dealer, agency, representative, importer or manufacturer- manufacturer, it may request a refund or a price reduction at the rate of defect.
21. Customer may file complaints and objections to consumer courts or consumer arbitration committees.
22. The warranty certificate must be kept by the customer during the warranty period. In case of loss of the document, a second document will not be issued. In case of loss, repair and replacement of devices and apparatus will be made for a fee.



This device is a Waste Electrical and Electronic Equipment according to the directives applied in Europe 2002/96/EC.

(WEEE) Before scrapping or throwing away this device, you must prevent its potential negative consequences for the environment and human health. Otherwise it would be inappropriate waste. This symbol on the product is intended to warn that the product should not be treated as household waste and should be delivered to electrical and electronic waste collection points.

Disposal of the product must be done by local environmental regulations. You can obtain detailed information from authorized units on how to destroy, reuse and recycle the product.

- **Manufacturer's**
- **Title:** EMS KONTROL ELEKTRONİK VE MAKİNE SAN. VE TİC. A.Ş.
- **Address:** Halkapınar Mah. 1376 Sokak Boran Plaza No:1/L Konak / İzmir-TÜRKİYE
- **Telephone:** (232) 431 2121
- **E-Mail:** info@emskontrol.com
- **Company Stamp:**

**EMS KONTROL ELEKTRONİK
VE MAKİNE SAN. TİC. A.Ş.**
Halkapınar Mahallesi 1376 Sk.Boran Plaza
No:1/L Konak / İZ MİR
EGE V D. 334 104 4628
Mersis No 033410446280001

✂

<p>Vendor Company Title: Address: Telephone:..... Faks:..... E-Mail:..... Invoice Date and Number:..... Delivery Date and Place:..... Signature of Authorised Person:..... Company Stamp:.....</p> <p style="text-align: center;">STAMP</p> <p>Product's Type: Oxygen Transmitter Brand: EMS KONTROL Model: OT-3XX</p>

FAQs

Q: What is the recommended supply voltage for the Oxygen O2 Transmitter?

The recommended supply voltage is between 12 V DC and 24 V DC.


Q: What is the default Baud rate value for Modbus communication?

The default Baud rate value for Modbus communication is 9600.

Q: How should I reset the changes made to the Slave ID or Baud rate?

Press and hold the Calibration button to reset the changes made to the Slave ID or Baud rate to the default values. Wait until the Status (green) LED turns off (approximately 30 seconds) and then release the button.

Documents / Resources



[ems kontrol OT-301 Oxygen O2 Transmitter](#) [pdf] User Manual
OT-301, OT-341, OT-361, OT-301 Oxygen O2 Transmitter, OT-301, Oxygen O2 Transmitter, Transmitter

References

- [User Manual](#)

[Manuals+](#), [Privacy Policy](#)

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.