

emtest BS 200N100 Electronic Switch Voltage Transient Testing



emtest BS 200N100 Electronic Switch Voltage Transient Testing Instruction Manual

[Home](#) » [emtest](#) » emtest BS 200N100 Electronic Switch Voltage Transient Testing Instruction Manual 

Contents

- [1 emtest BS 200N100 Electronic Switch Voltage Transient Testing](#)
- [2 FAQ](#)
- [3 Operating functions](#)
- [4 Equipment description](#)
- [5 Technical Data](#)
- [6 Calibration / Measuring procedure](#)
- [7 Maintenance](#)
- [8 Application](#)
- [9 Delivery Groups](#)
- [10 Appendix](#)
- [11 Documents / Resources](#)
 - [11.1 References](#)



emtest BS 200N100 Electronic Switch Voltage Transient Testing



Specifications:

- Product Name: BS 200N100
- Manufacturer: AMETEK CTS GmbH
- Model Numbers: BS 200N100, BS 200N100.1
- Function: Electronic switch for Voltage Transient testing
- Load Impedance: CABS 200N for BS200N100
- Accessories: RS-Box Shunt resistor, R-Box LV124

Product Usage Instructions:

1. Standards Covered by BS 200N100:

The BS 200N100 covers the following standards for conducted emission transients:

- ISO 7637-2 Ed3 (2011-03) – Road vehicles; Electrical disturbances by conduction and coupling; Part 2: Electrical transients conduction along supply lines only
- LV 124 – In accordance with ISO 7637 Part 2

2. Operating Functions:

Operating Elements on the Top Side:

Ensure that the device is connected to a power source before proceeding with any testing.

Operating Elements Front- and Rearside:

Refer to the user manual for specific instructions on how to operate the front and rear elements of the device for accurate testing.

3. Application:

Test Setup ISO 7637-2 Ed.3 (2011):

Follow the guidelines provided in ISO 7637-2 Ed.3 (2011) for setting up the test environment to evaluate automotive electrical and electronic components.

LV 124 Test E-10 Short Interruption Text Case 3:

Refer to the user manual for detailed instructions on conducting the LV 124 Test E-10 with short interruption text case 3 using the BS 200N100.

4. Delivery Groups:

Basic Equipment:

Ensure that all basic equipment components are properly connected and configured before initiating any tests.

Options:

If you have additional options or accessories, refer to the user manual for instructions on how to incorporate them into your testing setup.

FAQ

Q: How do I ensure repeatable switching of inductive loads with the BS 200N100?

A: The BS 200N100 includes an electronic switch designed for repeatable switching of inductive loads, as specified in ISO 7637-2:2011. Ensure that the device is properly calibrated and follow the recommended procedures in the user manual for consistent results.

The BS 200N100 is used to evaluate automotive electrical and electronic components for conducted emissions of transients along battery fed or switched supply lines of a Device Under Test (DUT). A device under test which is considered a potential source of conducted disturbances should be tested according to ISO 7637 part 2. The BS 200N100 and BS 200N100.1 include an electronic switch for repeatable switching of inductive loads as specified in ISO 7637-2:2011 yet supporting former standard editions.

- ISO 7637-1:1990
- ISO 7637-2:1990
- ISO 7637-2:2004
- ISO 7637-2:2011

Standards covered by BS 200N100

With the BS 200N100, the user covers the following standards for conducted emission transients:


- ISO 7637-2 Ed3 (2011-03) Road vehicles; Electrical disturbances by conduction and coupling ;
 - Part 2: Electrical transients conduction along supply lines only
- several standards
 - In accordance with ISO 7637 Part 2
- LV 124
 - Elektrische und elektronische Komponenten in Kraftfahrzeugen bis 3,5t
 - Allgemeine Anforderungen, Prüfbedingungen und Prüfungen

Maximum applicable dc voltage supply

The maximum applicable DUT dc voltage supply for the BS 200N100 is 60V DC Higher dc voltages will damage the equipment.

Operating functions

Operating elements on the top side



1. Switch Trigger mode: Manual or Ext. / Auto
2. Switch operating mode (normally open/closed)
3. LED Switch closed
4. Button MANUAL Trigger
5. Switch TEST ON / OFF
6. Potentiometer Pulse duration 10ms ...>500ms
7. Potentiometer Pulse repetition 1s...>5s

1. Trigger Mode

Trigger release selection of the BS 200N100 switch: MAN / EXT: The trigger is released by manual operation with the button MANUAL, or via an external trigger signal at the BNC plug EXT. AUTO : After switch TEST ON button, the BS 200N100 switch starts to work.

2. Switch Mode

Setting of the switch mode: – NO : (Normally Open) The switch is normally open and close at each event. – NC : (Normally Closed) The switch is normally closed and opens at each event.

3. LED Switch closed

The LED is lighted during the switch is closed.

4. Manual Trigger

Select the “Manual trigger” mode of the switch. (open and closing time depends the time setting) – OFF: Initial state – ON: One switch event is released.

5. TEST

On / Off switch for start the electronic switch: – OFF: Switch out of service (switch status depends on setting NC or NO). – ON: Switch in operation (open and closing time depends the time setting).

6. Pulse Duration

Potentiometer for adjust the switch duration. Range: 10ms ... > 500ms \pm 5%

7. Pulse Repetition

Potentiometer for adjusting the repetition time. Range: 1s ... > 10s \pm 5%

Operating elements Front- and Rearside



1. Power IN +
2. Input DUT supply – IN
3. Monitor DUT output 1:200, 5%
4. Trigger OUT (15V neg. slope)
5. Trigger IN (Pull down)
6. BS200N100 Power supply 24V DC
7. Output to DUT +
8. Output to DUT –

9. Reference earth connection

1. Power IN + supply

The battery supply + IN for the DUT is connected to this input. The switch is located between POWER +IN and DUT + plug. The nominal dc supply parameters are 60V / 100A .

2. Power IN – supply

The battery supply – IN for the DUT is connected to this input. Internal is a direct connection to DUT- plug.

3. Monitor DUT

Monitor output for voltage measuring (divider 200:1, 5%). The monitor measures the voltage at the DUT side. The BNC output plug is isolated. For transient emission measuring an external voltage probe with >400MHz bandwidth must be used.

4. CRO Trigger OUT

Trigger output for an oscilloscope trigger. Trigger with a negative slope (+15V to 0V).

5. Trigger IN

The Trigger IN (Umax. +15V) has two different modes

1. External trigger input for start a single switch event using the duration, setting with the potentiometer. The trigger shall be a zero going signal (BNC to GND).
2. Direct switch control ON/OFF (LV124 application) The trigger controls direct the switch. This happens normally with the PFS 200 generator trigger out signal. For set the BS 200N100 in this mode, the user must press during the power on time the “Manual Trigger” button. A short LED blinking confirms the correct setting.

6. Power supply device 24V DC

Input plug for 24V dc supply 1A.

7. Output to DUT +

The DUT is connected at the banana output sockets OUT +.

8. Output to DUT –

The DUT is connected at the banana output sockets OUT -.


9. Reference earth connection

The bottom plane is the reference GND of the BS 200N100 and must be connected to the ground reference plane.

Equipment description

The Switch BS 200N100 is designed with the following main components:

- Electronic switch
- Differential Voltage divider 200:1



Electronic switch




Figure 3.2. : Operating modes Switch BS 200N100

The electronic Switch has 2 operating modes: NC : Normally Closed NO : Normally Open

- Figure 3.2 shows the both operating modes with the variable parameters “Repetition” and “Duration”
 - The electronic switch disconnects the DUT from battery supply voltage for a specified time in a well specified and reproducible manner.
- Figure 3.2. : Operating modes Switch BS 200N100
 - The electronic switch is activated by pushing the button TEST. The red LED indicates the closed status.

In AUTO mode the electronic switch is triggered internally with the preselected repetition rate. In MANUAL mode a single switching event is triggered either by pushing the MANUAL button or by remote trigger. The electronic switch can switch currents up to 100A and is able to withstand voltages up to 1000V. The electronic switch is protected against overload and can withstand short-circuit conditions. Specific protection requirements of the EUT must be separately assured by the user.

- **Inrush currents**
 - Inrush currents up to 500A are permitted.
- **Overvoltage**

- The switch is protected against over voltages higher than 1000V by internal varistors.

- **Divider 1:200**

- The built in differential divider is designed to monitor the supply voltage. The measuring signal is available on the MONITOR BNC plug. The 10MHz bandwidth is not designed for measuring the transient emission. The standard recommends an external voltage probe for this measurement. The divider is an ohmic-capacitive differential divider with a 50 terminating resistor to the BNC plug.


- **Air cooling**

- The BS200N100 has internal air ventilation for cooling the battery supply switch. The ventilation grid and ventilator (blower) must be kept away from other devices in order to allow sufficient air flow through the battery supply switch.

Technical Data

Technical data BS 200N100 and BS 200N100.1


Test voltage	
Operating voltage	Max. 60 V
Operating current	Max. 100 A continuous
Peak current protection	500 A
Inrush current	400 A for 200 ms
Voltage drop	Less than 0.2 V @ 25 A Less than 1.2 V @ 100 A
Peak voltage	Typ. 1300 V
Overvoltage protection	By varistor
Overload protection	short – circuit over temperature protected switch off after approx. 2 min with 120 A; switch on after approx.. 45 s cooling time.
Inverse polarity protection	Protected with an additional acoustic signal in case of inverse polarity
Electronic switch	
Switching time	300 ns \pm 20% (240 ns – 360 ns) into test load 50mH/0.6 W
On/Off duration	Min. 10 ms to 500 ms continuously selectable by potentiometer \pm 5%
On/Off repetition	Min. 1 s to 10 s continuously selectable by potentiometer \pm 5%
Operation	Switch closed indicated by LED
Output noise	< 400 mV peak, (typical 300 mV)
Trigger	
Manual	Manual trigger of a single event

Auto	Automatic trigger with min. ~ 0.1 Hz to max. 1 Hz repetition, continuously selectable by potentiometer
Extern	External trigger ~ 0 V, BNC input (Umax. +15 V)
External LV124 Mode	Active when Manual Trigger button is pressed during "Power ON"
Trigger delay typical	Switch off: approx. 10.5 μ s Switch on: approx. 94 ms
Measurement	
Voltage monitor	BNC output; differential divider 1:200, $\pm 5\%$; Bandwidth 10 MHz
CRO trigger	BNC output, ~ 0 V
General data	
Output connector	50mm above GND plane
Connector DUT	6mm high current connector 100 A, 4 mm safety lab connectors 32 A
Dimensions	<p>90 mm x 125 mm x 120 mm (L x W x H);</p> 
Weight	1.30 kg
Supply voltage	24V DC via mains supply adapter


Power Supply adapter BS200N100	
Model	GE24I24-P1J
Input Voltage	90 → 264V ac
Output Voltage	24V dc
Output Current	1A
Power Rating	24W
Package Plug	Top
Type	Switch Mode
Dimensions	81x43x40.5mm
Efficiency	85%
MTBF	100 khrs
Load Regulation	±3%
Ripple and Noise	240 mV p-p
Line Regulation	±1%
Operating Temperature	-10 → +50°C
Weight	134g
Plug Type	CH/AUS, EURO, UK, USA
ErP Compliance	ErP level V
Number of Outputs	1

Technical data CA BS 200N


Test voltage		
Battery supply voltage	28Vdc max.	
Load current	50A max.	
Operating time	13.5V supply	approx.1 hour
	28.0V supply	approx. 10 minutes
Overheat indication	LED	
Protection	Switch Off by over temperature sensor	
Cooling	Forced air temperature controlled	
Impedance		
Load	0.6 W in series with 50mH	selectable with bridge (R/L)
Parallel load resistor	10W, 20W, 40W, 120W	selectable with bridge
General data		
Dimensions	19"/ 3HU154 x 448 x 505mm	
Weight	18.35 kg	
Mains supply	100V to 230V ac	50/60Hz
Fuse	1A slow blow	
Cable	2 x 0.45m, red and black 6mm2, each 0.125kg	



Technical data Shunt resistor RS-Box

RS-Box				
Resistances	10W, 20W, 40W, 120W			
Accuracy	<5%			
Impedance	10W	20W	40W	120W
Max. EUT voltage	30V	30V	50V	60V
Max. EUT current	3A	1.5A	1.25A	0.5A
Max. power	90W	45W	62.5W	30W
Cooling	passive			
Max Temperature	30V continuous	approx. 50deg max. 50V continuous approx. 90deg max.		
General data				
Dimensions	300 x 105 x 90mm (L x W x H) 			
Weight	1.70kg			

R-Box LV124 Resistor box

Resistance	0.1Ω	10kΩ	100kΩ
Max. Spannung	60V	60V	60V
Load at Vmax.	continuous	continuous	
Max. load	5W 10 min		
	10W 5 min		
General Data			
Dimension	150 x 80 x 80mm (L x W x H) 		
Weight	0.45 kg		

Calibration / Measuring procedure

Test load CABS 200N

- The test impedance CABS 200N, a test load with 0.6 Ω in series with 50 Ω H inductor, is designed for verification of the BS 200N100 acc. ISO 7637-2 standard.
- Test load => R (total) = 0,6 Ω in series with L (total) = 50 Ω H (1 kHz)

Both R and L also include the variations of the cable and the structure. The parallel capacity which cannot be avoided is approx. 50pF




Figure 5.2.: Verification setup

Test voltage

According to the standard, the switch-Off time should be determined under varying test voltages, such as

- V_a : $U_1 = 13.5V$ and $U_2 = 27V$

Consequently, constant currents of 22.5A or 45A must be considered. The resulting energy consumption at the test load is:

DC Supply	Power 0.6W
13.5 V	304 W
27.0 V	1215 W

Switch-Off fall time

The switch-off fall time is specified as follows (90% to 10%):

- ISO 7637 (old version < 1992) $t_f = 200 \dots 400ns$
- ISO 7637-2: 2011 and DIN 40839 part 1 $t_f = 300ns + 20\%$ specified at 13.5V only

The resulting transients of the BS 200N100 are measured with a 1:200 voltage probe under loaded conditions according to the standard. The voltage probe is directly connected to the + and – output of the generator.

Measuring results

Voltage drop in dependence of the test load

DUT current	Nominal voltage drop	voltage drop (typical value)
1 A	≤ 2.0	0.01 V
5 A	≤ 2.0	0.04 V
10 A	≤ 2.0	0.07 V
25 A	≤ 2.0	0.17 V
50 A	not specified	0.35 V
100 A	≤ 1.0 EM Test specs.	0.96 V


Specification values (measured between Power IN+ und DUT+)

Measuring results with verification set-up as per Standard

All measuring values indicated as well as the curve illustrated have been recorded with a serial model.

Reference values measured with BS 200N100

- Input Voltage: 13.5 V
- Output Voltage: 13.30 V
- Upeak: – 1030 V
- tf (90% – 10%): 327.4 ns



Verification

Verification as per ISO 7637-2 Ed3 (2011-03) is defined at 13.5V only. Verification must be performed with calibration load CABS: 0.6 in series with 50 H; Rshunt not used

Verification with CABS	Va output voltage	tf 90% – 10% fall time
With standard load	+13.5V ±10%	300ns ±20%

Function	Setting
Switch Mode	NO / NC
Trigger Mode	Man.Ext / Auto
Manual	OFF / ON
Test	OFF / ON
Pulse Repetition	1s
Pulse Duration	10ms

Example for the switch off impulse




Figure 5.4.: Test load at 13.5V

Maintenance

General

The internal semiconductor switch does not need any maintenance.

Calibration and Verification

Factory calibration

Every EM TEST generator is entirely checked and calibrated as per international standard regulations before delivery. A calibration certificate is issued and delivered along with a list of the equipment used for the calibration proving the traceability of the measuring equipment. All auxiliary equipment and accessories are checked to our internal manufacturer guidelines.

The calibration certificate and the certificate of compliance (if available) show the date of calibration.

The EM Test product is calibrated in the factory and marked with a calibration mark. The used measuring instruments are traceable to the Swiss Federal Office of Metrology.

The calibration interval is to the responsibility of the user's quality system. Neither the certificate of calibration nor the corresponding label mark any due date for re-calibration.

Example: Calibration mark


Guideline to determine the calibration period of EM Test instrumentation

Our International Service Departments and our QA Manager are frequently asked about the calibration interval of EM TEST equipment.

EM TEST doesn't know each customer's Quality Assurance Policy nor do we know how often the equipment is used and what kind of tests are performed during the life cycle of a test equipment. Only the customer knows all the details and therefore the customer needs to specify the calibration interval for his test equipment.

In reply to all these questions we like to approach this issue as follows: EM TEST make use of a solid state semiconductor switch technique to generate high voltage transients. A precious advantage of this technique is the absolute lack of periodical maintenance effort. In consequence, thereof a useful calibration period has to be defined based on two criteria:

- The first one is the customer's Quality Assurance Policy. Any existent internal regulation has to be applied at highest priority. In the absence of such internal regulation the utilization rate of the test equipment has to be taken into consideration.
- Based on the experience and observation collected over the years EM TEST recommends a calibration interval of 1 year for frequently used equipment. A 2-years calibration interval is considered sufficient for rarely used test generators in order to assure proper performance and compliance to the standard specifications.



Example: Calibration mark

Calibration of Accessories made by passive components only:

Passive components do not change their technical specification during storage. Consequently, the measured values and the plots stay valid throughout the storage time. The date of shipment shall be considered as the date of calibration.

Periodically In-house verification

Please refer to the corresponding standard before carrying out a calibration or verification. The standard describes the procedure, the tolerances and the necessary auxiliary means. Suitable calibration adapters are needed. To compare the verification results, EM Test suggests to refer to the waveshape and values of the original calibration certificate.

Application

Important

- The artificial network AN shall be connected directly to the ground reference plane.
- All wires between AN and the DUT shall be isolated from the ground plane by 50mm.
- The DUT will be placed on the ground plane as in real installation.
- directly grounded to the ground plane or
- 50mm isolated from the ground plane
- The position of the instruments shall be as specified in the standard.

Switch as per ISO 7637-2:2011

For the measurement of the emission, the ISO 7637-2: 2011 standard defines two different switches and switch positions. These are pending from the rise time of the voltage impulse. The switch position for slow impulses in the ms range is before the electrical switch see Figure 7.1. For fast impulses, in and ns range, the switch is on the DUT side Figure 7.2. During the examination, only one switch may be operated. For the emission measurement ISO 7637-2: 2011 defines the test setup below. EM Test proposes the test setup illustrated in figure 7.1, 7.2 and 7.3.




Figure 7.1.: Setup for pulses in the ms range




Figure 7.2.: Setup for pulses in the μ s / ns range

Setup for **DUT** with internal Switch

ISO 7637-2:2011 offers a new test setup as shown in figure 7.3 for measuring the transient emission using DUT with internal switch. This setup is for measuring the transient emission pulses in ns to us range. Cause the existing original switch inside the DUT, it is not necessary to use the BS200N100 in the setup. The shunt resistor R_s is to use as per clause 5.2 of the ISO 7637-2 standard.




Figure 7.3: Setup for DUT with internal switch for μs / ns pulses

Electronic Switch for pulses below 400V

Inside the BS 200N100, the electronic switch is built in. A clear determination of a disturbance is possible only if an electronic switch with reproducible characteristics is used. For the measurement of the pulses under 400V an electronic switch is recommended (ISO7637-2:2011). The BS200N100 can be used up to 1000V pulses. In order to determine the amplitude and wave shape of a transient, first use the test set-up shown in Figure 7.1 for determine the maximum amplitude of the slower impulses (ms range). In the next procedure use test setup as shown in Figure 7.2 for measure the maximum amplitude of the fast transients.

Switch for voltage impulses higher than 400V special in $\Omega\text{ s}$ / ns range

The switch affects in particular the characteristics of the fast transient ones substantially. Besides gladly high amplitudes arise with fast pulses, which can be limited by the protection device of the electrical switch. Therefore, the standard recommends using the original switch how it is used in the vehicle as a switching device for pulses in $\Omega\text{ s}$ / ns range. If such a device is not available, an automotive relay with the following characteristics shall be used:

- contact rating, $I = 30\text{ A}$, continuous, resistive load;
- high-purity silver contact material;
- no suppression across relay contact;
- single/double position contact electrically insulated from the coil circuit;
- coil with transient suppression.

The switching relay shall be replaced if significant contact degradation occurs.

Resistor R_s

A shunt resistor of 40Ω shall simulate the dc impedance of other connected consumers in the cable tree. According to ISO/DIN 7637 when measuring transient overvoltage, a shunt resistor of 40Ω is required, whereas when measuring transient overcurrent, a shunt resistor of 2Ω is required. For this purpose, an external resistor of $2.5\Omega / 400\text{ W}$ (at 30 V DC) respective 40Ω must be connected in the test circuit. (Figures 7.1., 7.3 and 7.3.)

LV 124 Test E-10 short interruption Text case 3

The LV124 is a cooperated standard of all German car manufacturers. The application note AN 213 describes in detail the tests with E-10 and E-13. The following chapter describes the test using the BS200N100

EM Test proposal for Test case 3 with 0.1Ω resistor

This proposal is not as exact as it is in the LV 124 standard, because the 0.1Ω resistor is only during the interruption time in the circuit. This disadvantage allows the using of smaller dc sources. It is not necessary to drive a constant 110A current into the 0.1Ω resistor.




Figure 7.4: EM Test proposal for test setup for test case 3

Test setup and cabling

DUT is connected wired with the PFS200 and BS200N100 as shown in figure 7.4.

Cabling

- + pole (PFS200N) to DUT +
- DUT+ to Power IN+ (BS200N100)
- DUT+ (BS200N100) to Input (R-Box LV124, Box set to 0.1Ω)
- GND (R-Box LV124) to – pole (PFS200)
- DUT- (BS200N100) to – pole (PFS200)
- DUT- to Power IN- (BS200N100)
- BNC cable: PFS200 trigger to Trigger IN (BS200N100).

Settings on BS200N100:

- Switch Mode: NO Normally Open
- Trigger Mode: MAN / Ext.
- Duration: Synchronous with trigger signal PFS200 (Power ON BS200N100 as per note below)
- Test: ON
- Power ON BS200N100: The BS200N100 must work synchronous with the trigger IN signal. For set the BS200N100 into the LV 124 mode, the user must press the “Manual Trigger” button during connect the power to the BS 200N100. A short LED blinking with an acoustic beep confirms the correct LV 124 mode. The potentiometer time setting is disabled in this mode.

Function BS200N100

The Trigger IN controls the ON / OFF position of the switch. The trigger signal is generated from the PFS200 power fail generator



Figure 7.5: R-Box LV124

Delivery Groups

Basic equipment

- Switch BS 200N100
- Mains cable
- Manual on USB memory stick
- Calibration certificate
- Mains adapter 24V dc
- Plug Type CH/AUS, EURO, UK, USA



Figure 8.1.: BS 200N100



Figure 8.2.: Supply adapter

- 4 connection clamps for assembling
- 2 connection bridge 6mm BS200N100 to AN 200N100 with junction 4mm to a load resistor R_s



Figure 8.3 connectors

Identical accessory parts are delivered only once if several devices are ordered. The delivered packing list is in each case valid for the delivery

Options

- CA BS calibration load 50uH 0.6Ω Delivery: Mains cable 2x connection cable (45cm) 2x Short circuit bridges
- **AN 2050N Artificial Network for Automotive**
 - LISN Impedance: As per ISO 7637-2 Impedance: 5ΩH – 50Ω
 - Current: 50A continuous, 100A short-time
- **AN 200N100 Artificial Network**

- LISN Impedance: As per ISO 7637-2, ISO 11452-2 CISPR16-1-2, CISPR 25
- Impedance: 5Ω – 50Ω
- Current: 100A continuous



Figure 8.4. CA BS



Figure 8.5.: AN 2050N

• Shunt resistor R_s

Shuntresistor for simulate the resistance of other vehicle devices which are connected in parallel to the DUT.
The standard ISO 7637-2 defines the shuntresistor R_s . RS-Box 10Ω , 20Ω , 40Ω , 120Ω max. 60V (30V)



Figure 8.6.: AN 200N100



Figure 8.7. RS-Box

• R-Box LV124

- Resistor box for LV124 E 10 Resistors: 0.1Ω , $10k\Omega$ und $100k\Omega$

- Voltage: 60V continuous for 10k Ω and 100k Ω
- Max load 0.1 Ω : 5W 10 min, 10W 5 min



Figure 8.8.: R-Box LV124

Appendix

Declaration of CE-Conformity

- Manufacturer:
 - AMETEK CTS (Switzerland) GmbH Address: Sternenhofstr. 15 CH 4153 Reinach Switzerland declares, that under its sole responsibility, the product's listed below, including all their options, are conformity with the applicable CE directives listed below using the relevant section of the following EC standards and other normative documents.
- Product's name: Switch
- Model Number(s) BS 200N100 BS 200N100.1 CA BS RS-Box R-Box LV124

Low Voltage Directive 2014/35/EU

Standard to which conformity is declared

- EN 61010-1: 2011
 - Safety requirements for electrical equipment for measurement, control, and laboratory use.

EMC Directive 2014/30/EU

Standard(s) to which conformity is declared

- EN 61326-1: 2013
- Electrical equipment for measurement, control and laboratory use Class A
- EN 61000-3-2: 2014
- Limits for harmonic current emissions
- EN 61000-3-3: 2013
- Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems

European representative
AMETEK CTS Germany GmbH
Lünenerstr. 211
D 59174 Kamen
Tel: +49 (0) 2307 / 26070-0
Fax: +49 (0)2307 / 17050



By
Place
Date

A. Gerstner
General manager
Kamen, Germany
1. July 2017

Manufacturer
AMETEK CTS GmbH
Sternenhofstr. 15
CH 4153 Reinach
Tel: +41 61-7179191
Fax: +41 61-7179199



A. Burger
Business Manager Conducted EMC
Reinach BL, Switzerland
1. July 2017

BS 200N100 – Overview






Figure 9.1.: Overview BS 200N100

CA BS – Overview



Documents / Resources



Manual for Operation
BS 200N100
BS 200N100.1
Electronic Switch Voltage Transient Testing, Switch Voltage Transient Testing, Voltage Transient Testing, Transient Testing, Testing

[emtest BS 200N100 Electronic Switch Voltage Transient Testing \[pdf\]](#) Instruction Manual
BS 200N100 Electronic Switch Voltage Transient Testing, BS 200N100, Electronic Switch Voltage Transient Testing, Switch Voltage Transient Testing, Voltage Transient Testing, Transient Testing, Testing

References

- [EM TEST](#)
- [EM TEST](#)
- [User Manual](#)

[Manuals+](#), [Privacy Policy](#)

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.