



EtherWAN EW200-TA Cellular Gateway User Manual

[Home](#) » [EtherWAN](#) » EtherWAN EW200-TA Cellular Gateway User Manual 

EtherWAN EW200-TA Cellular Gateway User Manual



EtherWAN Cellular Gateway Firmware Release Note Copyright 2023 EtherWAN Systems, Inc.
Release Date: November 01, 2023

RELEASE SUMMARY EW200-TA / EW200-EUS
Version: EW200_0EW00G0.N91_e91.0EW1_10191600.bin

SUPPORTED PRODUCTS
EW200 Series

NEW FEATURES / ENHANCEMENTS N.A.

BUG FIXES

1. Manually Network Scan operate more smoothly.
2. Once IP lost and detect by system, system will auto trigger Auto Restore Configuration mechanism to recover.
3. Limit DH/PFS group setting to Group: None,1,2,5,14 for “Advanced settings” of “L2TP over IPsec”.
4. Wi-Fi WDS Hybrid Mode missing.

History

Release Date: April 13, 2023

RELEASE SUMMARY

EW200-TA / EW200-EUS Version: EW200_0EW00G0.N41_e41.0EW0_04071300.bin

SUPPORTED PRODUCTS

EW200 Series

NEW FEATURES / ENHANCEMENTS

1. Follow Azure to update Certificate Authority.

BUG FIXES

1. Data Logging data swap issue.
2. MQTT JSON value content is incorrect, when Modbus set Function Code : 0x04.
3. MQTT JSON content send to Azure is incorrect format in some data.
4. "Log file management" of "Azure Agent" of "Service", content of download file is empty.
5. Once "Polling Rate" of "Modbus Proxy rule" of "Data Logging" set value greater 3600 will be continued polling rapidly.

Release Date: December 30, 2021 RELEASE SUMMARY EW200-TA / EW200-EUS

Version: EW200_0EW00G0.L81_e81.0EW1_12151730.bin

SUPPORTED PRODUCTS

EW200 Series

NEW FEATURES / ENHANCEMENTS

1. Data Tag Pro function

BUG FIXES

1. NAT issue under virtual computer.
2. Parity setting of Modbus cause Data Logging working fail.
3. SNMP cannot set Enable / Disable of IPSec.

Contents

[1 Documents /
Resources](#)

[1.1 References](#)

Documents / Resources

