

Gems Warrick Series 26M Control Low-Water Cutoff Plug-In **Module User Manual**

Home » Gems » Gems Warrick Series 26M Control Low-Water Cutoff Plug-In Module User Manual



Contents

- 1 Gems Warrick Series 26M Control Low-Water Cutoff Plug-In
- 2 Specifications
- 3 Installation
- **4 Dimensional Drawing**
- **5 Operation**
- 6 Documents / Resources
 - **6.1 References**
- **7 Related Posts**



Gems Warrick Series 26M Control Low-Water Cutoff Plug-In Module



This bulletin should be used by experienced personnel as a guide to the installation of the Series 26M Control. Selection or installation of equipment should always be accompanied by competent technical assistance. We encourage you to contact Gems Sensors or a representative if further information is required.

Specifications

- Control Design: Solid-state components enclosed in a clear Lexan plug-in style housing. Not NEMA rated.
- Contact Design: 1 SPDT (1 form C), powered contacts (input Power L1 connected to common of relay contacts)
- Contact Ratings: 10A@120/240-VAC resistive (120°F), 1A @120/240VAC resistive (150°F), 1/3 HP @ 120/240-VAC (120°F).
- Contact Life: Mechanical -5 million operations Electrical -100,000 operations minimum at rated load
- Supply Voltage: Factory Configured: 24V, 120V, 220V, or 240V AC +10%/-15% of nominal, 50/60 Hz. Factory Configured: 208V/240V
- Model: 187V Min to 242V Max, VAC 50/60 Hz
- Power Consumption: 24/120/220/240-VAC with both relays energized ~ 4.4 VA.
- Secondary Circuit: 2.3 VAC RMS voltage on probes, < 1 milliampere source capability.
- Sensitivity: Factory programmed to 4.7K, 10K, 26K, 50K, or 100K Ohms
- Operating Ambient Temperature Range: -40°F to +150°F (-40°C to +65°C)
- Terminals: All connections made with screw-clamp terminals.
- **Time Delays:** Standard LLCO, 0.5 sec. on rising level, 3 sec. on falling level. Optional 0-90 sec. time delays in 1-sec. increments for rising and falling.
- Listings: Control carries U.L. Limit Control Listing (UL-353) for 24VAC and 120VAC Line Powered units only (220VAC, 240VAC, 208/240VAC units not rated).


Installation

- 1. Install octal socket in appropriate enclosure using two #6 or #8 screws.
- 2. Install rail mount socket on appropriate rail (DIN mount) in appropriate enclosure if applicable.
- 3. Wire control per wiring diagram following N.E.C and local codes.
- 4. Install control module in socket.


Sensitivity vs. Maximum Probe Wire Distance*

SENSITIVITY CHARACTER	SENSITIVITY (K-OHMS)	Distance (FT)
Α	4.7	900
В	10	600
С	26	250
D	50	100
Е	100	50

Dimensional Drawing



Wiring Diagram



IF METALLIC, TANK MAY BE USED INSTEAD OF REFERENCE PROBE

Operation

AUTOMATIC RESET

(Reset Switch terminals not wired) When the liquid rises to the electrode on terminal LLCO, the control energizes, changing state of the load contacts. (LED will be lit) The control remains energized until the liquid level recedes below electrode on terminal LLCO. The control then de-energizes, (LED will not be lit) returning load contacts to original state. Unless otherwise specified, there is a three second time delay on decreasing level. Liquid must be below probe on terminal LLCO for a full three seconds before control de-energizes.

MANUAL RESET

(Normally closed pushbutton installed across reset terminals) When the liquid rises to the electrode on terminal LLCO, the control will remain de-energized until the pushbutton is depressed. Upon Reset Switch activation, the control will energize, (LED will be lit) changing the state of the contacts. The control remains energized until the liquid level recedes below electrode on terminal LLCO. The control then de-energizes, (LED will not be lit) returning load contacts to their original state. Unless otherwise specified, there is a three second time delay on decreasing level. Liquid must be below probe on terminal LLCO for full three seconds before control deenergizes. Operator to wait 5 full seconds after power is applied before pressing reset switch (if manual reset is used).

• MANUAL RESET OPTIONAL POWER OUTAGE FEATURE

(Normally closed pushbutton across reset terminals) Control will auto-recover from a power loss. With liquid present on LLCO electrode at a power outage event, the control will de-energize and will automatically re-energize upon return of power with liquid present on the probe at powerup. However, if loss of liquid is sensed on power-up, the control will remain de-energized until liquid again rises to electrode and the pushbutton is depressed. The control will not attempt to auto-recover from a power outage if no liquid was present on the probe at power loss.


• TEST FEATURE

Allows LLCO circuit to be tested without the need to drop the water level in the boiler to create a dry probe condition. Holding down the reset button for 3 seconds will allow the LLCO circuit to trip, simulating a dry

probe. The controller will return to normal operation once the reset button is pressed a second time.

LED STATUS INDICATOR

In normal operation, the LED on the control will either be on or off depending on the controller state. On-board microprocessors continuously monitor for fault conditions. In the event a fault is detected, the LED will blink a pattern indicating the fault type. If you experience an inoperable control and the LED is blinking, attempt to leave the control in the blinking state and contact the factory for assistance.



	N.C.	Power	Test
	Pushbutton	Outage	Feature
Α	X	X	X
В			X
С	X		
Е		X	
F	X	X	
Υ	X		X
Z		X	Χ
0	No Option		

1.888.610.7664 www.calcert.com sales@calcert.com

Documents / Resources



Gems Warrick Series 26M Control Low-Water Cutoff Plug-In Module [pdf] User Manual Warrick Series 26M Control Low-Water Cutoff Plug-In Module, Warrick Series, 26M Control Low -Water Cutoff Plug-In Module, Cutoff Plug-In Module, Plug-In Module, Module, Module

References

• **Calcert**

Manuals+,