



**VRG Series  
Register  
Wall  
Heater**



# Global Commander VRG Series Register Wall Heater Instruction Manual

[Home](#) » [Global Commander](#) » Global Commander VRG Series Register Wall Heater Instruction Manual 

## Contents

- [1 Global Commander VRG Series Register Wall Heater](#)
- [2 IMPORTANT INSTRUCTIONS](#)
- [3 INSTALLATION INSTRUCTIONS](#)
- [4 OPERATING INSTRUCTIONS](#)
- [5 MAINTENANCE INSTRUCTIONS](#)
- [6 WIRING DIAGRAM](#)
- [7 Frequently Asked Questions](#)
- [8 Documents / Resources](#)
  - [8.1 References](#)
- [9 Related Posts](#)



## Global Commander VRG Series Register Wall Heater



## Product Specifications:

- **Model:** Register Wall Heater – VRG Series
- **Installation:** Recess wall mounting
- **Junction Box Volume:** 35 in.3 (576 cm3)
- **Recommended Wall Depth:** 3 in. (76 mm)
- **Power Supply:** Electrical
- Not recommended for use with ground fault circuit interrupter (GFCI)

## WARNING

When using electrical appliances, basic precautions should always be taken to reduce the risk of fire, electrical shock and injury, including the following.

Read carefully these instructions before installation, operation of the heater. Failure to adhere to the instructions could result in fire, electric shock, serious personal injury, and death or property damage. Review frequently for continuing safe operation and instruction of future users, if necessary.

## IMPORTANT INSTRUCTIONS

1. Read all instructions before installing or using this heater.
2. This heater is hot when in use. To avoid burns, do not let bare skin touch hot surfaces. Keep combustible materials, like furniture, pillows, bedding, papers, clothes, and curtains at least 36 in. (915 mm) from the front of the heater.
3. Extreme caution is necessary when any heater is used by or near children or invalids and whenever the heater is left operating and unattended.
4. Do not operate any heater after it malfunctions. Disconnect power at service panel and have heater inspected by a reputable electrician before reusing.
5. Do not use outdoors.
6. Do not insert or allow foreign objects to enter any ventilation or exhaust opening as this may cause an electric shock or fire, or damage the heater.
7. Do not block air intakes or exhaust in any way whatsoever.
8. This heater has hot and arcing or sparking parts inside.
9. Do not use it in areas where gasoline, paint, or flammable liquids are used or stored.
10. Use this heater only as described in this manual. Any other use not recommended by the manufacturer may cause fire, electric shock, or injury.
11. The heater has been designed and certified for ambient heating only. The maximum ambient operating temperature is 30 °C (86 °F).
12. The heater is not designed for use in a humid environment where condensation may form on the device.
13. This heater includes a visual alarm to warn that parts of the heater are getting excessively hot. If the light turns on, immediately turn the heater off and inspect for any objects on or adjacent to the heater that may have blocked the airflow or otherwise cause high temperatures to have occurred. If no obstruction is visible, the heater must be checked by a qualified person.
14. DO NOT OPERATE THE HEATER WHEN THE ALARM LIGHT IS ON.
15. The thermostat should not be considered an infallible device in cases where maintaining a temperature is considered critical. Examples: Hazardous material storage, computer server room, etc. In these particular

cases, it is imperative to add a monitoring system to avoid the consequences of a thermostat failure.


## INSTALLATION INSTRUCTIONS

The installation of this heater must be executed by a qualified person, where required by law.

### ATTENTION :


- For bathroom use, the heater must be installed so that switches and other controls cannot be touched by anyone in the bath or shower.
- This product is not recommended with the ground fault circuit interrupter (GFCI). The humidity in the air can generate a leakage current higher than the limit of the GFCI which will cause the product to stop.

### RECESS WALL MOUNTING;



1. May be recessed in 2X3 in. stud wall.
2. Provide an opening as shown on drawing, a minimum of 3 in. (76 mm) deep (Fig. 1).
3. Remove the appropriate knock-out from the recess box for the electrical supply. The heater junction box volume is 35 in.3 (576 cm3).
4. Install the heater or the recess box and be sure that the heater is attached firmly with the provided screws. Install so that when assembled, the deflectors direct the air towards the floor. Make sure that the edge on each side of the recess box lean on the gypsum panel and not on the structural parts of the wall. See marking on the sides of the recess box. **IMPORTANT:** If the recess box is pre-installed, insert the keyholes of the venturi on the 4 screws of the recess box and tighten the 4 screws to prevent vibration.
5. Connect the heater leads to the supply leads according to the wiring diagram of these instructions in accordance with local and national codes.
6. Install the grille using the provided screws. Make sure that the fan blade is free to rotate and the heater assembly is free of foreign objects and/or matter. Make sure that the solid panel of the grille covers the supply connection box.

7. Test heater by temporarily adjusting the thermostat at maximum temperature.



#### **SURFACE WALL MOUNTING:**

1. Locate the power supply leads behind the surface box.
2. Mount the surface box securely to the wall with the provided screws so that when assembled, the deflectors direct the air towards the floor.
3. Follow instructions 3 to 7 mentioned previously in the recess wall mounting section.

#### **4. OPTIONAL THERMOSTAT:**


Refer to the instruction supplied with the option.

#### **CAUTION:**

- High temperature, risk of fire, keep electrical cords, drapery, furnishings, and other combustibles at least 36 in. (915 mm) from the front of the heater. To reduce the risk of fire, do not store or use gasoline or other flammable vapors and liquids in the vicinity of the heater.
- In addition to ensuring that the clearance distances set out above are respected, ensure that the framing materials, insulation and finishing which are likely to be in contact with or close to the device can withstand temperatures of at least 90 °C (194 °F).

#### **IMPORTANT**

1. Allow 4 ft. (1.2 m) minimum clearance for air outlet.
2. Do not install less than 4 in. (102 mm) from flooring withstands temperature and 10 in. (254 mm) from linoleum flooring.
3. Do not install the venturi of the heater directly in the wall. Always install the heater in the wall with the recess box.



## OPERATING INSTRUCTIONS

1. The heater must be properly installed before it is used.
2. Turn the power on at the circuit breaker panel.
3. Electronic thermostat: be sure to set it on the fan mode.
4. Built-in thermostat (optional): to set thermostat at the desired temperature, follow these steps:
  - Set thermostat at maximum temperature (turn clockwise).
  - When the desired temperature is reached, turn the thermostat counterclockwise slowly until you hear a click.
5. Built-in thermostat with control knob, the setting can be done with the supplied knob, located on the front cover.
6. Built-in tamperproof thermostat: the setting can be done through the hole in the front cover with a small slotted screwdriver.
7. This heater includes a visual alarm to warn that parts of the heater are getting excessively hot. If the light turns on, immediately turn the heater off and inspect for any objects on or adjacent to the heater that may have blocked the airflow or otherwise caused high temperatures to have occurred. **DO NOT OPERATE THE HEATER WHEN THE ALARM LIGHT IS ON.**

## MAINTENANCE INSTRUCTIONS

1. Once a year, remove the front panel and use a vacuum cleaner to remove the dust accumulation inside the heater and through openings of the front panel.
2. Cleaning should be done while the heater is disconnected from the main service panel. Wait until the housing and heating element cool before performing maintenance.
3. Replace the front panel before energizing.
4. Any other servicing should be performed by a qualified technician.

## WIRING DIAGRAM

# WIRING DIAGRAM

The diagram illustrates a control circuit for a motor (M) and a lamp. The circuit includes a main power supply connected to a motor (M) and a lamp. A HI-LIMIT switch is connected in parallel with the lamp. A THERMOSTAT switch is connected in series with the motor. A THERMOSTAT switch (OPTION) is connected in parallel with the motor. A THERMOSTAT switch (OPTION) is connected in parallel with the motor. The circuit is grounded (GND).

- User Manual

## **Manuals+. Privacy Policy**

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.