



GROWATT Shine Master Monitoring Module User Manual

[Home](#) » [Growatt](#) » GROWATT Shine Master Monitoring Module User Manual 

Contents

- [1 GROWATT Shine Master Monitoring Module](#)
- [2 About the user manual](#)
- [3 Product Description](#)
 - [3.1 Unpacking](#)
- [4 Installation and Connection](#)
- [5 ShineMaster built-in page parameter setting](#)
- [6 5 ShineMaster data uploading to ShineServer](#)
- [7 Device Maintenance](#)
 - [7.1 Reset ShineMaster](#)
- [8 Technical specifications](#)
 - [8.1 ShineMaster specification](#)
- [9 Contact us](#)
- [10 Documents / Resources](#)
 - [10.1 References](#)



GROWATT Shine Master Monitoring Module



Some advantages of installing the datalogger and keeping it online:

1. Real-time monitoring: Get the health status of the PV plant; Receive the regularly reminder like daily reports, monthly reports and other free services.
2. Intelligent Operation and Maintenance: Get the one-click diagnosis function to easy the troubleshooting; Support the remote upgrade and parameters setting.

About the user manual

Manual description

Dear users, thank you very much for using the ShineMaster data logger (hereinafter referred to as ShineMaster) developed and produced by Shenzhen Growatt New Energy Co., Ltd. (hereinafter referred to as Growatt). We sincerely hope that this product will meet your needs and expect you give more opinions on the performance and function of the product. The purpose of this manual is to provide users with detailed product information and instructions for installation, operation, and maintenance.

Copyright Statement

This user manual is copyrighted by Growatt. Any unit or individual may not excerpt or copy part or all of this user's manual without the written permission of the company. It may not be transmitted in any form, including materials and publications. Infringement must be investigated. The version of this manual is V1.0. Growatt owns the final interpretation right of this user manual. If there is any change in product parameters, appearance, packaging, etc., the latest information of the company shall prevail without notice.

Applicable personnel


This manual is for professional technicians who install, commission, and maintain the ShineMaster and for users who perform daily operations. This manual does not include electrical connections for inverters, combiner boxes, weather stations, smart meters, and anti-reflux devices, as well as related precautions. If necessary, refer to Growatt's corresponding user manual or instruction.

Manual usage

Please read this manual carefully before using ShineMaster. At the same time, please keep this manual in a safe place so that operators and maintenance personnel can find out. The contents of the manual will be continuously updated and corrected. It is inevitable that there will be slight inaccuracies or errors in the actual contents. Users should refer to the actual product purchased. The latest user manuals can be downloaded from www.ginverter.com, and can also be obtained through Growatt's sales or service channels.

Product Description

Device Overview



Interface

The interface of ShineMaster, as shown in figure 2-1 above. The functional description of each interface is shown in table 2-1.

Item	Name	Function
A	POWER	Power supply port
B	KEY	Reset button (temporarily unavailable)
C	SIM	SIM card slot
D	ANTENNA	Antenna, used to receive wireless signals (Temporarily not supported)
E	LAN	RJ45 port Connect Shine ShineMaster to the local network area of Shine Server through RJ45 cable
F	RS-485	Two-way RS485 interface

Indicator Led

ShineMaster is equipped with seven LED indicators. The status of the ShineMaster can be displayed by the LED indicator. As shown in figure 2-1 and table 2-2 above.

Item	Name	Function
G	Power LED	Power indicator light, constant on means power supply is normal
H	Network LED	Network light: 1: off means fail to obtain IP address; 2: flashing means connecting to the server; 3:on means connection to the server successfully
I	Device LED	The number of the LED continuously flashing means the device number connected to the ShineMaster
J	Configuration LED	Flashing when configuration , if successful , the LED will be off temporarily unavailable
K	RF	RF signal indicator temporarily unavailable
L	WiFi	WiFi signal indicator temporarily unavailable
M	2G/4G	2G/4G signal indicator temporarily unavailable

Unpacking

Packing List

ShineMaster and accessories can be found as below figure 2-2




Fig 2-2

Item	Name	Amount
A	ShineMaster	1 pcs
B	5V power adapter	1 pcs
C	Terminal RS485	1 pcs
D	Wall plastic column	4 pcs
E	M3.5*20 screw	4 pcs
F	ShineMaster user manual	1 pcs
G	Ethernet cable	1 pcs

Serial No. and Check Code

The ShineMaster serial No. S/N and check code C/C is ticked on the ShineMaster's package box, which have 10 digits mixed up with letters and numbers. the serial No. and check code for each device are unique, to identify each ShineMaster. When you want to upload the data of ShineMaster to the server, you need the serial No. and 'check code' corresponding to register on the server

ShineMaster Network Introduction

ShineMaster supports network communication, which can be communicated via wired WLAN, wireless WiFi, 2G/4G, GPRS and cloud server. Upload the monitored data to the server of Growatt, and then access the server's domain name. Realize industrial common communication mode RS485 and wireless RF communication, also supports wired and wireless communication ways to monitor and set slave devices and perform online upgrades on devices. By accessing ShineMaster's internal IP address, you can enter the built-in page for parameter setting and device addition viewing (please refer to section 4.4 below). ShineMaster monitors the photovoltaic devices through RS485 and RF(temporarily not supported). The diagram below shows the schematic diagram of network monitoring through wired RS485. Note: The precondition of local access is that the address of PC and ShineMaster must be in the same domain, thereby building up a local monitoring system.



Fig 2-5

Installation and Connection


ShineMaster installation

The installation environment of ShineMaster and communication with other devices:

1. Indoor installation, temperature – 30 ~ 60 , avoid moisture and direct sunlight.
2. Cable RS485 in maximum 1000m.
3. The length of communication cable to the switch or router is not more than 100m

ShineMaster installation

Installation Procedure



The installation steps are as follows:

1. Install ShineMaster on a vertical plane or horizontal plane.
2. Connect cables between RS485 interface and RS485 interface on ShineMaster (please refer to 3.3.1 below for details)
3. Connect the network cable (insert the network line into the LAN interface on ShineMaster).
4. Connect the Power supply (connect the power cord to the Power interface on ShineMaster).


Connect to the photovoltaic device

ShineMaster can communicate with the inverter, weather station, smart meter, combiner box and other photovoltaic devices to achieve the purpose of data collection.


RS485 cable connection

1. ShineMaster (master) communicates with slave devices via RS485 wired connection. 485A+ on the RS485 port of the slave device corresponds to A1+ or A2+ on the ShineMaster 485 port, 485B- and ShineMaster 485 on the RS485 port of the slave device. Corresponding to B1- or B2-. The following is a schematic diagram of the connection between the ShineMaster and the inverter:

Note: the RS485 shielded wire must be ground (PE) for long distance communication, so as not to affect the communication stability.



1. Note that the inverter also has an interface like the one below:



1. The inverters are connected to the ShineMaster via RS485 serial connection. Using the RS485 wired communication connection, the ShineMaster can monitor up to 64 inverters stably.
2. The ways of ShineMaster connection to Smart meter, combiner box and environmental monitor are similar to the connection of inverters. The weather station can be connected to the inverter in series, and the communication line of the smart meter can be directly connected to the ShineMaster RS485 port.
Note: The weather station, combiner, and smart meter manufacturers must be designated by Growatt, otherwise monitoring will not be possible.

ShineMaster built-in page parameter setting

ShineMaster IP address query

1. Connect the PC computer and the ShineMaster LAN port to the network port of the router through the network cable so that they are in the same LAN.
2. Go to the router's management page and check the "Internet host list" to query the IP address of the ShineMaster IP address with the serial number of the ShineMaster as the device name. This IP address is the IP address assigned by the router to the ShineMaster. If you do not know how to do this, contact your network administrator to perform the operation.

Note: The router needs to enable automatic IP assignment, that is, open the DHCP function

3. Enter the ShineMaster IP address in the browser to enter the ShineMaster internal page

ShineMaster built-in page access

Before accessing, check whether the communication cable between the devices is securely connected. then you can enter the ShineMaster IP address in the IE browser to access the built-in page of ShineMaster. As long as the ShineMaster is on the same domain as the computer you are accessing, you can access the Shine WebBox built-in server.

1. If the user successfully access the ShineMaster internal page, you can directly enter the built-in page login interface, as shown in Figure 4-1



Fig 4-1

2. Enter the user name and password, the default login user name: admin password: admin, fill in and click on login to enter the Growatt ShineMaster system page.

ShineMaster Status View

Click the ShineMaster datalogger Status to view information such as the "System Status Information", "Serial Number", "Server Address", "Number of Connected Devices", etc. of the ShineMaster



ShineMaster Setting Center

[简体中文](#)
[English](#)

[Datalogger information](#)
[Export limit & Datalogger setting](#)
[Network setting](#)
[System management](#)
[Device state](#)

Logout

Datalogger information	
Connection status	Online
SN	YKC0835014
Server IP	server-cn.growatt.com
Server port	5279
Datalogger location IP	192.168.0.161
Time	0.5
Datalogger MAC	00:47:00:BF:96:E6
Hardware version	V1.0
Firmware version	1.0.5.9
Datalogger type	ShineMaster
Device number	0
Offline data number	0
Export limit enable	Disable
Export limit power (kW)	2

ShineMaster Datalogger managing

Devices should be added in 'ShineMaster datalogger setting' interface in internal page prior to monitoring

Add device

- Before ShineMaster monitors photovoltaic equipment, it is necessary to enter the "ShineMaster Data Collector Settings" page of the built-in page to add devices.



ShineMaster Setting Center

[简体中文](#)
[English](#)

[Datalogger information](#)
[Export limit & Datalogger setting](#)
[Network setting](#)
[System management](#)
[Device state](#)

Logout

Export limit & Datalogger setting	
Meter channel	RS485_2
Meter address	2
Monitor mode	<input checked="" type="radio"/> NONE <input type="radio"/> Export limitation <input type="radio"/> Storage Parallel
Reactive power regulation	<input type="radio"/> On <input checked="" type="radio"/> Off
Add or delete devices	RS485_2 NULL <input type="radio"/> Add <input type="radio"/> Del
SCADA to Vietnam	<input type="radio"/> On <input checked="" type="radio"/> Off
Update firmware	<input type="radio"/> Yes <input checked="" type="radio"/> No
Reboot	<input type="radio"/> Yes <input checked="" type="radio"/> No
<div>Save</div> <div>Cancel</div>	

- In the second drop-down list, select the type of monitored device

ShineMaster Setting Center 简体中文 English

[Datalogger information](#)
[Export limit & Datalogger setting](#)
[Network setting](#)
[System management](#)
[Device state](#)

[Logout](#)

Export limit & Datalogger setting	
Meter channel	RS485_2
Meter address	2
Monitor mode	<input checked="" type="radio"/> NONE <input type="radio"/> Export limitation <input type="radio"/> Storage Parallel
Reactive power regulation	<input type="radio"/> On <input checked="" type="radio"/> Off
Add or delete devices	RS485_2 GRT_METER 10 <input type="radio"/> Add <input type="radio"/> Del
SCADA to Vietnam	<input type="radio"/> On <input checked="" type="radio"/> Off
Update firmware	<input type="radio"/> Yes <input checked="" type="radio"/> No
Reboot	<input type="radio"/> Yes <input checked="" type="radio"/> No
<input type="button" value="Save"/> <input type="button" value="Cancel"/>	

3. In the third drop-down list, fill in the communication address of monitored device

ShineMaster Setting Center 简体中文 English

[Datalogger information](#)
[Export limit & Datalogger setting](#)
[Network setting](#)
[System management](#)
[Device state](#)

[Logout](#)

Export limit & Datalogger setting	
Meter channel	RS485_2
Meter address	2
Monitor mode	<input checked="" type="radio"/> NONE <input type="radio"/> Export limitation <input type="radio"/> Storage Parallel
Reactive power regulation	<input type="radio"/> On <input checked="" type="radio"/> Off
Add or delete devices	RS485_2 GRT_METER 10 <input type="radio"/> Add <input type="radio"/> Del
SCADA to Vietnam	<input type="radio"/> On <input checked="" type="radio"/> Off
Update firmware	<input type="radio"/> Yes <input checked="" type="radio"/> No
Reboot	<input type="radio"/> Yes <input checked="" type="radio"/> No
<input type="button" value="Save"/> <input type="button" value="Cancel"/>	

4. Select “Add” and click Save.

5. After successfully saving, enter the “Device Status” page to confirm whether the device is added successfully.

ShineMaster Setting Center 简体中文 English

[Datalogger information](#)
[Export limit & Datalogger setting](#)
[Network setting](#)
[System management](#)
[Device state](#)

[Logout](#)

Address	Device type	Device SN	Device state	Channel
010	GRT_METER		Normal	RS485_2

Remove device

1. Select the monitoring method for monitoring PV devices in the first drop-down list of “Add or Remove Devices”.
2. In the second drop-down list, select the type of PV plant being monitored.
3. Fill in the PV device communication address in the third drop-down list.
4. Select “Del” and click Save to finish removing of the device.
5. After successfully saving, enter the “Device Status” page to confirm whether the device is successfully deleted.

5 ShineMaster data uploading to ShineServer

Registration and login

(1) Enter the address of the server on the computer browser to enter the ShineServer login page. If you are logging in for the first time, register the user name first. Enter the domain name access page, as shown in Figure 5-1.

- The Chinese user server domain name is: <http://server-cn.growatt.com>
- The overseas user server domain name is: <http://server.growatt.com>



Figure 5-1 Shine Server login page

Register the user name and input the user information according to the pop-up. After the information is completed, click “Register”.

Note: “ShineMaster serial number” and “datalogger check code” seen on the package box.


The image shows a web registration form for GROWATT. At the top left is the GROWATT logo. The title 'Register' is centered at the top. On the top right is a link 'Back To Login'. Below the title are three tabs: 'User' (selected), 'Installer', and 'Distributor'. The 'User' tab contains the following fields: 'Country' (a dropdown menu), 'Username' (with a hint 'No More Than 30 Characters'), 'Password' (with a hint 'Not Less Than 6 Digits'), 'Password Confirm' (with a hint 'Not Less Than 6 Digits'), 'Language' (a dropdown menu with 'English' selected), 'Phone Number', 'E-Mail', and 'Installer Code'. Below these fields is a checkbox labeled 'I have read and agree to the (Privacy policy)'. At the bottom is a blue 'Next' button.

Fig 5-2

View monitoring data

1. After the registration is completed, it will automatically jump to the ShineServer main interface. Click “plant” → “plant data” , and the displayed information is the total power chart of the plant on the day. The drop-down list “Select collector” can be used to view the daily power chart of a single inverter in the power station.




Fig 5-3

- Click “plant” → “Device list” to see real-time data monitored by datalogger, “Inverter”, “Weather station”, “Smart Meter”, and “Combined Box” “MAX” .

Device Maintenance

Reset ShineMaster

Common faults and troubleshooting

Fault	Cause	Suggestion
Cannot enter the Shine Master internal page	ShineMaster can not obtain the IP	1.Enable Router DHCP Function 2.PC and the Shine Master must be in the same domain.
ShineMaster built-in page "System Status Information" shows not connected	Unable to connect to server	1.Check whether the router network is connected to the Internet. 2. Check if the "server address" is correct The Chinese user server domain name is: http://server-cn.growatt.com The overseas user server domain name is: http://server.growatt.com
ShineMaster is online, but the monitored device is disconnected after logging in to the account	1.Monitor connection failed 2.No access to the built-in page to add equipment 3.Inconsistent Photovoltaic equipment address and added equipment address 4.Illegal PV device serial number	1.Check the communication line is in contact with the stability 2.Enter the built-in page "datalogger settings" to add photovoltaic devices 3. On the "Device Status" page of the built-in page, check whether the device's communication address is consistent with the added device. 4.Check whether the serial number of the monitored PV equipment is 10 digits. It can only contain English letters and numbers, and there are no illegal characters.
Long time no refresh interface after operation	Configuration page does not respond	Refresh the page or login in again.

Maintenance

1. Avoid frequent switching of power supply, gently handle, to prevent damage;
2. ShineMaster is a product for indoor use. Do not place ShineMaster in a humid environment or in direct sunlight.

Technical specifications

ShineMaster specification

General specification

Length * width * height	135mm*79mm*29mm
Net Weight	70g

Operating environment

Ambient temperature	-40°C~ +80°C
Installation	Indoor

Communication


Wireline communication	RS485 maximum stability monitoring 64 inverters
Wireless communication	Not supported temporarily
RS485 communication distance	1000 meters maximum (twisted shielded cable)

Contact us

Growatt New Energy provides customers with a full range of technical support. Users can contact the nearest Growatt new energy office or customer service point, or they can contact the company's customer service center directly.

- Name: SHENZHEN GROWATT NEW ENERGY CO.,LTD
- **Address:** 4-13/F, Building A, Sino-German(Europe) Industrial Park, Hangcheng Ave, Baoan District, Shenzhen, China
- **Customer Service Hotline:** +86 755 27471942
- **E-mail:**service@ginverter.com
- **Company website:** www.ginverter.com

Documents / Resources

	GROWATT Shine Master Monitoring Module [pdf] User Manual Shine Master, Shine Master Monitoring Module, Monitoring Module, Module
---	---

References

- [G Sign In](#)
- [G Sign In](#)

-  [Growatt | Global Leading Distributed Energy Solution Provider](#)

Manuals+.