

# Honeywell HE225A Bypass Flow-Through Humidifiers with **Agion Owner's Manual**

Home » Honeywell » Honeywell HE225A Bypass Flow-Through Humidifiers with Agion Owner's Manual



#### **Contents**

- 1 Honeywell HE225A Bypass Flow-Through Humidifiers with Agion
- **2 OPERATING YOUR HUMIDIFIER**
- 3 HE225B,HE265B
- 4 HE225A,B AND HE265A,B BY-PASS FLOW-THROUGH HUMIDIFIERS WITH
- **5 HOW YOUR HUMIDIFIER WORKS**
- **6 MAINTAINING YOUR HUMIDIFIER**
- 7 End of Humidification Season
- **8 CHECKING YOUR HUMIDIFIER OPERATION**
- 9 TROUBLESHOOTING YOUR HUMIDIFIER
- **10 WARRANTY**
- 11 Documents / Resources
  - 11.1 References
- 12 Related Posts


Honeywell

# Honeywell HE225A Bypass Flow-Through Humidifiers with Agion



## **OPERATING YOUR HUMIDIFIER**

Your Enviracaire Elite™ HE225A and HE265A. Humidifiers from Honeywell are controlled by the H8908B Convertible Humidity Control. The convertible humidity control is installed either on an interior wall in the living area, or on the return air duct. Choose the humidity control setting using the combination relative humidity/outdoor temperature setting scale on your humidity control dial. Match the dial setting to the outdoor temperature for optimizing the humidity level while reducing moisture condensation on your windows. The table below can also be used to adjust humidity control to the recommended setting.




At Outside Temperature	Recommended Control Setting	At Outside Temperature	Recommended Control Setting
-20°F (-29°C)	15	+10°F (-12°C)	30
-10°F (-23°C)	20	+20°F (-7°C)	35
0°F (-18°C)	25	Above 20°F (-7°C)	40

## **NOTE**

As outside temperature drops, the recommended humidity control setting is lowered to adjust for effects of dewpoint. These settings should reduce the accumulation of moisture and ice on your windows and other areas of your home. Some indoor activities such as cooking, showering and clothes drying can cause excessive levels of humidity and start the accumulation of moisture on your windows. If this condition persists for more than a few hours, set the humidity control to the lowest setting to turn off the humidifier. If the condition does not improve, ventilate your home to remove the moisture.

# HE225B,HE265B

Your Enviracaire Elite™ HE225B and HE265B. Humidifiers are controlled by the Honeywell H1008 Automatic Humidity Control with HumidiCalc+™. The automatic humidity control is mounted in the return air duct where it can be exposed to the air stream of the return air.



## HE225A,B AND HE265A,B BY-PASS FLOW-THROUGH HUMIDIFIERS WITH AGION

The HumidCalc+<sup>TM</sup> software inside your automatic humidity control is designed to measure or infer outdoor temperature and automatically adjust the humidity based on the frost factor setting that the homeowner sets to allow for variances in furnace size, window type and insulation. The Automatic Humidity Control with HumidiCalc+<sup>TM</sup> requires an initial adjustment period. For maximum humidification, set the H1008 to 10 and run the fan continuously. Check for condensation on windows after a cold night. If there is no condensation, leave the setting at 10. If there is condensation, lower the frost factor dial one setting. Continue to check for condensation on cold mornings until the correct humidity setting is reached for your home. Allow two days between adjustments to determine if further adjustment is necessary. Once you have tuned in the proper setting, you should never have to adjust it again. HumidiCalc+<sup>TM</sup> takes over and makes any future adjustments caused by varying outdoor temperatures, thus reducing moisture build-up on windows while maintaining the optimal humidity level.

Humidity Level	Recommended Setting	
Insufficient humidity	Increase the frost factor dial by one setting.	
Condensation on windows	Decrease the frost factor dial by one setting.	

## **HOW YOUR HUMIDIFIER WORKS**

Your Enviracaire Elite<sup>TM</sup> humidifier uses the principle that vapor (evaporated water) is created when warm air blows over a water-soaked area. As the vapor circulates, the relative humidity rises. Your humidity control monitors the relative humidity and activates the humidifier

relative humidity rises. Your humidity control monitors the relative humidity and activates the humidifier accordingly. The humidifier has a water supply that dispenses water evenly over the AglON™ antimicrobial humidifier pad. The warm dry air, from the furnace, passes over the humidifier pad and picks up the moist air to circulate it throughout your home. Humidified air feels warmer and more comfortable so you may be able to lower your thermostat heating setpoint, which saves money on your heating fuel bills. The end result is that your humidifier gives you a cleaner, more comfortable environment that is also energy efficient.

## **MAINTAINING YOUR HUMIDIFIER**

A regular maintenance program prolongs the life of your humidifier and provides a more comfortable home. The frequency of cleaning depends on the condition of your water. You can use either hard or soft water in your humidifier, but hard water mineral deposits are more difficult to clean than soft water deposits. For optimum performance, Honeywell recommends replacing the AglON<sup>TM</sup> antimicrobial pad once a year. Use the following

procedure to clean your Honeywell humidifier.

#### **WARNING**

- · Serious Personal Injury Hazard.
- Can cause electrical shock and injury from moving parts.
- Disconnect power and shut off water supply before removing cover.


**IMPORTANT:** Never oil any part of the humidifier.

## **Every 1 to 3 Months (Depending on Water Quality)**

- 1. Disconnect power and turn off humidifier water supply.
- 2. Remove the humidifier cover by unplugging the connector and loosening the thumb screw. Grasp the cover near the bottom and pull toward you.
- 3. Remove humidifier pad assembly from humidifier by grasping top of tray and pulling it toward you.
- 4. Lift the tray off the pad.
- 5. Gently pinch water nozzle catches inward until you can lift water nozzle off tray.
- 6. Carefully remove any mineral deposits from tray and frame. Be sure frame drain hole is not blocked.
- 7. Disconnect drain hose from drain fitting on the bottom of the humidifier housing.
- 8. Clean the drain fitting, if necessary.
- 9. Bend the drain hose to loosen any mineral deposits.
- 10. Flush the drain hose with pressurized water (a running tap) to clean the hose.
- 11. Reattach the drain hose to the drain fitting.
- 12. Snap the water nozzle back on the tray.
- 13. Be sure the marked end of the pad is facing up. Place the tray on the new pad.
- 14. Place humidifier pad assembly in humidifier housing. Be sure water feed tube is placed in guide slots.
- 15. Replace the humidifier cover.
- 16. See Checking Your Humidifier for Proper Operation section to verify operation.

#### **End of Humidification Season**

Clean the humidifier and shut it off at the end of the heating season. See Every 1 to 3 Months section, steps 1 through 15, to shut down for the season.



**IMPORTANT:**Be sure humidifier power is off.

## **Vacation**

- The humidifier water supply and your humidity control can be turned off.
- Turn on humidifier water supply and reset your humidity control when you return.

# **CHECKING YOUR HUMIDIFIER OPERATION**

After winter startup or servicing, check the humidifier operation:

- 1. Turn on the humidifier power and water supply.
- 2. Turn H8908B Control to highest setting or H1008A Control to test position; set thermostat to 10°F (6°C) above room temperature.

## **NOTE**

• The H1008A Automatic Humidity Control stays in test mode for thirty minutes. Then it automatically resets to


- the maximum frost factor setting.
- If system checkout is not completed in thirty minutes, test mode can be extended by turning dial setting back and then returning it to test mode.
- 1. Observe that water is flowing out of the drain hose. The furnace blower must be on to activate the humidifier.
- 2. Reset thermostat and H8908A Control to comfortable setting or H1008A Automatic Control to desired frost factor setting for automatic operation.

## TROUBLESHOOTING YOUR HUMIDIFIER

Problem	What to Look for	What to Do
Low humidity	Furnace blower not operating.	<ul> <li>Reset circuit breaker or replace fuse.</li> <li>Check that the furnace power is on.</li> <li>Check all external wiring connections.</li> <li>Check humidity control setting.</li> <li>Call a heating contractor.</li> <li>Keep doors and windows closed.</li> </ul>
	Rapid air changes. Drafts (cold air i s dry and is an added load to humidifier).	Close fireplace damper if not using.  Minimize exhaust fan running time.  Seal around doors and windows.
High humidity	Condensation on walls.	•Turn off humidity control and water until condensati on is completely evaporated.
	Heavy condensation on windows.	•Turn humidity control low enough to eliminate bath and cooking condensation moisture. If moisture per sists, more ventilation is needed.

## ADDING PERFECT CLIMATE® CONTROLS FOR COMFORT AND CONVENIENCE

- 1. Honeywell Perfect Climate Comfort Center™ controls or Chronotherm® IV Programmable Thermostats.
- 2. Honeywell media air cleaner or electronic air cleaners3. Honeywell humidistats.
- 3. Honeywell humidifiers.
- 4. Honeywell home ventilation systems.



#### **Describing Perfection**

The cleanest, healthiest, most convenient, energy efficient, and comfortable indoor environment possible today! Perfect climate is achieved when the following five core components of a home's climate system work together:

- · optimal efficiency heating and cooling equipment,
- precise, programmable temperature control,
- · effective indoor air quality control,
- · controlled humidity,
- proper ventilation and air distribution.

Contact your local Perfect Climate® dealer for an evaluation of your home.

## **WARRANTY**

Honeywell warrants this product, excluding the humidifier pad, to be free from defects in the workmanship or materials, under normal use and service, for a period of one (1) year from the date of purchase by the consumer. If, at any time during the warranty period, the product is defective or malfunctions, Honeywell shall repair or replace it (at Honeywell's option) within a reasonable period of time. If the product is defective, return it, with a bill of sale or other dated proof of purchase, to the place where you purchased it.

This warranty does not cover removal or reinstallation costs. This warranty shall not apply if it is shown by Honeywell that the defect or malfunction was caused by damage

that occurred while the product was in the possession of a consumer. Honeywell's sole responsibility shall be to repair or replace the product within the terms stated above.

HONEYWELL SHALL NOT BE LIABLE FOR ANY LOSS OR DAMAGE OF ANY KIND, INCLUDING ANY INCIDENTAL OR CONSEQUENTIAL DAMAGES RESULTING, DIRECTLY OR INDIRECTLY, FROM ANY BREACH OF ANY WARRANTY, EXPRESS OR IMPLIED, OR ANY OTHER FAILURE OF THIS PRODUCT. Some states do not allow the exclusion or limitation of incidental or consequential damages, so this limitation may not apply to you.

THIS WARRANTY IS THE ONLY EXPRESS WARRANTY HONEYWELL MAKES THIS PRODUCT. THE DURATION OF ANY IMPLIED WARRANTIES, INCLUDING THE WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, IS HEREBY LIMITED TO THE ONE YEAR DURATION OF THIS WARRANTY. Some states do not allow limitations on how long an implied warranty lasts, so the above limitation may not apply to you. This warranty gives you specific legal rights, and you may have other rights which vary from state to state. If you have any questions concerning this warranty, please write Honeywell

#### Customer

- Care, 1985 Douglas Dr N, Golden Valley, MN 55422 or call 1-800-468-1502. In
- Canada, write Retail Products, ON15, Honeywell Limited/Honeywell Limitée, 35
- Dynamic Dr, Toronto, Ontario M1V 4Z9.

#### **Automation and Control Solutions**

- Honeywell International Inc. Honeywell Limited-Honeywell Limitée
- 1985 Douglas Drive North 35 Dynamic Drive
- Golden Valley, MN 55422 Toronto, Ontario M1V 4Z9 yourhome.honeywell.com

### **Documents / Resources**



Honeywell HE225A Bypass Flow-Through Humidifiers with Agion [pdf] Owner's Manual HE225A, HE265B, HE265B, Bypass Flow-Through Humidifiers with Agion, HE225A B ypass Flow-Through Humidifiers with Agion

### References

• H Honeywell Home | Smart Home Comfort and Security

Manuals+,