




[Home](#) » [HYTRONIK](#) 

HYTRONIK[®]

HMW24 Daylight Harvest for Independent DALI
Instruction Manual





Contents


- [1 Stand-alone HF Motion Sensor HF](#)
- [2 Technical Data](#)
- [3 Functions and Features](#)
- [4 Settings \(Remote Control HRC-11\)](#)
- [5 Rotary Switch Preset](#)
- [6 Wiring Diagram](#)
- [7 Detection Pattern](#)
- [8 Documents / Resources](#)
 - [8.1 References](#)

Stand-alone HF Motion Sensor HF

HMW24

Daylight Harvest for Independent DALI

Mechanical Structure



1. Sensor inset
2. Lens pluggable
3. Protection cover (covers the high-voltage terminals).
4. Ceiling (drill hole $\varnothing 70\text{mm}$).

Note: We recommend the mounting distance between sensor to sensor should be more than 2m to prevent sensors from false-triggering.

Technical Data

Input Characteristics

Model No.	HMW24
Mains voltage	220~240VAC 50/60Hz
Stand-by power	<0.5W
Switched power	Max. 20pcs devices, 40mA
Warming-up	20s

Safety and EMC

EMC standard (EMC)	EN55015, EN61000
Safety standard (LVD)	EN60669, AS/NZS60669
Radio Equipment (RED)	EN300440, EN301489, EN62479
Certification	Semko, CB, CE, EMC, RED, RCM

Sensor Data

Model No.	HMW24
Sensor principle	High Frequency (microwave)
Operation frequency	5.8GHz +/- 75MHz
Transmission power	<0.2mW
Detection range	Max. (O x H) 12m x 6m
Detection angle	360°

Environment

Operation temperature	Ta: -20°C ~ +50°C
IP rating	IP20








Functions and Features


1. Daylight Harvest



Light will not switch on when natural light is sufficient, even there is motion detected.




The light switches on automatically with presence when natural light is insufficient.



The light turns on at full or dims to maintain the lux level. The light output regulates according to the level of natural light available.



The light switches off when the ambient natural light is sufficient.



The light dims to stand-by period after hold-time and stays on selected minimum dimming level.



The light switches off completely after the stand-by period.

Note:

The Light automatically dims down and eventually turns off if the natural light lux level exceeds the daylight threshold. However, if the stand-by period is preset at “+∞”, the fixture never switches off but dim to minimum level, even the natural light is sufficient.

2. Manual Override

With the help of push-switch, this sensor can be over-riden by the end-user to manually switch on/off the light, or adjust the target lux level by push-switch, which makes the product more user-friendly and offers more options to t some extra-ordinary demands:

* Short Push (<1s): on/off function;

On → Off: the light turns off immediately and cannot be triggered ON by motion until the expiration of pre-set hold-time. After this period, the sensor goes back to normal sensor mode.

Off → On: the light turns on and goes to sensor mode, no matter if ambient Lux level exceeds the daylight threshold or not.

* Long Push (>1s): adjust the target lux level by turning the light up or down. Both the adjustment on remote control and push switch can overwrite each other. The last adjustment remains in memory.

Note: if end-user do not want this manual override function, just leave the “push” terminal unconnected to any wire.

3. Semi-auto Mode (Absence Detection)

It is easy to forget to switch off the light, in office, corridor, even at home. And in many other cases, people do not want to have a sensor to switch on the light automatically, for example, when people just quickly pass-by, there is no need to have the light on. The solution is to apply this “absence detector”: motion sensor is employed, but only activated on the manual press of the push-switch, the light keeps being ON in the presence, and dims down in the absence, then switches off in the long absence.

Note: end-user can choose either function 2 or function 3 for application. Default function is manual override.

4. Synchronization Function

By connecting the “SYNC” terminals in parallel (see wiring diagram), no matter which sensor detects motion, all HMW24 in the group will turn on the lights when surrounding natural light is below the daylight threshold. The detection area could be widely enlarged in this way.

Settings (Remote Control HRC-11)



Permanent ON/OFF function

Press button “ON/OFF” to select permanent ON or permanent OFF mode.

* Press button “AUTO”, “RESET” to quit this mode.

The mode will change to AUTO Mode after power failure.



Reset Settings

Press button “RESET”, all settings go back to rotary switch settings.



Shift Button

Press button “Shift”, the LED on the top left corner is on to indicate mode selection.

All values / settings in RED are valid for 20 seconds.



AUTO mode

Press button “AUTO” to initiate automatic mode. The sensor starts working and all settings remain as before the light is switched ON/OFF.



SEMI-AUTO mode

1. Press button “Shift”, the red LED flashes for indication.
2. Press button “SEMI-AUTO/AUTO” to initiate semi-auto mode. The fixture is manually turned on by pressing the push-switch, and goes off automatically in this mode. (Absence detection mode)



Power output

Press the buttons to select light output at 80% (at initial 10,000 hours) or 100%.

Note: “Sensor off” and “Twilight” functions are disabled.




Brightness +/-

Press the buttons to adjust the light brightness to reset the target lux level.



Scene program – 1-key commissioning

1. Press button “Start” to program.
2. Select the buttons in “Detection range”, “Daylight threshold”, “Hold-time”, “Stand-by time”, “Stand-by dimming level” to set all parameters.
3. Press button “Memory” to save all the settings programmed in the remote control.



HRC-11

4. Press button “Apply” to set the settings to each sensor unit(s).

For example, to set detection range 100%, daylight threshold Disable, hold-time 5min, stand-by time +, stand-by dimming level 30%, the steps should be: Press button “Start”, button “100%”, “Disable”, “Shift”, “5min”, “Shift”, “+”, “30%”, “Memory”. By pointing to the sensor unit(s) and pressing “Apply”, all settings are passed on the sensor(s).

Detection range

Press buttons in zone “Detection range” to set detection range at 100% / 75% / 50% / 10%.

Daylight threshold

Press buttons in zone “Daylight threshold” to set daylight sensor / target lux level at 50Lux / 100Lux / 300Lux / 500Lux / Disable. Note: 2lux / 10lux are disabled.

Note: 2lux / 10lux are disabled.

To set daylight sensor at 100Lux / 300Lux / 500Lux, press “Shift” button first.

Ambient daylight threshold

1. Press button “Shift”, the red LED starts to flash.
2. Press button “Ambient”, the surrounding lux level is sampled and set as the new daylight threshold / target lux level.

Hold-time

Press buttons in zone “hold-time” to set the hold-time at 2s / 30s / 1min / 5min / 10min / 15min / 20min / 30min.

Note:

1. To set hold-time at 30s / 5min / 15min / 30min, press “Shift” button first.
2. 2s is for testing purpose only, stand-by period and daylight sensor settings are disabled in this mode.
*To exit from Test mode, press button “RESET” or any button in “Hold-time”.

Stand-by time (corridor function)

Press buttons in zone “stand-by time” to set the stand-by period at 0s / 10s / 1min / 5min / 10min / 30min / 1h / +.

Note: “0s” means on/off control; “+” means bi-level control, the fixture is 100% on when there is motion detected, and remains at the stand-by dimming level when no presence after motion hold-time.

Stand-by dimming level

Press the button in zone “stand-by dimming level” to set the stand-by dimming level at 10% / 20% / 30% / 50%.

Daylight harvest auto-configuration function

1. Press button “Shift”, the red LED starts to flash.
2. Select a time period and the sensor will do light level measurement and determine/save the lowest light level (commission line) with 100% light on, so as to set the target lux level automatically.

Note:

1. Make sure the light level measurement covers the night time.
2. The fixture will go into sensor mode after the measurement, all sensor settings remain unchanged.

Dual tech & RF mode

All buttons are disabled.

Rotary Switch Preset


A rotary switch is built inside the sensor for scene selection / fast programming. Total 16 channels are available:




Note: settings can also be changed by remote control HRC-11. The last action controls.

Channel	Detection range	Hold-time	Daylight sensor	Stand-by time	Stand-by dim level
0	100%	5s	Disable	10s	10%
1	100%	1min	50Lux	5min	10%
2	100%	5min	50Lux	10min	10%
3	100%	5min	75Lux	+∞	10%
4	100%	5min	100Lux	+∞	10%
5	100%	5min	200Lux	+∞	30%
6	100%	10min	50Lux	30min	10%
7	100%	10min	75Lux	+∞	10%
8	100%	10min	100Lux	+∞	10%
9	100%	10min	200Lux	+∞	30%
A	100%	20min	100Lux	1h	10%
B	100%	20min	200Lux	+∞	30%
C	100%	30min	100Lux	+∞	10%
D	100%	30min	200Lux	+∞	30%
E	100%	30min	400Lux	+∞	50%
F	100%	5s	100Lux	10s	10%

Wiring Diagram



Detection Pattern




Additional Information / Documents

1. Regarding precautions for microwave sensor installation and operation, please kindly refer to www.hytronik.com/download->knowledge->Microwave Sensors – Precautions for Product Installation and Operation
2. Regarding Hytronik standard guarantee policy, please refer to www.hytronik.com/download->knowledge->Hytronik Standard Guarantee Policy

Subject to change without notice.
Edition: 26 Feb. 2020 Ver. A0

Documents / Resources

	<p>HYTRONIK HMW24 Stand-Alone HF Motion Sensor [pdf] Instruction Manual HMW24 Stand-Alone HF Motion Sensor, HMW24, Stand-Alone HF Motion Sensor, Motion Sensor, Sensor</p>
---	--

References

- [Catalogue_Hytronik](#)