



JohnPointR CT-600 Refrigeration Temperature Controller User Manual

[Home](#) » [JohnPointR](#) » JohnPointR CT-600 Refrigeration Temperature Controller User Manual 

Contents

- [1 JohnPoint CT-600 Refrigeration Temperature Controller](#)
- [2 Documents / Resources](#)
- [3 Related Posts](#)

JohnPoint®

JohnPoint CT-600 Refrigeration Temperature Controller



Product Information

- Product Name: JohnPoint R CT-600 Refrigeration Temperature Controller
- Manufacturer: CANNEX TECHNOLOGY INC.
- Year of Manufacture: 2020
- Customization: Customizable and production of controllers with suitable functions according to customer requirements.
- Country of Origin: Taiwan
- Website: <http://www.akr.com.tw>
- Contact Information:

- Tel: +886-4-861-3883 (Representative)
- Fax: +886-4882-8209
- Address: No.182, Sec.2, Yuanlu Rd., Sihua, Changhua, 51449,Taiwan

Product Usage Instructions

1. Ensure the CT-600 Refrigeration Temperature Controller is properly connected to the refrigeration system.
2. Power on the controller using the designated power source.
3. Set the desired temperature using the controller's interface or buttons.
4. Monitor the current temperature displayed on the controller's screen.
5. If necessary, adjust the temperature settings to maintain the desired refrigeration temperature.
6. Refer to the user manual for additional features and functions of the CT-600 controller.
7. In case of any issues or concerns, contact the manufacturer's representative via telephone or fax using the provided contact information.

Dimensions : 140(137) X 39(31.5) X 31 mm
Aperture : 137(±0.5) X 32(±0.5) mm



Please scan this QR Code
for the user manual.

- Temperature Setting : $-40^{\circ}\text{C} \sim +40^{\circ}\text{C}$
- Temperature Differential Setting: $1 \sim 9^{\circ}\text{C}$
- Operation Cycle: $1 \sim 24$ hours
- Defrost Cycle: $0 \sim 60$ points
- Temperature Calibration: $-10 \sim 10^{\circ}\text{C}$
- Locking Function: On / Off

Customizable and produced controllers with suitable functions according to customer requirements.

<http://www.akr.com.tw>

Tel : +886-4-861-3883(Rep) Fax : +886-4882-8209

Add : No.182,Sec.2,Yuanlu Rd.,Sihua,Changhua, 51449, Taiwan

Documents / Resources

	JohnPointR CT-600 Refrigeration Temperature Controller [pdf] User Manual CT-600 Refrigeration Temperature Controller, CT-600, Refrigeration Temperature Controller, Temperature Controller, Controller
--	--

