

# Kinetic Technologies KTS1693EVB Surge Protected Load Switch User Manual

[Home](#) » [Kinetic Technologies](#) » Kinetic Technologies KTS1693EVB Surge Protected Load Switch User Manual




## Contents

- [1 Kinetic Technologies KTS1693EVB Surge Protected Load Switch](#)
- [2 Recommended Operating Conditions](#)
- [3 Product Usage Instructions](#)
- [4 Brief Description](#)
- [5 Ordering Information](#)
- [6 EVAL Kit Physical Contents](#)
- [7 User-Supplied Equipment](#)
- [8 Typical Test Setup Diagram](#)
- [9 Electrical Schematic](#)
- [10 Additional Test Procedures](#)
- [11 Troubleshooting](#)
- [12 Documents / Resources](#)
  - [12.1 References](#)



Kinetic Technologies KTS1693EVB Surge Protected Load Switch



## Product Information

The KTS1693 Evaluation (EVAL) Kit is a surge-protected load switch with overvoltage protection (OVP) and overcurrent protection (OCP). It is used to demonstrate and evaluate the functionality, performance, and PCB layout of the KTS1693 IC. The kit includes a fully assembled and tested PCB with the KTS1693 IC installed, two pairs of high-current XT30-to-Banana power cables, and a printed copy of the Quick Start Guide.

## Ordering Information

- Part Number: KTS1693EVB-MMEV01
- Description: KTS1693 EVAL Kit
- IC Package: WLCSP-20

## EVAL Kit Physical Contents

Item #	Description	Quantity
1	KTS1693 EVAL fully assembled PCB	1
2	XT30-to-Banana power cables, red/black pair	2 pairs
3	Anti-static bag	1
4	Quick Start Guide, printed 1 page (A4 or US Letter)	1
5	EVAL Kit box	1

## Recommended Operating Conditions

Symbol	Description	Value	Units
VIN	Input Withstand Voltage	-0.3 to 28	V
VIO	Input Operating Voltage	2.8 to 5.7 (OVP)	V
IOUT	Output Load Current	0 to 6	A
IVDET	Output Current VDET	0 to 3	mA

Product Usage Instructions

1. Set Jumpers to default: EN = GND.
2. Connect one pair of XT30-to-Banana power cables to the XT30 connector at VIN and GND (left edge of EVAL Kit).
3. Before connecting the EVAL Kit to the VIN bench supply, turn on the supply and adjust the voltage as close to the recommended operating voltage as possible.

**Note:** Please refer to the Quick Start Guide for more detailed instructions and information on using the EVAL Kit.

EVAL Kit Manual  
KTS1693

Surge Protected Load Switch with OVP and OCP

Brief Description

The KTS1693 Evaluation (EVAL) Kit is used to demonstrate and evaluate the KTS1693 functionality, performance, and PCB layout. The kit includes a fully assembled and tested PCB with the KTS1693 IC installed, two pairs of high-current XT30-to-Banana power cables, and a printed copy of the Quick Start Guide (also contained within this document).

Ordering Information

Part Number	Description	IC Package
KTS1693EVB-MMEV01	KTS1693 EVAL Kit	WLCSP-20



3D CAD Image



## EVAL Kit Physical Contents

Item #	Description	Quantity
1	KTS1693 EVAL fully assembled PCB	1
2	XT30-to-Banana power cables, red/black pair	2 pairs
3	Anti-static bag	1
4	Quick Start Guide, printed 1 page (A4 or US Letter)	1
5	EVAL Kit box	1

## QR Links for Documents

IC Datasheet	EVAL Kit Landing Page
 <a href="https://www.kinet-ic.com/kts1693/">https://www.kinet-ic.com/kts1693/</a>	 <a href="https://www.kinet-ic.com/kts1693evb-mmeev01/">https://www.kinet-ic.com/kts1693evb-mmeev01/</a>

## User-Supplied Equipment

### Required Equipment

1. Bench Power Supply for VIN – 10V/30V and 0.5A/6A, as needed for the intended application. For testing over-voltage protection and withstand voltage, a 28V adjustable bench power supply is preferred.
2. Digital Multimeter – one or more, used to measure input/output voltages and currents.

### Optional Equipment

1. Bench Power Supply for VIO – 1.5V to 5V, low current. Needed for shutdown mode ( $\overline{EN} = VIO = \text{High}$ ) and power good monitoring ( $\overline{ACOK}$  pull-up voltage).
2. Oscilloscope – for dynamic testing of voltages (and currents with a current probe, if available).
3. Load – either an eLoad, power resistors, or an actual system load.
4. Additional Digital Multimeters

## Recommended Operating Conditions

Symbol	Description	Value	Units
VIN	Input Withstand Voltage	-0.3 to 28	V
	Input Operating Voltage	2.8 to 5.7 (OVP)	V
VIO	VIO Operating Voltage	1.5 to 5.5	V
IOUT	Output Load Current	0 to 6	A
IVDET	VDET Output Current	0 to 3	mA

## Jumper Descriptions


Designator	Name	Description	Default
P1	$\overline{\text{EN}}$	Active-Low Enable Input  VIO (High): Shutdown Mode – switch disabled  GND (Low): Enable Mode – normal switch operation	GND
P2	OC_MODE	OCP behavior select pin with internal pull-up 5M $\Omega$ .  VIO (High): Auto restart mode during over-current condition.  GND (Low): Over-current protection mode during over-current condition	GND

## Quick Start Procedures


1. Set Jumpers to default:  $\overline{\text{EN}}$  = GND
2. Connect one pair of XT30-to-Banana power cables to the XT30 connector at VIN and GND (left edge of EVAL Kit).
3. Before connecting the EVAL Kit to the VIN bench supply, turn on the supply and adjust the voltage as close to 0V as possible. Then turn off the supply. While off, connect the banana ends of the XT30-to-Banana power cables to the VIN bench supply.
4. Turn on the VIN bench supply and very slowly ramp its voltage to an appropriate voltage, such as 5V. While ramping VIN slowly, use the bench supply's output current indication (or a digital multimeter) to monitor the VIN current. If the current becomes high, reduce the VIN voltage quickly to prevent damage. Then inspect the setup for any wiring errors.
5. With valid VIN voltage such as 5V, use a digital multimeter to check the output voltage between the KVOUT and GND terminals on the EVAL Kit. It should be the same as the input voltage.
6. Use a digital multimeter to check the no-load supply current at VIN. Consult the KTS1693 datasheet for the expected current range at the VIN voltage condition in use. For conditions of VIN = 5V,  $\overline{\text{EN}}$  = GND, and no-load, it should be close to 160 A.

## Typical Test Setup Diagram

As an example, use the following test setup to measure items 5 and 6 in the Quick Start Procedures.



Electrical Schematic




Bill of Materials (BOM)

Item #	Quantity	Designator	Description	Value	Package	Manufacturer	Manufacturer Part Number	Digikey Part Number	Mouser Part Number
1	1	C1	CAP CER 10uF 50 V X5R 0805	10 uF	0805	Murata	GRM21BR61H106KE43L	490-18663-1-ND	81-GRM21BR61H106KE3L
2	1	C3	CAP CER 22uF 25 V X5R 0805	22 uF	0805	Murata	GRM21BR61E226ME44L	490-10749-1-ND	81-GRM21BR61E226ME4L



3	2	CN1, CN2	30A Right Angle Through Hole Power Connectors			AMASS	XT30PW-M		
4	4	H1, H2, H3, H4	BRD SPT SNAP LOCK REST MNT 4MM			Essentra Components	PSD-4M-19	PSD-4M-19-ND	144-PSD-4M-19
5	2	P1, P2	CONN HEADER VERT 3POS 2.54MM		TH	Sullins Connector Solutions	PREC003SAA-N-RC	S1012EC-03-ND	
6	1	R1	RES SMD 0603	NL	0603				
7	1	R2	RES 1K 1% 1/10W 0603	1K	0603	Yageo	RC0603FR-071KL	311-1.00K HRCT-ND	603-RC0603FR-071KL
8	1	R7	RES 2.0K 1% 1/10W 0603	2K	0603	Yageo	RC0603FR-072KL	311-2.00K HRCT-ND	603-RC0603FR-072KL
9	2	R8, R9	RES 47K 1% 1/10W 0603	47K	0603	Yageo	RC0603FR-0747KL	311-47.0K HRCT-ND	603-RC0603FR-0747KL
10	4	TP1, TP2, TP3, TP4	TERM TURRET SINGLE L=5.56MM TIN		TH	Keystone	1502-2	36-1502-2-ND	534-1502-2
11	3	TP5, TP11, TP13	PC TEST POINT MULTIPURPOSE RED		TH	Keystone	5010	36-5010-ND	534-5010
12	3	TP6, TP7, TP9	PC TEST POINT MULTIPURPOSE YELLOW		TH	Keystone	5014	36-5014-ND	534-5014
13	2	TP12, TP14	PC TEST POINT MULTIPURPOSE BLACK		TH	Keystone	5011	36-5011-ND	534-5011
14	1	U1	Surge Protected Load Switch with OVP and OCP		WLCS P45-20	Kinetic Technologies	KTS1693EVB-TR		389-KTS1693EVB-TR



## Additional Test Procedures

### 1. Logic Pins Testing:

- Before connecting the EVAL Kit to the VIO bench supply, turn on the supply and adjust the voltage as close to 0V as possible. Then turn off the supply. While off, connect the VIO bench supply to VIO and GND terminals on the EVAL Kit (with user-supplied banana-to-clip leads).
- Turn on the VIO bench supply and very slowly ramp its voltage to an appropriate voltage, such as 1.8, 3.3, or 5V. While ramping VIO slowly, use the bench supply's output current indication (or a digital multimeter) to monitor the VIO current. If the current becomes high, reduce the VIO voltage quickly to prevent damage. Then inspect the setup for any wiring errors.
- With valid VIO at 3V and VIN voltage at 5V, check the  $\overline{\text{EN}}$  and  $\overline{\text{AOK}}$  functionality.
- Check the shutdown supply current at VIN with  $\overline{\text{EN}} = \text{VIO}$ . The shutdown supply current should be around 1 $\mu\text{A}$  only.  $\overline{\text{AOK}}$  Power Good flag pin voltage should be close to VIO = 3V.



- With  $\overline{EN} = \text{GND}$ , check the  $\overline{ACOK}$  Power Good output pulls low to GND when  $V_{IN} > 2.8\text{V}$  (UVLO) and  $V_{IN} < 5.77\text{V}$  (OVLO).

## 2. Testing with Load:

- Use the second XT30-to-Banana power cable pair to apply loads between VOUT and GND.
- Under heavy-load conditions, use caution. The KTS1693 IC may become hot; avoid skin contact.
- Use multimeters and an oscilloscope to make DC and transient measurements as desired.

## 3. To check the KTS1693 OVP (over voltage protection) functionality:

- Slowly increase the power-supply voltage  $V_{IN}$  from 5V to 6V.
- Check that the output voltage VOUT drops to zero once the input voltage  $V_{IN}$  exceeds the Internal Overvoltage Trip level or 5.95V typical.

## 4. To check the KTS1693 OCP (over current protection) functionality:

- Slowly increase the E-load output current IOUT from 4.5A to 5.5A.
- Check that the output voltage VOUT drops to zero once the output current IOUT exceeds about 5.0A typical.

## 5. To measure the KTS1693 OVP/OCP switch on-resistance $R_{DS(ON)}$ :

- Measure the output current between the VOUT terminal and the load.
- Measure the voltage between the test points KVin and KVout (Kelvin connections).
- The switch resistance can be calculated with the formula:  $R_{DS(ON)} = (VK_{Vin} - VK_{Vout}) / I_{OUT}$ .

## Troubleshooting

Symptom	Root Cause	Solution
$\overline{ACOK}$ does not go high during faults.	VIO supply is off or not connected.	Connect and enable a VIO pull-up supply. $\overline{ACOK}$ has an Absolute Maximum Rating of 6 V.
$\overline{EN} = \text{VIO}$ does not disable the switch.	VIO supply is off or not connected.	Connect and enable a VIO pull-up supply. $\overline{EN}$ has an Absolute Maximum Rating of 6V.

## Important Notices

### Legal notice

Copyright © Kinetic Technologies. Other names, brands and trademarks are the property of others. Kinetic Technologies assumes no responsibility or liability for information contained in this document. Kinetic Technologies reserves the right to make corrections, modifications, enhancements, improvements, and other changes to its products and services at any time and to discontinue any product or services without notice. The information contained herein is believed to be accurate and reliable at the time of printing.

### Reference design policy

This document is provided as a design reference and Kinetic Technologies assumes no responsibility or liability for the information contained in this document. Kinetic Technologies reserves the right to make corrections, modifications, enhancements, improvements, and other changes to this reference design documentation without notice.

Reference designs are created using Kinetic Technologies' published specifications as well as the published specifications of other device manufacturers. This information may not be current at the time the reference design is built. Kinetic

Technologies and/or its licensors do not warrant the accuracy or completeness of the specifications or any information contained therein.

Kinetic Technologies does not warrant that the designs are production worthy. Customer should completely validate and test the design implementation to confirm the system functionality for the end use application. Kinetic Technologies provides its customers with limited product warranties, according to the standard Kinetic Technologies terms and conditions.

For the most current product information visit us at [www.kinet-ic.com](http://www.kinet-ic.com)

### Life support policy

LIFE SUPPORT: KINETIC TECHNOLOGIES' PRODUCTS ARE NOT DESIGNED, INTENDED, OR AUTHORIZED FOR USE AS COMPONENTS IN LIFE SUPPORT DEVICES OR SYSTEMS. NO WARRANTY, EXPRESS OR IMPLIED, IS MADE FOR THIS USE. AUTHORIZATION FOR SUCH USE SHALL NOT BE GIVEN BY KINETIC TECHNOLOGIES, AND THE PRODUCTS SHALL NOT BE USED IN SUCH DEVICES OR SYSTEMS, EXCEPT UPON THE WRITTEN APPROVAL OF THE PRESIDENT OF KINETIC TECHNOLOGIES FOLLOWING A DETERMINATION BY KINETIC TECHNOLOGIES THAT SUCH USE IS FEASIBLE. SUCH APPROVAL MAY BE WITHHELD FOR ANY OR NO REASON.

"Life support devices or systems" are devices or systems which (1) are intended for surgical implant into the human body,(2) support or sustain human life, or (3) monitor critical bodily functions including, but not limited to, cardiac, respirator, and neurological functions, and whose failure to perform can be reasonably expected to result in a significant bodily injury to the user. A "critical component" is any component of a life support device or system whose failure to perform can be reasonably expected to cause the failure of the life support device or system, or to affect its safety or effectiveness.


### SUBSTANCE COMPLIANCE

Kinetic Technologies IC products are compliant with RoHS, formally known as Directive 2002/95/EC of the European

Parliament and of the Council of 27 January 2003 on the restriction of the use of certain hazardous substances in electrical and electronic equipment. However, this evaluation kit does not fall within the scope of the EU directives regarding electromagnetic compatibility, restricted substances (RoHS), recycling (WEEE), FCC, CE or UL, and may not meet the requirements of these or related directives. To the best of our knowledge the information is true and correct as of the date of the original publication of the information. Kinetic Technologies bears no responsibility to update such statement.

2023 – EUM-0017-01 Page 7 of 7 Kinetic Technologies Confidential

### Documents / Resources

	<p><a href="#">Kinetic Technologies KTS1693EVb Surge Protected Load Switch</a> [pdf] User Manual KTS1693EVb Surge Protected Load Switch, KTS1693EVb, Surge Protected Load Switch, Protected Load Switch, Load Switch, Switch</p>
-------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

### References

- [Kinetic Technologies - Analog & Mixed-Signal Semiconductors](#)
- [KTS1693 Surge Protected Load Switch with OVP and OCP](#)
- [KTS1693EVb-MMEV01 - Kinetic Technologies](#)