



Knightsbridge MSENSOR Microwave Sensor Max Instruction Manual

[Home](#) » [Knightsbridge](#) » Knightsbridge MSENSOR Microwave Sensor Max Instruction Manual 

Contents

- [1 Knightsbridge MSENSOR Microwave Sensor Max](#)
- [2 GENERAL INSTRUCTIONS](#)
- [3 SAFETY](#)
- [4 INSTALLATION](#)
- [5 GENERAL](#)
- [6 WARRANTY](#)
- [7 Documents / Resources](#)
 - [7.1 References](#)
- [8 Related Posts](#)



Knightsbridge MSENSOR Microwave Sensor Max



GENERAL INSTRUCTIONS

These instructions should be read carefully and retained after installation by the end user for future reference and maintenance. These instructions should be used to aid installation of the following product: MSENSOR


SAFETY

- This product must be installed in accordance with the latest edition of the IEE Wiring Regulations (BS7671) and current Building Regulations. If in any doubt, consult a qualified electrician
- Please isolate mains prior to installation or maintenance
- Please note the IP (Ingress Protection) rating of this product when deciding the location for installation
- Do not overload this accessory or subject it to conditions outside its rating
- This product has a maximum load of 1000W Incandescent and 500W LED
- This product is IP20 rated
- This product should be installed in a luminaire or non-metallic enclosure

INSTALLATION

Note: Microwave sensors may not be suitable for all installations. for example – enclosed spaces, as they are able to detect movement through non-metallic surfaces like plasterboard and thin doors

- Provide power to the required point of installation
- Fix the sensor base to a suitable point in a luminaire or enclosure
- Connect the sensor to the luminaire and mains supply ensuring that correct polarity is observed L – Live (brown), L1 Load, N – Neutral (blue) (see Fig. 1)



- Turn all three sensor dials anti-clockwise to their minimum settings
- Turn on power supply and check for correct operation

WARNING

This product must be disconnected from the circuit if subjected to any high voltage or insulation resistance testing. Irreparable damage will occur if this instruction is not followed.

GENERAL

This product should be recycled in the correct manner when it reaches the end of its life. Check local authorities for where facilities exist. Clean with a soft dry cloth only, do not use aggressive cleaning products or solvents which may damage the product.

WARRANTY

This product has a warranty of 1 year from date of purchase. Failure to install this product in accordance with the current edition of the IEE Wiring Regulations (BS7671), improper use, or removal of the batch code will invalidate the warranty. If this product should fail within its warranty period, it should be returned to the place of purchase for a free-of-charge replacement. ML Accessories does not accept responsibility for any installation costs associated with the replacement product. Your statutory rights are not affected. ML Accessories reserve the right to alter product specification without prior notice.

ML Accessories Limited LU5 4LT www.mlaccessories.co.uk

Documents / Resources

	<p>Knightsbridge MSENSOR Microwave Sensor Max [pdf] Instruction Manual MSENSOR Microwave Sensor Max, MSENSOR, Microwave Sensor Max, Microwave Sensor, Sensor, Sensor Max</p>
---	---

References

- [ML Accessories](#)