

Labkotec D25201FE-3 SET OS2 Capacitive Level Probe Instruction Manual


[Home](#) » [Labkotec](#) » Labkotec D25201FE-3 SET OS2 Capacitive Level Probe Instruction Manual 



SET/OS2
Capacitive Sensor for Liquid Level Detection



Installation and Operation Instructions



SYMBOLS



Warning / Attention



Pay special attention to installations at explosive atmospheres

Contents

1 GENERAL

2 ADJUSTING THE SWITCHING POINT

3 SERVICE AND REPAIR

4 TECHNICAL DATA

5 Documents / Resources

GENERAL

SET/OS2 is a level detector for high level, low level and e.g. leak detection.

Typical applications are oil separators and grease traps where oil/water interface or water/air interface need to be detected.

The operational principle of the SET/OS2 sensor is capacitive and it can be connected to Labkotec SET-series control units.

SET/OS2 is an apparatus of equipment group II, category 1 G. The sensor can be installed in zone 0/1/2 hazardous area.




Fig. 1. SET/OS2 dimensions





Fig. 2. Application; pounding alarm

CONNECTIONS AND INSTALLATION

SET/OS2 is equipped with a shielded 3-wire cable. The wires 1 and 2 shall be connected to the corresponding connectors (1 = +, 2 = -) in the control unit. Wire 3 shall be connected to equipotential ground together with the shield of the cable. Please refer also to the installation instructions of the control unit.

The cable can be shortened or, when the control unit is located further away from the sensor, the cable can be extended with the junction box. The sensor can be installed to hang up in the air from the top of the tank to generate the high level alarm or immersed into the liquid to generate the low level or oil/water alarm.

 When installing the sensor into an explosion hazardous area (0/1/2), the following standards need to be followed; EN IEC 60079-25 Electrical apparatus for potentially explosive atmospheres – Intrinsically safe electrical system “i”, EN IEC 60079-14 Electrical apparatus for explosive gas atmospheres.

The sensor shall not be installed into a space where caustic vapour, gas or liquid, such as aromatic and chlorinated hydrocarbons or strong alkalis or acids, can damage the equipment.




Fig. 3. Wiring example

ADJUSTING THE SWITCHING POINT

1. Turn the SENSE trimmer of the control unit to the extreme clockwise position.
2. Immerse the sensor to the liquid to be measured. When 30-40 mm of the sensor is immersed in liquid, the control unit should operate. If it doesn't, adjust the SENSE trimmer slowly counter clockwise until the desired switching point is reached. As for conductive liquids (water etc.), the switching point should be achieved when 10-20 mm of the sensor is immersed.
3. Check the function by lifting and immersing the sensor few times into the liquid.

IF THE SENSOR DOES NOT WORK



If the sensor is located in a hazardous area an Exi-classified multimeter must be used and the Ex-standards mentioned in chapter 4. SERVICE AND REPAIR must be followed.

Make sure that the sensor is properly connected to the control unit. The voltage between connectors 1 and 2 in the control unit should be 10,5...12V.

If the voltage is correct, measure the sensor current as follows:

- Connect the ampere meter according to the picture below by disconnecting the conducting wire 1 from the central unit.
- Measure the current.




Fig. 4. Measuring the sensor current

Sensor current in different conditions:

Version O (Code = SE6311)	
clean and dry sensor in air	5...7 mA
sensor entirely in oil ($\epsilon_r \approx 2$)	9...11 mA
sensor entirely in water	12...16 mA
Version V (Code = SE6312)	
clean and dry sensor in air	5...6 mA
sensor entirely in water	12...16 mA

SERVICE AND REPAIR


The sensors must always be cleaned down and tested when emptying the tank or separator and when carrying out annual maintenance. For cleaning, a mild detergent (e.g. washing-up liquid) and scrubbing brush can be used.



Service, inspection and repair of Ex-apparatus needs to be done according to standards EN IEC 60079-17 and EN IEC 60079-19.

TECHNICAL DATA

SETOS2 sensor

Control units	Labkotec SET control units
Cable	Shielded, oil-proof instrumentation cable 3 x 0,5mm ² 0 5,7mm. Standard length is 5m. Can also be delivered according to the order with a maximum 15 m long cable. The cable can be extended with a similar instrumentation cable. The maximum pair resistance of the cable should not extend 75 Ω.
Temperature Operational Safety	-25 °C...1-60 °C -25 °C...1-60 °C
Materials	AISI 316, PVC
EMC Emission Immunity	EN IEC 61000-6-3 EN IEC 61000-6-2
IP-classification Sensor Junction box	IP68 IP67
Ex-luokitus ATEX Special conditions (X)	 II 1 G Ex is IIA T5 Ga VTT 03 ATEX 009X Ta = -25 °C...4-60 °C The sensor cable can be extended with the junction box type LJB3-78-83 or LJB2-78-83.
Ex-connection values	Ui = 18 V I = 66 mA Pi = 297 mW Ci = 3 nF Li = 30 pH UN= 9...18 V
Operating principle	Capacitive
Manufacturing year: Please see the serial number on the type plate	xxx x xxxxx xx YY x where YY = manufacturing year (e.g. 19 = 2019)

EU DECLARATION OF CONFORMITY

We hereby declare that the product named below has been designed to comply with the relevant requirements of the referenced directives and standards.

Product Level sensor SEVOS2, SEVOSK2

Manufacturer

Labkotec Oy Myllyhaantie 6 FI-33960 Pirkkala
Finland

Directives

The product is in accordance with the following EU Directives:

2014/30/EU Electromagnetic Compatibility Directive (EMC)

2014/34/EU Equipment for Potentially Explosive Atmospheres Directive (ATEX)

2011/65/EU Restriction of Hazardous Substances Directive (RoHS)

Standards

The following standards were applied:

EMC: EN IEC 61000-6-2:2019 EN IEC 61000-6-3:2021

ATEX: EN IEC 60079-0:2018 EN 60079-11:2012

EC-type examination certificate: VTT 03 ATEX 009X.

Notified Body: VTT Expert Services Ltd, Notified Body number 0537.

The revised harmonised standards have been compared to the previous standard versions used in the original type certification and no changes in the “state of the art” apply to the equipment.


RoHS: EN IEC 63000:2018

The product is CE-marked since 2003.

Signature


This declaration of conformity is issued under the sole responsibility of the manufacturer. Signed for and on behalf of Labkotec Oy.

Pirkkala 4.8.2021


Janne Uusinoka, CEO
Labkotec Oy

Labkotec Oy
Myllyhaantie 6
FI-33960 PIRKKALA
FINLAND
Tel: 029 006 260
Fax: 029 006 1260
Internet: www.labkotec.fi

Documents / Resources

	<p>Labkotec D25201FE-3 SET OS2 Capacitive Level Probe [pdf] Instruction Manual D25201FE-3 SET OS2 Capacitive Level Probe, D25201FE-3, SET OS2 Capacitive Level Probe , OS2 Capacitive Level Probe, Capacitive Level Probe, Level Probe</p>
---	---