LEVITON GSCM1-3C Self Test Cord Set





LEVITON GSCM1-3C Self Test Cord Set Instruction Manual

Home » Leviton » LEVITON GSCM1-3C Self Test Cord Set Instruction Manual

Contents

- 1 LEVITON GSCM1-3C Self Test Cord Set
- **2 OVERVIEW**
- **3 Technical Information**
- **4 Specifications**
- **5 SPECIFICATION SUBMITTAL**
- **6 Product Usage Instructions**
- 7 FAQ
- 8 Documents / Resources
 - 8.1 References



LEVITON GSCM1-3C Self Test Cord Set



OVERVIEW

UPC Code: 078477471135Country Of Origin: China

Self-Test Cord Set GFCI, 15 Amp, 120 Volt, 3 Foot, Manual Reset 15 Amp, 120 VAC, Self-Test Manual Reset GFCI Cord Set, 3 Foot, 12-3 SJTW Cord, Molded on NEMA Plug 5266-CY (5-15P) and Connector 5269-CY (5-15R), Yellow

- Satisfies latest UL 943 self-test requirement
- Improve safety protect critical personnel from electrical shocks Withstand outdoor conditions rainproof and outdoor rated devices are OSHA compliant and feature weather-resistant SJTW cables
- Ideal for vending machines, construction sites, RV parks, marinas, and spas/hot tubs
- Automatic reset automatically restores power to connected equipment when plugged in or after power interruption, ideal for hard-to-access locations

Technical Information

AC Horsepower Ratings

At Rated Voltage: 3/4 Horsepower

Electrical Specifications

• Amperage: 15 A

• Current Interrupting: 2 kA

· Grounding: GFCI Ground Fault

• Pole: 2

• Short Circuit Current Rating: 2kA

• Temperature Rise: Max 30C after 50 cycles OL at 150 per cent rated current

• Trip Level: 5mA plus or minus 1mA

• Voltage: 120 VAC

• Wire: 3

Environmental Specifications

• Flammability: Rated V-2 per UL94

• Operating Temperature: -35C to +66C

Material Specifications

• Blades/Contacts: Brass

• Body Material: Polycarbonate

Specifications

UPC Code: 078477471135Country Of Origin: China

• Model: GSCM1-3C

• Type: Self-Test Cord Set GFCI

Amperage: 15 AmpVoltage: 120 VoltCord Length: 3 Foot

9

• Reset Type: Manual Reset

· Colour: Yellow

Mechanical Specifications

• Cord Length: 3 FT.

• Cord Type: 12-3 SJTW Yellow

Product ID: Ratings marked on device label

• Terminal ID: Brass-Hot, Green-Ground, Silver-Neutral

Product Features

• Colour: Yellow

Standards and Certifications

• ANSI: C-73

CSA: C22.2 No.42 & No. 144
CSA C22.2: File LR-57811

• **NEMA**: WD-6

• NOM: 057

UL 498: File E-48380UL 943: Class A (GFCI)Warranty: 2-Year Limited

Patents

- MX265718
 - US7436639
- MX344697
 - US9276393

SPECIFICATION SUBMITTAL

Leviton Manufacturing Co., Inc.

201 North Service Road, Melville, NY 11747 Telephone: +1-800-323-8920 · FAX: +1-800-832-9538 · Tech Line (8:30 AM-7:30 PM E.S.T. Monday-Friday): +1-800-824-3005

Leviton Manufacturing of Canada, Ltd.

165 Hymus Boulevard, Pointe Claire, Quebec H9R 1E9 · Telephone: +1-800-469-7890 · FAX: +1-800-824-3005 · www.leviton.com/canada

Leviton S. de R.L. de C.V.

Lago Tana 43, Mexico DF, Mexico CP 11290 · Tel.: (+52)55-5082-1040 · FAX: (+52)5386- 1797 · www.leviton.com.wx Visit our Website at: www.leviton.com © 2021 Leviton Manufacturing Co., Inc. All Rights Reserved. Subject to change without notice.

Leviton has a global presence.

If you would like to know where your local Leviton office is located please go to: www.leviton.com/international/contacts/

This list is provided for patent marking purposes only. A good faith effort is made to maintain the accuracy and completeness of this list. No legal inference should be drawn from the omission of a patent from this list.

Product Usage Instructions

Safety Precautions

Before using the GFCI Cord Set, read and understand all safety instructions provided in the manual.

Initial Setup

Ensure the power source is turned off before plugging in the cord set. Connect the NEMA plug to the power outlet and the connector to your device.

Self-Test Feature

The GFCI Cord Set features a self-test function. Press the test button periodically to ensure the proper functioning of the GFCI.

Manual Reset

In case of power interruption or tripping, manually reset the GFCI by pressing the reset button on the cord set.

Ideal for Hard-to-Access Locations

This cord set is designed for use in hard-to-access locations, making it convenient for various applications.

FAQ

Q: How often should I perform the self-test on the GFCI Cord Set?

A: It is recommended to perform the self-test regularly, such as monthly, to ensure the proper functioning of the GFCI.

Q: What should I do if the GFCI trips?

A: If the GFCI trips, first unplug all devices connected to it, then press the reset button to reset the GFCI.

Q: Can the GFCI Cord Set be used outdoors?

A: The GFCI Cord Set is suitable for outdoor use, but make sure it is protected from direct exposure to water or harsh weather conditions.

Documents / Resources



<u>LEVITON GSCM1-3C Self Test Cord Set</u> [pdf] Instruction Manual GSCM1-3C Self Test Cord Set, GSCM1-3C, Self Test Cord Set, Test Cord Set, Cord Set, Set

References

- <u>O Leviton | Switches, Dimmers, Outlets & Lighting Controls</u>
- User Manual

Manuals+, Privacy Policy

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.