


LUMINO V36S Optic IP64 Optical Light Display Installation Guide

[Home](#) » [LUMINO](#) » LUMINO V36S Optic IP64 Optical Light Display Installation Guide 

LUMINO

V36S OPTIC IP64
INSTALLATION MANUAL
IMV36S_OPTIC_IP64_R2102

Contents

- [1 HANDLING PRECAUTIONS](#)
- [2 SAFETY GUIDANCE](#)
- [3 DRIVERS](#)
- [4 ACCESSORIES](#)
- [5 CHECK FIRST!](#)
- [6 INSTALLATION](#)
- [7 EASY MOUNT
INSTALLATION](#)
- [8 ROTATION MOUNT](#)
- [9 Documents / Resources](#)
- [10 Related Posts](#)



HANDLING PRECAUTIONS

PLASTIC COVER / DIFFUSER

To avoid permanent damage, do not allow small or sharp objects to apply pressure on to the plastic cover / diffuser.

IMPACT PROTECTION

The product is not vandal resistant. Never stand or place weighted items on the product. This product has a maximum IK rating of IK08. **POWER CABLES** The product end caps, power cables and connectors must not be pulled or twisted. Never pull the product by its power cables or hang it from its power cables or connectors.

CUTTING AND SAWING

The product must not be sawn, drilled or otherwise modified in any way.

DAMAGES Inspect the product. If you see any damage upon unpacking, report to LUMINO immediately and do not install the product.

LOCATION Suitable for damp locations. IP64 rated product is dust tight and protected against water splashes. Protect product from dust, paint and harmful substances during installation and use. Ensure product is not exposed to VOC gases. Do not obstruct the product and its light output.



SAFETY GUIDANCE

WIRING GUIDE

Follow the guidance shown in the provided wiring guide, including maximum cable lengths, cable sizes and other wiring instructions. When running cables through an enclosure, ensure cables are protected from damage, separated from mains voltage cables and anchored against being pulled. Make connections appropriate for the IP rating of the product.

QUALIFIED INSTALLER

Installation must be carried out by a qualified person and conducted in accordance with local regulations and applicable standards.

THERMAL MANAGEMENT

Ensure ambient temperature (T_a) does not exceed 40°C (104°F) and case temperature (T_c) does not exceed 70°C (158°F). Exceeding maximum T_c will cause permanent damage and void the product warranty. Allow sufficient clear air space for the LED drivers, as well as suitable access to the drivers as specified on installation instructions.

REPAIR AND REPLACEMENT

If the product is not functioning, contact LUMINO to register a Service Call for factory repair or replacement. Light source is not user replaceable. See page 5 for Ecodesign and end of life information.



DRIVERS

POWER OFF

Product and driver must not be live wired. Switch off power before work begins. Follow instructions and guidance for the make and model of driver being used.

CONSTANT CURRENT DC

Ensure supply current does not exceed 350mA or 500mA (see product label). Drivers must be constant current type with both overload and short-circuit protection. Exceeding the stated voltage or current will cause permanent damage and void the product warranty.

DIMMERS

Check dimmer is compatible with the driver and certified to local regulations.

INRUSH CURRENT

Many LED drivers can have high inrush current at power-on. Driver inrush current can be many times the normal operating current. Use a suitable MCB. Type C MCBs are normally suitable but if inrush current is a persistent

problem an inrush suppressor may be required.





PROTECTION

Use only with constant current Class 2 power unit to UL1310 standard with overload and short-circuit protection. Rate drivers for at least 10% above load. Driver protection circuitry must not be relied upon to protect secondary electrical circuits from damage caused by over-voltage or short circuit. DC fuses or DC electronic circuit breakers are recommended for full protection. Allow for access to drivers for maintenance and sufficient clear air space for ventilation.

CABLING


Do not overload the driver. Damage will be caused by incorrect input voltage, reverse polarity or short circuit. Plan for loads, driver locations, dimming and cabling prior to start of work. Ensure basic insulation is maintained between mains and dimming control wires.

ACCESSORIES


IDC Connector VECA-CA90 -R1 Sealant connector. 1 – 3A Max / 3 – 5A Max. Pair		Stealth Mount V36S-MS501-R1 Hidden fixing clip Allow 3 clips per metre	
Easy Mount V36S-MS402-R1 Mounting clips 1 pair per luminaire		Rotation Mount V36S-MS601-R1 Rotation mount Allow 2 clips per metre	

CHECK FIRST!

TURN OFF POWER! COUPER LE COURANT! STROM ABSHALTEN! CORTE CORRIENTE!



CHECK THE WALL!
VÉRIFIER LE MUR!
DIE WAND ÜBERPRÜFEN!
COMPRUEBE LA PARED!



INSTALLATION


1. Plan Installation

Check product and its dimensions against the planned installation. Runs of LEDs may have to be installed in a particular sequence.

305 / 600 / 900 / 1190mm length



~1714g per metre




2. Prepare Power Supply

This product requires a 350mA or 500mA (see product label) constant current power supply. Please refer to the provided wiring guide document. Failure to follow guide may result in damage to the product and voiding of warranty.



3. Cable Exit

Plan cable entry and exit points before installing the product. Make a suitably sized hole for the cable/s to pass through, and position beneath where the product is planned to be placed.



4. Mounting Clips

Fix all the clips securely to the mounting surface. Recommended screw size is no greater than Ø4.00mm in


diameter. Use fixings suitable for the material being fixed into.

Products should be held with equally spaced clips (see accessories for quantity per metre).

Products shorter than 505mm may be held by just 2 clips. There must always be a clip within 100mm to 200mm of each end of the product.

5. Connect to LED Driver

With the power off. Feed the power cables to the V36S, connecting the product to the LED driver. Finalise all electrical connections and test the circuit. If the product does not function as expected, turn power off immediately and check all connections.




- ◆ Local regulations must be observed.
- ◆ Do not exceed current rating on product label.
- ◆ Do not hot-wire the luminaire.
- ◆ Connection must be IP rated!

Please refer to provided wiring guide document. Failure to follow the provided guide may result in damage to the product and voiding of warranty.

6. Mount Product

Align clips and carefully push the product into the clips. Ensure the product is fully clipped in place and check it is not misaligned or misplaced due to screw heads or wires. Ensure that cables are not pinched when installed.




For further help regarding installation visit lumino.lighting

EASY MOUNT INSTALLATION

V36S-MS402-R1

1. Plan Out Installation


Easy mount fixing orientation should be installed as shown.




2. Measure and Drill Holes

Plan fixing hole positions, drill pilot holes and cable entry/exit holes as required.

Make a suitably sized hole for the cable/s to pass through, and position beneath where the product is planned to be placed.




Easy mounts spaced 50mm from each end of the luminaire.




3. Fix to Mounting Surface

Fix the easy mount to the fixing surface using a screw fixing appropriate for the mounting surface. Use a screw no bigger than Ø5mm. Allow for easy mount to have some movement.




4. Install V36S

Fit V36S to the easy mounts, making sure not to pinch cables when installing.




5. Close Latch

Secure V36S to the easy mounts by closing the latch. Check that mounting is secure.



Removing V36S

To remove, use a plastic pry tool. Following steps 4 and 5 in reverse.




For further help regarding installation visit lumino.lighting

ROTATION MOUNT

INSTALLATION V36S-MS601-R1


1. Mount Positions

Adjust positions of the mounts against the V36S profile by spacing the mounts out as shown in the diagram, then tighten screws using the provided Allen key.




2. Mount the V36S

Fix the V36S to the mounting surface using a screw fixing appropriate for the mounting surface.



3. Adjust

Adjust the V36S to the desired position and lock of the angle of adjustment using the provided Allen key. Ensure that all adjustment screws are tightened.



ECODESIGN REGULATION

This product is considered to be a “containing product” in the sense of Regulations (EU) 2019/2020 and (EU) 2019/2015.

The contained light source is an integrated part of the containing product and its removal can only be done by causing permanent damage to the containing product.

Therefore, replacement of the light source with the use of commonly available tools is not justified due to its restricted mechanical, electrical, optical, thermal and/or environmental protection requirements.



DISMANTLING

Dismantling of light source from the containing product at end of life:

The containing product shall be cut to the length of the contained light source and the light source mechanically detached from the containing product.

Containing product component parts shall then be disassembled.

Containing products shall be separated from building material and/or from other additional mounting accessories by means of a professional installer.

Separate control gear and light sources must be disposed of at certified disposal companies in accordance with Directive 2012/19/EU (WEEE) in the EU and with Waste Electrical and Electronic Equipment (WEEE) Regulations 2013 in the UK.

LUMINO is a member of the WEEE producer compliance scheme.

Registration number: WEE/MM8138AA


ENERGY RATING

This product contains light sources of energy efficiency classes as shown:


LED	CCT	60W/m
ColorCORE	4000K	F
	3500K	F
	3000K	F
	2700K	F


CONSTANT CURRENT WIRING GUIDE

LED Driver Wiring



Wiring Diagram



 Cable lengths are based on average resistance for typical copper cables. Cable characteristics may vary according to manufacturer, temperature, copper purity, connections etc.

MAX CABLE DISTANCE*

			DRIVE	0.3m m ²	0.5m m ²	0.75m m ²	1.0m m ²	16AWG	2.5m m ²
LED LENGTH	VOLTAGE	WATTAGE	CURRENT	22AWG	20AWG	18AWG	17AWG	1.5m m ²	14AWG
0.3m / 1ft to 2.1m / 7ft	36V	12.6W	350mA	16m	25m	40m	40m	40m	40m
	252V	88.2W		52ft	82ft	131ft	131ft	131ft	131ft
0.3m / 1ft to 2.1m / 7ft	36V	18W	500mA	11m	18m	29m	36m	40m	40m
	252V	126W		36ft	59ft	95ft	118ft	131ft	131ft

*Observe maximum cable lengths – as shown above or as specified by the driver manufacturer, whichever is the

shortest. Longer cable lengths increase EMI susceptibility.

MAX WATTAGE

LED LENGTH	VOLTAGE	350mA	500mA
0.3m / 1ft	36V	12.6W	18W
0.6m / 2ft	72V	25.2W	36W
0.9m / 3ft	108V	37.8W	54W
1.2m / 4ft	144V	50.4W	72W
1.5m / 5ft	180V	63W	90W
1.8m / 6ft	216V	75.6W	108W
2.1m / 7ft	252V	88.2W	126W

For further help regarding installation visit lumino.lighting

Use appropriate constant current LED drivers (350mA or 500mA, see product specification) with overload and short-circuit protection. Use reputable driver manufacturers with appropriate standards for the local requirements. USA & Canada: Use only with Class 2 power unit to UL1310 standard. Use only with maximum output 350mA or 500mA (see product specification) Class 2 power unit.

IM-Constant_Current_CC_R2103



Maximum cable lengths shown above are calculated for voltage drop and do not consider EMI. Long cables can potentially emit EMI. Do not exceed the maximum cable length stated by the driver manufacturer. Installers must ensure EMI emissions do not exceed local regulated limits.

Shielded cables and ferrite coils can be used where applicable.

Installers must ensure voltage drop does not exceed 2%.

Ensure LED driver is disconnected from mains before making any connections.

Polarity is critical and must be observed when making connections.

Constant current LED circuits must be wired in series. Parallel wiring will not correctly power the LEDs and can potentially cause damage.

Live loading or incorrect polarity connections of LEDs will cause damage and void the warranty.

Constant current LEDs can have high forward voltages at power-on. LED forward voltage can be significantly higher than the normal operating voltage of the circuit. Colder temperatures will also increase the forward voltage required to power up the LEDs.

Constant Current LED drivers can also have high inrush current at power-on. Driver inrush current can be many times the normal operating current. Use a suitable MCB. Type C MCBs are normally suitable but if inrush current is a persistent problem an inrush suppressor may be required.

- Installation must be carried out by qualified electrician.
- Electrical work to be conducted in accordance with local regulations.
- Power must be disconnected prior to installation work.
- Ensure free-moving air space around LEDs and drivers.
- Protect the LEDs from dust and paint during installation and use.

- Plan for loads, driver locations, cables sizes etc prior to installation.
- Shielded control pair required for dimming signal wires.
- Incorrect current/voltage, reverse polarity or short circuit will cause damage.

TECHNICAL SUPPORT
+44(0) 1279 635 411
www.lumino.lighting
LUMINO DISTRIBUTION LTD
Lumino House, Lovet Road
Harlow, Essex CM19 5TB
United Kingdom

Installers must read this document and any other referenced documents in full before commencing installation work.

Failure to observe all installation guidance in this document may result in unsafe installation, cause permanent product damage and void product warranty.


This document is subject to change without notice.

Check for latest documentation with LUMINO.

Copyright © LUMINO. E&OE



Documents / Resources

	<p>LUMINO V36S Optic IP64 Optical Light Display [pdf] Installation Guide V36S Optic IP64, Optical Light Display, V36S Optic IP64 Optical Light Display, Light Display</p>
---	--