

LUTRON QSWS2-2RLDI-SW-E01 Dual 2 Button With Raise Instructions

Contents

- [1 LUTRON QSWS2-2RLDI-SW-E01 Dual 2 Button With Raise](#)
- [2 Product Information](#)
- [3 Specifications](#)
- [4 Product Usage Instructions](#)
- [5 FAQs](#)
- [6 USING A WIRED KEYPAD](#)
- [7 OVERVIEW](#)
- [8 Documents / Resources](#)
 - [8.1 References](#)
- [9 Related Posts](#)



LUTRON QSWS2-2RLDI-SW-E01 Dual 2 Button With Raise

Product Information

The Lutron Shade Keypad is designed to work with Sivoia QS / Palladium Wired shades to allow users to set limits for their window treatments conveniently.

Specifications

- **Compatibility:** Sivoia QS / Palladium Wired shades
- **Function:** Setting limits for window treatments
- **Connection:** Wired to shading power panel

Product Usage Instructions

1. Press and hold Open and Raise simultaneously for 5 seconds.
 2. Tapping Open selects the next window treatment, Close selects the previous window treatment.
 3. Hold Raise or Lower to adjust the window treatment \position.
 4. Press and hold Open for 5 seconds to store the open limit, or Close for 5 seconds to store the close limit.
 5. Press and hold Open and Raise simultaneously for 5 seconds to exit the setting mode.
- **(Blackout Shade)** – Use these buttons for setting limits using the keypad.

- **(Solar Shade)** – Use these buttons for setting limits using the keypad.

FAQs

- **Q: What should I do if the limits are not being set correctly?**
 - A: Make sure the shades are properly wired to the shading power panel and that the keypad is functioning correctly. Repeat the limit-setting process carefully.
- **Q: Can I set different limits for each window treatment?**
 - A: Yes, you can set individual limits for each window treatment by following the same process for each shade.


USING A WIRED KEYPAD

Setting Limits on Sivoia QS / Palladium Wired shades using a wired keypad


This procedure is used when you have Sivoia QS shades wired for power and communication back to a shading power panel. When you have keypads also wired to this panel, you can manually set limits from these keypads. This is particularly helpful in scenarios where shades are hard to physically reach or accessing the shade drive buttons is inconvenient.

Setting limits from a Keypad:


1. Press and hold Open and Raise simultaneously for 5 seconds




2. Tapping Open selects the next window treatment, Close selects the next window treatment




3. Hold Raise or Lower to adjust the window treatment position





Documents / Resources

	<p>LUTRON QSW2-2RLDI-SW-E01 Dual 2 Button With Raise [pdf] Instructions QSW2-2RLDI-SW-E01 Dual 2 Button With Raise, QSW2-2RLDI-SW-E01, Dual 2 Button With Raise, Button With Raise</p>
---	--

References

- [User Manual](#)

[Manuals+](#), [Privacy Policy](#)

This website is an independent publication and is neither affiliated with nor endorsed by any of the trademark owners. The "Bluetooth®" word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. The "Wi-Fi®" word mark and logos are registered trademarks owned by the Wi-Fi Alliance. Any use of these marks on this website does not imply any affiliation with or endorsement.