




JYT18503






**⚡ ⚠ DANGER**




**HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH**

- Turn off all power supplying this device before working on it.
  - Use a voltage tester with a suitable rated voltage in order to check that all active conductors aren't energized.
  - Carefully inspect the work area to check that no tools or objects could have been left inside the equipment.
- Failure to follow these instructions will result in death or serious injury.**

**1 Unboxing**



Commercial Reference		
	Neutral Cable	Phase Cable
EZ9CCUCABLEKITMR	1	1



Commercial Reference	Cable Kit Qty
EZ9E212MCCU	1
EZ9E312MCCU	2

**Note:**

- Cable kit is flexible to support position of Incomer Switch on Left or Right.
- For three-row consumer unit, it is recommended to use Terminal Block to connect the cable from second row to third row.