

EcoNet Controls Troubleshooting Document

Date: March 18 2022 Applies to EVC200 ZWave Controller

How do I unpair, then pair my ZWave (EVC200) Bulldog Controller?



Difficulty: Easy

Example: The device LED is solid green light indicating it has been paired with a controller, is there a way to factory reset the device then pair to a new controller?

Unpairing:

- You should exclude the Bulldog Valve Controller in the ZWave hub/controller's software by following the steps for your specific ZWave hub/controller for exluding the device and then pressing the EVC200 button 3-5 times quickly.
- If this isn't possible you can perform a system reset on your ZWave bulldog controller by holding down the controller button for over 10 seconds. You will see the LED quickly blip when done.

Pairing:

- Set your ZWave Controller to scan for ZWave devices or Specify the EcoNet Valve Robot if this option is present.
- Set your controller to pair to your new hub by pressing the button on the controller repeatedly as fast as you can 3-5 times. This can take a minute depending on the ZWave Controller