


# Waterdrop

## X Series Reverse Osmosis Water Filtration System

**MODEL:** WD-X8/WD-X8-WAN/WD-X10/WD-X10-WAN



System Certified by IAPMO R&T against NSF/ANSI Standard 42&58 for the reduction of the claims specified on the Performance Data Sheet, and to NSF/ANSI 372 for low lead.

### Performance Data Sheet

Model	Substance	NSF Specified challenge concentration	Max permissible product water concentration	NSF reduction requirements	test result
WD-X8/WD-X8-WAN	TDS	750±40 mg/L	187 mg/L	≥75%	96.79%
WD-X10/WD-X10-WAN	TDS	750±40 mg/L	187 mg/L	≥75%	94.38%
WD-X8/WD-X8-WAN	Chlorine Taste and Odor	2.0±0.2 mg/L	/	≥50%	98.82%
WD-X10/WD-X10-WAN	Chlorine Taste and Odor	2.0±0.2 mg/L	/	≥50%	98.82%

This system has been tested according to NSF/ANSI 42&58 for reduction of the substances listed below. The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system, as specified in NSF/ANSI 42&58.

### Manufacturer Technical Support

Tel: 1-888-352-3558 (U.S.)  
E-mail: [service@waterdropfilter.com](mailto:service@waterdropfilter.com)



Made in China P001  
Qingdao Ecopure Filter Co., Ltd.

