



INSTALLATION INSTRUCTIONS

“N” Series Electric Heat Kits for Aspen Multi-Position Air Handlers

▲ WARNING

Disconnect ALL power before servicing or installing this unit. Multiple power sources may be present. Failure to do so may cause property damage, personal injury, or death.

The unit is designed for operation with 208/240 V, single phase, 60 Hz power supply. Aspen will not be responsible for damages caused due to modification of the unit to operate with alternative power sources.

This product designed and manufactured to permit installation in accordance with local and national building codes. It is the installer’s responsibility to ensure that product is installed in strict compliance with national and local codes. Manufacturer takes no responsibility for damage (personal, product or property) caused due to installations violating regulations. Installation of this unit shall be made in accordance with the National Electric Code, NFPA No. 90A and 90B, and any other local codes or utilities requirements.

Do not bypass safety devices.

Electric Heat Kits

Kit #		Description	Kit #		Description	Model used
W/ Terminal Block	NTS03	3KW Heat Strip w/ Terminal Block	W/ Circuit Breaker	NCS03	3KW Heat Strip w/ Circuit Breaker	LEM24A-E
	NTS05	5KW Heat Strip w/ Terminal Block		NCS05	5KW Heat Strip w/ Circuit Breaker	
	NTS08	8KW Heat Strip w/ Terminal Block		NCS08	8KW Heat Strip w/ Circuit Breaker	
	NTS10	10KW Heat Strip w/ Terminal Block		NCS10	10KW Heat Strip w/ Circuit Breaker	
	NTM03	3KW Heat Strip w/ Terminal Block		NCM03	3KW Heat Strip w/ Circuit Breaker	LEM24F-J LEM36A-E
	NTM05	5KW Heat Strip w/ Terminal Block		NCM05	5KW Heat Strip w/ Circuit Breaker	
	NTM08	8KW Heat Strip w/ Terminal Block		NCM08	8KW Heat Strip w/ Circuit Breaker	
	NTM10	10KW Heat Strip w/ Terminal Block		NCM10	10KW Heat Strip w/ Circuit Breaker	
	NTM15	5KW Heat Strip w/ Terminal Block		NCM15	15KW Heat Strip w/ Circuit Breaker	LEM36F-J LEM48A-E LEM60A-E
	NTL03	3KW Heat Strip w/ Terminal Block		NCL03	3KW Heat Strip w/ Circuit Breaker	
	NTL05	5KW Heat Strip w/ Terminal Block		NCL05	5KW Heat Strip w/ Circuit Breaker	
	NTL08	8KW Heat Strip w/ Terminal Block		NCL08	8KW Heat Strip w/ Circuit Breaker	
	NTL10	10KW Heat Strip w/ Terminal Block		NCL10	10KW Heat Strip w/ Circuit Breaker	
	NTL15	15KW Heat Strip w/ Terminal Block		NCL15	15KW Heat Strip w/ Circuit Breaker	
	NTX03	3KW Heat Strip w/ Terminal Block		NCX03	3KW Heat Strip w/ Circuit Breaker	LEM48F-J LEM60F-J
	NTX05	5KW Heat Strip w/ Terminal Block		NCX05	5KW Heat Strip w/ Circuit Breaker	
	NTX08	8KW Heat Strip w/ Terminal Block		NCX08	8KW Heat Strip w/ Circuit Breaker	
	NTX10	10KW Heat Strip w/ Terminal Block		NCX10	10KW Heat Strip w/ Circuit Breaker	
	NTX15	15KW Heat Strip w/ Terminal Block		NCX15	15KW Heat Strip w/ Circuit Breaker	
	NTX20	20KW Heat Strip w/ Terminal Block		NCX20	20KW Heat Strip w/ Circuit Breaker	

- 1) Refer to Table 1 for appropriate kit
- 2) Check kit for physical damage, do not installed damaged kit
- 3) Remove the upper access panel from air handler
- 4) Unplug the Mate-n-Lock connector (FIG. 3) and Remove block-off plate or existing heater kit from air handler by removing 6 screws (See FIG. 2)
- 5) Slide the heater kit into the slot and secure element plate and to divider deck with the six previously removed screws
- 6) Insert power leads into the circuit breaker lugs or terminal block and tighten (FIG. 3)
- 7) Connect ground wire to ground lug (FIG. 3)
- 8) Plug in the Mate-N-Lock connector
- 9) Break out appropriate number of circuit breaker openings (if applicable) on the access panel of the air handler




FIG. 1




FIG. 2



FIG. 3


10) Find the nameplate of the air handler unit and cross out the existing configuration and check the new heat kit model configuration that was installed. Nameplate shown below is a sample only.




MODEL NO. : LEM48AJ-000-NCL10
SERIAL NO. : H24-00000001
VOLTS : 208 / 240
PH / HZ : 1 / 60

MOTOR HP : 1.00
MOTOR FLA : 7.600
TEST DUCT STATIC PRESS : 0.5 IN. W.C. (MAX)

REFRIGERANT : R454B
MAX ALLOWABLE PRESSURE : 550 PSIG / 4.462 MPa
FACTORY CHARGED NITROGEN : 150 PSIG / 1.034 MPa



CONFORMS TO UL
STD 60335-2-40
CERTIFIED TO CSA
STD C22.28236
CTLR 64786




MEMBER
AHRI
AIR HANDLING
INSTITUTE

HEATER KIT MODEL NO.	ELECTRIC HEAT RATED (KW)	ELECTRIC HEAT ACTUAL (KW)		TOTAL UNIT AMPS		MINIMUM CIRCUIT AMPACITY		MAX FUSE OR BREAKER (HACR) AMPACITY		MIN. HEATING BLOWER SPEED
		208V	240V	208V	240V	208V	240V	208V	240V	
NO ELEC. HEAT	0 <input type="checkbox"/>	0	0	7.6	7.6	9.5	9.5	15	15	NA
+NCL00 +NTL00	0 <input type="checkbox"/>	0	0	7.6	7.6	9.5	9.5	15	15	NA
+NCL03 +NTL03	3 <input type="checkbox"/>	2.3	3	18.4	20.1	23	25.1	25	30	T2
+NCL05 +NTL05	5 <input type="checkbox"/>	3.6	4.8	24.9	27.6	31.1	34.5	35	35	T2
+NCL06 +NTL06	6 <input type="checkbox"/>	4.5	6	29.2	32.6	36.5	40.8	40	45	T2
+NCL08 +NTL08	8 <input type="checkbox"/>	6	8	36.4	40.9	45.6	51.2	50	60	T3
+NCL10 +NTL10	10 <input checked="" type="checkbox"/>	7.2	9.6	42.2	47.6	52.8	59.5	60	60	T3
+NCL15 +NTL15	15 <input type="checkbox"/>	10.8	14.4	42.2/17.3	47.6/20	52.8/21.8	59.5/25	60/25	60/25	T3
+NCL20 +NTL20	20 <input type="checkbox"/>	14.4	19.2	42.2/34.6	47.6/40	52.8/43.3	59.5/50	60/45	60/50	T3

NOTE: RE-CHECK APPROPRIATE BOX ☐ FOR HEATER KIT CHANGES IN THE FIELD.
SUITABLE FOR 0 INCH CLEARANCE BETWEEN UNIT AND COMBUSTIBLE SURFACES AND 0 INCH CLEARANCE BETWEEN OUTLET PLENUM AND FIRST 3 FEET OF
OUTLET DUCT AND COMBUSTIBLE SURFACES WHEN HEATERS ARE INSTALLED. MAXIMUM OUTLET AIR TEMPERATURE NOT TO EXCEED 197°F

11) Find the wiring diagram label that is included in the heat kit and stick it near the nameplate. Wiring Diagram shown below is a sample only.



HOW TO REPLACE A DEFECTIVE THERMAL CUT OFF (TCO) OF A HEATER KIT:



Fig. 1 – TCO Image




Fig. 2 – Heater Kit w/ TCO

1. Disconnect power, unscrew and open upper access panels to access the heater kit from the unit.
2. Locate the TCO(s) and disconnect the 2 black wires per TCO. Using a multimeter, measure continuity/resistance of the fuse element by placing the test probes across the two terminals to verify if the fuse has failed. The quantity of TCO's depends on the heater kit model. The heater kit model shown in Figure 2 has two TCOs.
3. Unscrew the defective TCO from the base plate and using the same screw(s) mount the new one back in the same spot.
4. Re-connect all the wirings in the same terminals that you disconnect it from.
5. Mount the access panel back in the unit.



373 Atascocita Rd., Humble, TX 77396 • Phone: 281.441.6500 • Toll Free: 800.423.9007
•Fax: 282.441.6510

www.aspenmfg.com

Subject to change without notice and without incurring obligation.
© Copyright 2024 Aspen Manufacturing. All Rights Reserved