

Design Guideline

VRF Dx-coil Interface(DDC type) Design Guideline

CONTENTS

1.	Applica	ition	 1
2.	System	n compatibility, Overview	 1
3.	Operat	ing conditions	 1
4.	Pipe Si	 2	
5.	Pipe le	ngth and height difference	 2
6.	•	t Configuration	
	6.1.	Product Configuration	 2
	6.2.	Major Specifications	 3
	6.3.	Control Input / Output Details	 3
	6-4.	Analogue Input Control Details	 6
7.	AHU / I	DX COIL Design	
	7.1.	Equipment selection procedure -Selection flow chart-	 7
	7.2.	Correction charts for Outdoor unit capacity calculation	 8
	7.3.	How to select DX COIL Design Guideline	 9
	7.4.	DX COIL Guideline HP	 10
	7.5.	DX COIL Guideline CO Pattern A	 11
	7.6.	DX COIL Guideline CO Pattern B	 12
	7.7.	DX COIL Manufacturing	 13
	7.8.	DX Controller Installation	
	7.9.	Sensor Connections	
_	7.10.	Dx-valve KIT Installation	 15
8.		Outline	
	8.1.	Cautions regard with DDC's programing	
_	8.2.	Protection Function Summary	
9.		specifications	 18
10.		ce requirements for controller	
		Indoor(DX) P.C board(MCC-1570) function	 18
	10.2.	DDC(0-10V) interface P.C board(TX-TOS1413) Function	 20
11.	Function	n code (DN code)	 21
12.	Dx-coi	l Controller , Dx-valve kit Dimensions	 22
13.	Wiring	Diagram	 23
14.	Compa	atibility with R/C, BMS, Open network system	 24
15.	Check	Codes	 25
		d cautions	 26
	Warra		 26


1 Application

The VRF Dx-coil Interface(DDC type) enables BMS capacity demand control of Toshiba Outdoor units connected to a DX COIL (with a field supplied AHU). It is compatible with either a Toshiba VRF system.


Product	Model name	Capacity	HP
Dx-coil controller	TCB-IFDDC201E	B-IEDDC201E 22.4kW , 28.0kW , 45.0kW , 50.4kW , 56.0kW	
		90kW, 101kW, 112kW	32, 36, 40
Dx-valve kit	RBM-A101VAE	22.4kW , 28.0kW	8 , 10
	RBM-A201VAE	45.0kW , 50.4kW , 56.0kW	16 , 18 , 20

2 System compatibility, Overview

- · Outdoor Unit
 - SMMS-e Cooling Only Model (MMY-MAP***6T8*P* / MMY-MAP***6T7*P)
 - SMMS-7 Cooling Only Model (MMY-MAP***7T8*P* / MMY-MAP***7T7*P)
 - SMMS-e Heat Pump Model (MMY-MAP***6HT8*P* / MMY-MAP***6HT7*P*)
 - SMMS-u Heat Pump Model (MMY-MUP***1HT8*P* / MMY-MUP***1HT7*P*) *
 - SMMS∞ Cooling Only Model (MMY-MUP***1T8*P*/ MMY-MUP***1T7*P) *
 - *: Even if connected with SMMS,SMMS-u Heat Pump Model, the sysytem communication type will become "TCC-Link" according to Dx-coil controller(TCB-IFDTA201E, TCC-Link type).
- Diversity
 - 75% 100%
- Overview



3 Operating conditions



4 Pipe Size

·	Pipe diameter					
Outdoor Unit Capacity	Gas Pipe	Liquid Pipe	Liquid Pipe			
	Gas Fipe	Valve kit to AHU	Valve kit to Y-Joint			
8 HP	Ø 19.1 or 22,2	Ø 12.7				
10 HP	Ø 22.2	Ø 12.7				
16 HP	Ø 28.6	Ø 15.9	-			
18 HP	Ø 28.6	Ø 15.9				
20 HP	Ø 28.6	Ø 15.9				
32 HP	Ø 34.9	Ø 15.9	Ø 19.1			
More than 36HP	Ø 41.3(38.1%1)	Ø 15.9	Ø 22.2			

※ 1 Only SMMS-u, SMMS∞

5 Pipe length and height difference

Main pipe equi	valent length	Same as piping length restriction of VRF ODU		
Total piping ler	ngth (real length)	120 m (100 m)		
Furthest equiva	alent pipe length L (real length)	100m		
Furthest equiva	alent pipe length between outdoor unit	-		
Max. Height	outdoor unit - indoor unit(Upper outdoor unit)	40m		
Difference outdoor unit - indoor unit(Lower outdoor unit)				
Amount of Add	itional Refrigerant	Refer to specification of Outdoor unit		

6 Product Configuration

6.1 Product Configuration

DX COIL tyoe		Normal				
Туре		Dx-coil Controller	Dx-Valve kit			
Model Name		TCB- IFDDC201E	TCB- RBM- R			
	8HP	1	1	-		
	10HP	1	1	-		
	16HP	1	-	1		
Connectable	18HP	1	-	1		
Dx-coil	20HP	1	-	1		
Capacity	32HP	1	-	2		
	36HP	1	-	2		
	40HP	1	-	2		

TCB-IEDDC201E (Dy-coil Controller)

<u>1C</u>	TCB-IFDDC201E (Dx-coil Controller)										
De	scription		Dx-coil c	ontroller in M	etal Enclosu	re, comprisir	ng:-				
MCC-1570 (Main Indoor(DX) P.C. board)											
			TX-TOS1413 (DDC(0-10V) interface P.C. board)								
			· 24VA	24VAC Transformer							
			· TA Se	TA Sensor, Length: 2.5m, Connector colour: Yellow							
			· TC1 S	ensor, Lengt	th : 2.5m, Co	nnector cold	our : Brown				
			· TC2 S	ensor, Lengt	th : 2.5m, Co	nnector cold	our : Black				
			· TCJS	ensor, Lengt	th : 2.5m, Co	nnector colo	our : Red				
			 Strain 	ers							
Ext	ernal Din	nensions H x	WxD(mm)				420 x 3	30 x 95			
Net	t Weight(I	kg)	6.0 kg								
No	tes:										
Ca	pacity cod	de (DN11) ne	eeds to be se	tup upon ins	tallation usin	g wired rem	ote controller	(not supplie	d).		
	HP	8	10	16	18	20	32	36	40		
	DN[11]	21	23	26	27	28	35	37	39		
	· Only F	leating and (Cooling Mode	es are availa	ble on the T0	CB-IFDDC20	1E (No Auto	matic or Fan	Only).		
	Components supplied loose requires brazing and local pinguark										

· Components supplied loose, requires brazing and local pipework.

RBM-A101VAE / RBM-A201VAE (Dx-valve kit)

Description	The PMV(Pulse Motor Valve, 2 models), comprising:- • PMV body & PMV Motor		
	· Terminal Block		
RBM-A101VAE	8HP & 10HP Size		
RBM-A201VAE	16HP & 18HP & 20HP Size		

6.3 Control Input / Output Details

- Input functions -

Input	Name	Description						
A1 A2	Capacity Demand	Analogue Input to control Capacity demand. (Details in section 6.4).						
	Analog Input (DC 0 - 10 V)							
	SW3 bit-2(TX-TOS1413) OFF	STEPPED response to analogue input						
	SW3 bit-2(TX-TOS1413) <u>ON</u>	LINEAR response to analogue input						
	· To ease the integration of the	e Dx-coil with the DDC the capacity control is able to operate with a						
	STEPPED or LINEAR function	on from the analogue input.						
	· To select either a STEPPED	(default) or LINEAR response, from the analogue input, use						
	SW03 bit2 located on the DDC(0-10V) interface P.C. board(TX-TOS1413)							
C1 C2	External ON / OFF Input	Digital Input to control ON / OFF:-						
		· ON (Closed) / OFF (Open).						
		External ON/OFF input signal type(pulse / static) is selectable by						
		Jumper Wire J01 on the Indoor(DX) P.C. board - MCC-1570.						
		Connect (Default) : Pulse / Cut : Static						
		Note the unit will not operate until there is an appropriate 0-10V						
		Capacity Control signal.						
C3 C4	Demand Signal Input	When signal input, AHU is in "thermostat-off" status forcibly.						
C5 C6	Safety contact.	If this contact is open for more than 1 minute, the check code "P10" is						
		generated and the Dx-coil controller switches off automatically.						
C7 C8	Fan Motor Trouble Input	An AHU fan operation monitor (Field supply), could be attached at this						
		dry contact terminal(For example, the abnormality of the fan motor.).						
		A closed contact generates the check code "L30".						
C23 C24	Operation Mode Input	Digital Input to control Mode:-						
		· HEAT (Closed) / COOL (Open)						

Output functions -


- Output functions -								
Output	Name Description							
D1 D2	Fan Motor Digital Output	A fan control signal is output. It is usually the ON output at the time						
		of operating, but it is the OFF output in defrosting.						
D5 D6	Alarm Active Digital Output	During Alarn	During Alarm operation, Alarm Active Digital Output is active.					
D7 D8	Defrost Mode Digital Output	During Defro	ost operation, Defrost Mode Output is active.					
D19 D20	Thermostat On Digital Output	Thermostat	ON signal is output. It is usually the ON output at the					
		time of opera	ating.					
D31 D32	DO_1 Digital Output1	Output funct	tion set using rotary switch "SW1" on the DDC(0-10V)					
	(User Defined)	interface P.0	C board(TX-TOS1413)					
		SW1	Output function					
		0	lower than capacity demand					
		1	higher than capacity command					
		2	cooling oil recovery /heating refrigerant recovery					
		3	cooling output (operation+no error+cooling mode)					
		4	heating output (operation+no error+heating mode)					
		5	Thermostat ON					
		6∼F	No function (for future development)					
D33 D34	DO_2 Digital Output2	Output funct	tion set using rotary switch "SW2" on the DDC(0-10V)					
	(User Defined)	interface P.0	C board(TX-TOS1413)					
		SW2	Output function					
		0	lower than capacity demand					
		1	higher than capacity command					
		2	cooling oil recovery /heating refrigerant recovery					
		3	cooling output (operation+no error+cooling mode)					
		4	heating output (operation+no error+heating mode)					
		5	Thermostat ON					
		6∼F	No function (for future development)					


- Summary of Digital input / output function (MCC-1570) -

Connector	Pin	Function	Remarks	Standard / Option	Terminal blocks
CN32	1	COM (DC 12V)		 	
(WHI)	2	Output	Ventilation control (Refer to "APPLICATION CONTROL MANUAL")	Option	
CN12.4	1	Saftey Contact	Check code P10, Normal close		C5
CN34	2				
(RED)	3	Input (DC 12V)		Standard	C6
	1	COM (DC 12V)			D1 / D7
	2	Defrost mode Digital output	ON while outdoor unit defroseted	Standard	D8
CN60	3				
(WHI)	4				
(******)	5				
•	6	Fan motor active Digital output	ON while Fan on	Standard	D2
	0	Fail motor active Digital output	Start/Stop input, Input signal type (pulse / static) is	Standard	D2
	1	External ON/OFF Input, Input (DC 5V)	selectable by Jumper Wire J01	Standard	C1
01104	2	COM (0V) for pin 1, 3			C2
CN61	3				
(YEL)	4				
	5	COM (DC 12V) for pin 4, 6			D5
	6	Alarm Active Digital Output	ON while Alarm ON	Standard	D6
CN70	1	Option	Option error input (Refer to "APPLICATION CONTROL MANUAL")	Option	
(WHI)	2	COM (0V)			
CN73	1	COM (0V)			C3
(RED)	2	Demand signal Input, Input (DC 5V)	Forced thermo-OFF input	Standard	C4
	1	Input (DC 12V)			C7
CN80	2				
(GRN)	3	Fan Motor Trouble Input	Error input from outside (interlock, the check code L30)	Standard	C8
	1				
	2				
CN82	3	Thermostat On Digital Output	Signal output during thermo-ON	Standard	D19
(BLU)	4				
(- /	5				
	6	COM (DC 12V)		Standard	D20
	1	PMV① DC12V(RED)		Standard	R_Dx-valve kit 1
	2	PMV① DC12V(BRN)	RBM-A201VAE does not include	Standard	BR_Dx-valve kit 1
	3	PMV①(WHI)		Standard	W_Dx-valve kit 1
	4	PMV@(WHI)	Only in normal Dx-coil (32, 36, 40HP)	Standard	W_Dx-valve kit 2
	5	PMV①(YEL)		Standard	Y_Dx-valve kit 1
CN510	6	PMV@(YEL)	Only in normal Dx-coil (32, 36, 40HP)	Standard	Y_Dx-valve kit 2
(WHI)	7	PMV①(ORN)		Standard	OR_Dx-valve kit 1
(8	PMV@(ORN)	Only in normal Dx-coil (32, 36, 40HP)	Standard	OR_Dx-valve kit 2
	9	PMV①(BLU)		Standard	BL_Dx-valve kit 1
	10	PMV@(BLU)	Only in normal Dx-coil (32, 36, 40HP)	Standard	BL_Dx-valve kit 2
	11	PMV@ DC12V(RED)	Only in normal Dx-coil (32, 36, 40HP)	Standard	R_Dx-valve kit 2
	12	PMV@ DC12V(BRN)	RBM-A201VAE does not include	Standard	BR_Dx-valve kit 2
	13~20				


- Capacity Demand signal(analogue input voltage) will be used as the main control value for the compressor frequency.
- The control of capacity may not be able to be performed according to the state of an air-conditioner (During oil recovercontrol, defrost etc.).


1) Demand 0-10V STEPPED control (SW3 bit-2 on the DDC(0-10V) interface P.C board(TX-TOS1413) "OFF")






2) Demand 0-10V LINEAR control (SW3 bit-2 on the DDC(0-10V) interface P.C board(TX-TOS1413) "ON")





7 AHU / DX COIL Design


7.1 Equipment selection procedure -Selection flow chart-



7.2 Correction charts for Outdoor unit capacity calculation

[1] Coil on Air temperature vs. capacity correction value


▼ Cooling




Coil on Air wet bulb temp. (°C)

The above capacity values are generated depends on each compressor operation level.

▼ Heating





AHU / DX COIL Design Notes:

Cooling & Heating output figures are based on calculations and 'general' test data. All figures are to be taken as approximations. The properties of the 3rd Party DX COIL will have an effect on the performance of Outdoor units.

- · For the AHU/DX COIL prepared on site, please design with referring to submittal of AHU.
- · The DX COIL must be suitable for R410A.
- The design should allow operation an Evaporator and a Condenser depends on selected usage.
 (Features: Multiple circuits / Liquid Capillary Distributor / Gas Header)
- · The counter flow principle must be observed for the DX COIL design.
- · A Drain Pan must be fitted (even if only used in Heat mode) due to defrost cycles.

7.4 DX COIL Guideline HP

- Guideline HP -

HP			8	10	16	18	20	32	36	40		
		TCB-IFDE	C201E	1	1	1	1	1	1	1	1	
,be		RBM-	8 HP	1	-	-	1	-	1	-	-	
=	mal	A101VAE	10 HP	-	1	-	1	-	1	-	-	
Dx-Coil type	Normal	RBM-	16 HP	-	-	1	1	-	2	-	-	
ă		A201VAE	18 HP	-	-	-	1	-	1	2	-	
			20 HP	•	-	-	1	1	1	-	2	
	АН	U Air	Std.	3,600	4,200	7,200	7,800	8,400	14,400	15,600	16,800	
	Flo	w rate	Min.	2,880	3,360	5,760	6,240	6,720	11,520	12,480	13,440	
	(m	n3/hr)	Max.	4,320	5,040	8,640	9,360	10,080	17,280	18,720	21,160	
	DX	Coil	Min.	3,400	4,250	6,800	7,650	8,500	13,600	15,300	17,000	
Inte	erna	al volume	Max.	4,600	5,750	9,200	10,350	11,500	18,400	20,700	23,000	
Сор	per	Tube Dia.	(mm)	Ø12.7, Ø9.52, Ø8.00 (Recommended Ø9.52 or Less)								
	Ма	x. Capacit	y (kW)	22.4	28.0	45.0	50.4	56.0	90.0	101.0	112.0	
0	Со	il on Air Te	mp.	15 - 24°CWB (18 - 32°CDB)								
Cooling	Eva	aporating 7	Гетр.	6.5°C								
8	Su	perheat		6K								
I^{U}	Air	Suction Te	emp.		27°CDB / 19°CWB							
	(De	esign temp)		27 CDB7 19 CWB							
	Ма	x. Capacit	y (kW)	25.0	31.5	50.0	56.0	63.0	100.0	113.0	126.0	
0	Со	il on Air Te	mp.	12 - 28°CWB								
Heating	Со	ndensating	g Temp					52°C				
<u> ea</u>	Sul	b Cooling						4K				
_	Air	Suction Te	emp.					20°CDB				
	(De	esign temp)				•	20 000				

No. of Ref. Circuit by DX Coil Copper Tube Dia. and DX Coil Size (HP)

	Number of Circuits									
Copper Tube	8.0mm		9.5	mm	10.7mm					
Tube			9.51	111111	12.7mm					
Dx Coil HP	Min Max		Min	Max	Min	Max				
8HP	8	12	6	10	4	6				
10HP	10	14	8	12	5	7				
16HP	16	22	12	16	8	10				
18HP	18	24	14	18	8	10				
20HP	20	26	16	20	10	12				
32HP	32	42	24	30	14	18				
36HP	36	48	26	34	16	20				
40HP	40	54	30	38	18	22				

- Guideline CO Pattern A -

HP	HP		8	10	16	18	20	32	36	40	
		TCB-IFDE	C201E	1	1	1	1	1	1	1	1
Ox-Coil type		RBM-	8 HP	1	-	-	-	-	-	-	-
	Normal	A101VAE	10 HP	ı	1	-	-	-	-	-	-
ပို	Nor	RBM-	16 HP	-	-	1	-	-	2	-	-
ă		A201VAE	18 HP	1	-	-	1	-	1	2	-
			20 HP	-	-	-	-	1	-	-	2
	ΑH	lU Air	Std.	3,600	4,200	7,200	7,800	8,400	14,400	15,600	16,800
	Flo	w rate	Min.				N	lo restrictio	n		
		13/hr)	Max.				N	lo restrictio	n		
DX	Co	il Internal	Min.	3,400	4,250	6,800	7,650	8,500	13,600	15,300	17,000
V	olur	me (cc)	Max.	6,400	8,000	12,800	14,400	16,000	25,600	28,800	32,000
Cop	ре	r Tube Di	a. (mn	Ø12.7, Ø9.52, Ø8.00 (Recommended Ø9.52 or Less)							
	Max. Capacity (kW)		22.4	28.0	45.0	50.4	56.0	90.0	101.0	112.0	
g	Coil on Air Temp.		15 - 24°CWB								
Cooling	Eva	Evaporating Temp.		6.5°C							
Ιĕ	Su	Superheat		6K							
	Air	Suction Te	emp.	27°CDB / 19°CWB							
	(Design temp)					21 0	JDD / 13 (
	Ма	x. Capacit	y (kW)	-	-	-	-	-	-	-	-
g	Со	il on Air Te	emp.					-			
Heating	Со	ndensating	g Temp					-			
Jes		b Cooling						-			
_		Suction Te	-					_			
	(De	esign temp)					-			

No. of Ref. Circuit by DX Coil Copper Tube Dia. and DX Coil Size (HP)

	Number of Circuits					
Copper Tube	8.0mm		9.5mm		12.7mm	
Tube	0.0	111111	9.5mm 		12.711111	
Dx Coil HP	Min	Max	Min	Max	Min	Max
8HP		12		10		6
10HP		14		12		7
16HP		22		16		10
18HP	No	24	No	18	No	10
20HP	restriction	26	restriction	20	restriction	12
32HP		42		30		18
36HP		48		34		20
40HP		54		38		22

^{*} It is able to connect SMMS-e H/P model when you set it as Cooling only mode.

Please setup the Function CODE(DN code) [0F]: "0000" to "0001" by a wired remote controller

- Guideline CO Pattern B -

HP	HP		8	10	16	18	20	32	36	40	
		TCB-IFDE	C201E	1	1	1	1	1	1	1	1
be		RBM-	8 HP	1	1	-	-	-	1	-	-
i i	Normal	A101VAE	10 HP	ı	1	-	-	-	-	-	-
Dx-Coil type	Nor	RBM-	16 HP	-	-	1	-	-	2	-	-
ă		A201VAE	18 HP	1	-	-	1	-	ı	2	-
			20 HP	-	-	-	-	1	-	-	2
	ΑH	lU Air	Std.	3,600	4,200	7,200	7,800	8,400	14,400	15,600	16,800
	Flo	w rate	Min.				N	o restrictio	n		
		n3/hr)	Max.				N	o restrictio	n		
DX	Со	il Internal	Min.	1,800	2,250	3,600	4,050	4,500	7,200	8,100	9,000
V	olur	me (cc)	Max.	4,000	5,000	8,000	9,000	10,000	16,000	18,000	20,000
Cop	ре	r Tube Di	a. (mn	Ø12.7, Ø9.52, Ø8.00 (Recommended Ø9.52 or Less)							
	Max. Capacity (kW)		y (kW)	22.4	28.0	45.0	50.4	56.0	90.0	101.0	112.0
б	Coil on Air Temp.		mp.	15 - 32°CWB							
Cooling	Eva	aporating 7	Гетр.	6.5 - 10.0°C							
١ĕ		perheat		6K							
		Suction Te	•	33°CDB / 28°CWB							
	(De	esign temp)		33 CDD / 20 CWD						
	Max. Cap		y (kW)	-	-	-	-	-	-	-	-
б	Со	il on Air Te	mp.	-							
Heating		ndensating	g Temp					-			
<u>اوء</u>		b Cooling						-			
_		Suction Te						_			
	(De	esign temp)					_			

No. of Ref. Circuit by DX Coil Copper Tube Dia. and DX Coil Size (HP)

	Number of Circuits					
Copper Tube	8.0mm		9.5mm		12.7mm	
Tube	0.0	111111	9.5mm 		12.711111	
Dx Coil HP	Min	Max	Min	Max	Min	Max
8HP		12		10		6
10HP		14		12		7
16HP		22		16		10
18HP	No	24	No	18	No	10
20HP	restriction	26	restriction	20	restriction	12
32HP		42		30		18
36HP		48		34		20
40HP		54		38		22

^{*} It is able to connect SMMS-e H/P model when you set it as Cooling only mode.

Please setup the Function CODE(DN code) [0F]: "0000" to "0001" by a wired remote controller

7.7 DX COIL Manufacturing

			
١.		& Pipework Design Pressure:	4.15MPa
-	- DA GOIL	a Fidework Design Flessure.	4. I SIVIT a

DX COIL & Pipework Burst Pressure (withstand): 12.45MPa (more than 3 x Design Pressure)

DX COIL Contamination:

· Ensure the DX COIL is cleaned, using detergent, after manufacture to remove contaminants from the coil

- · Do not use chlorinated detergent during the cleaning process
- · Do not leave flux on or inside the DX COIL

DX COIL & Pipework Contamination (Allowable Limits): Residual water amount 0.6 mg / m

Residual oil amount 0.5 mg / m Amount of solid contaminants 1.8 mg / m

• DX COIL contaminants must be equal to or less than the values shown above. The allowable contaminant levels shown assumes Ø9.52mm copper tube has been used for the manufacture of the DX COIL

7.8 DX Controller Installation

Installation Site	Avoid Direct Sunlight.
	DO NOT install outside.
	Avoid locations exposed to steam or oil vapours.
	Avoid locations where combustible gas may leak, settle or be generated.
	Avoid installation near machines emitting high-frequency waves.
	Avoid places where acidic solutions are frequently used.
	Avoid places where sulphur based or other sprays are frequently used.
	Avoid places where vibrations may occur.
	Standard Rating ; IP21
Notes	To avoid damage; when making holes for cable glands, please first remove the Gland
	Plate from the DX Coil CONTROLLER
Ambient Temperature	0°C to 40°C
Ambient Humidity	Relative humidity 10 ~ 90% (or less). No dew condensation allowed.
	If the DX-Controller is to be installed where dew condensation could form,
	locally sourced insulation should be fitted to avoid condensation.
Installation Angle	Vertical Installation

7.9 Sensor Con	
Installation	Sensor holders MUST be brazed to the DX COIL to ensure reliable temperature sensing.
\ A #:	Follow the information in the Dx-coil controller Installation Manual for details.
Wire Connections	TC1, TC2, TC and TA which have a 2.5m cable are combined in the Dx-coil controller. If these Sensors are removed during installation ensure the sensors are reconnected to the Dx-coil Controller main PCB (MCC-1570) as shown below: • TC1 Sensor (BRN Plug [2 Pin]) > MCC-1570 CN100 (BLOWN Socket [2 Pin]) • TC2 Sensor (BLK Plug [2 Pin]) > MCC-1570 CN101 (BLK Socket [2 Pin]) • TCJ Sensor (RED Plug [2 Pin]) > MCC-1570 CN102 (RED Socket [2 Pin]) • TA Sensor (YEL Plug[2 Pin]) > MCC-1570 CN104 (YEL Socket [2 Pin]) Take care to re-connect them correctly. The cables should be installed with a U-bend
	at Sensor ends to stop water dripping into components. The sensor cables vinyl tube can withstand up to 105°C be careful to keep clear of high temperature parts. The extension cables' connectors are not IP rated. Ensure that they are located within the AHU.
	If these Sensors needs to extend, following the below cable specification(locally sourced): Cable Specification: VFF, 0.3-0.5 mm2 Available Extend Length(m): Max. 10m (Total: 12.5m) Take care to connect them correctly and carefully handle and prepare the extend cable to prevent getting such as electrical noise, water and dust.
TA Sensor position	The TA sensor which is combined in the Dx-coil controller must be located right position for TOSHIBA control, not demand control. The cooling/heating demand is determined from the DDC. Following the below example picture; 1. Fresh Air Only AHU Supply Air 2. Outdoor Air(Fresh Air) mixed with Return Air AHU Fresh Air Return TA sensor position Return TA sensor position
	3. Outdoor Air(Fresh Air) mixed with Return Air by Heat Recovery Exchanger Exhaust Air Outdoor Air (Fresh Air) Heat Recovery Exchanger DX coil Fan Supply Exchanger

7.10 Dx-valve KIT Installation

7.10 BX Valve III Histaliation					
Installation	Avoid locations in direct sunlight.				
	Standard Rating ; IP21				
Environment	Insulation should be fitted to Dx-valve kit (locally sourced).				
	Ideally the Dx-valve kit should be contained within the AHU. If installed outside, a cover				
	(locally sourced)should be fitted to protect from wind and rain in addition to Insulation.				
Installation	The supplied components need to be assembled on to the DX COIL using custom locally sourced pipework.				
	The PMV (Pulse Motor Valve) must be NOT installed upside down (PMV Motor on bottom). The connection angle between PMV body and PMV Motor is fixed at the factory (using thread lock) and should not be changed. The PMV Motor should not be removed from PMV body. Carefully handle and prepare the PMV when fitting to prevent ingress from foreign matter such as dust or water.				
Brazing	PMV A) Whilst brazing, the PMV body and PMV Motor must be water cooled to keep the				

- A) Whilst brazing, the PMV body and PMV Motor must be water cooled to keep the component's temperature does not exceed 120°C.
- B) Whilst brazing, nitrogen gas must flowed through the PMV body and pipework to prevent internal oxidization.
- C) Prevent cooling water from getting inside the PMV body and connector of the lead during brazing.
- D) Take care not to damage the PMV cables during brazing.

Sensor holders

- · To ensure reliable operation, all Sensor holders must be fitted by brazing.
- Be careful of that the brazing material does not enter into the sensor holder when attaching the TC1, TC2 and TCJ sensor holder.
 - <u>TC1 Sensor</u>: Install it in the collecting part of the gas header.

Braze the TC1 sensor on the location of the lowerside 45 $^{\circ}$ to detect the stable temperature.


<u>TC2 Sensor</u>: Install it in the between the liquid pipe distributor and the PMV.


(TC2 sensor is attached to the refrigerant cycle of AHU.)

<u>TCJ Sensor</u>: Install it in the pass where the temperature of the capillary tube is the lowest. If the TC1, TC2 or TCJ sensors are easy to be subjected to the surrounding thermal effect, cover them with the heat insulator material, and fix them with the fixing band

TC1, TC2 and TCJ sensor position on DX COIL

Gas pipe





8 Control Outline

8.1 Cautions regard with DDC's programing

- (1) Operation Start
- Capacity Demand signal(analogue input voltage) should be output after the AHU's fan operating.

Then, recommend to keep more than 50%(Heating; 40%) Capacity Demand signal during 5mins.

- To protect the compressor, for 5 mins after operation start the compressor will continue to operate even if receives "Zero" demand signal.
- (2) Freeze prevention control (Low temperature release)
- When the compressor(s) stopped by Freeze prevention control, it will re-start after maximum 20 mins depends on DX-COIL condition.
- (3) Recovery control
- Cooling oil(refrigerant) recovery operation duration is approx. 2 to 5 mins and normally takes place every 2 hrs.
- Heating refrigerant (oil) recovery operation duration is 2 to 10 mins and normally takes place every 1 hr.
- (4) Defrost control (Full Defrost)
- The defrost operation terminates based on TE1 & TE2, and re-occur every 55 mins. (Just after start-up or upon changeover from cooling to heating, the target cumulative duration is 25 mins.)
- The defrost operation takes maximum 10 mins.
- (5) Compressor restart prevention timer
- If the compressor(s) is stopped by Capacity Demand or protection function(except Freeze prevention control), normally the compressor will continue to stop for 2 mins 30 secs, even if receives Capacity Demand signal.

8.2 Protection Function Summary

Protection Controls varies by Outdoor unit, please see appropriate Outdoor unit service manual for full details (Below "Protection Function Summary" is according to SMMS-e.)


Y	nction Summary" is according to SMMS-e.)
Function	Summary
Freeze prevention control	In Cooling Mode prevents low DX-COIL temperatures by controlling compressor speed
(Low temperature release)	(based on TC1/TC2/TCJ sensor temperature).
Cooling oil (refrigerant)	This control periodically increases flow-rate to ensure refrigerant oil does not build up
recovery control	in inter-unit gas pipes (which can occur when operating command is inadequate,
	or while cooling is progressed under low ambient conditions).
	During this control the compressors are operated at a target speed, and Dx valve kit
	PMV is opened to a certain degree. Upon completion of recovery control normal
	Cooling operation resumes.
Heating refrigerant (oil)	This control periodically increases flow-rate to ensure liquid refrigerant trapped inside
recovery control	the DX COIL. It also serves the purpose of recovering DX COIL / Outdoor refrigerant
(Heating Start up Control)	after defrosting and recovering oil present in outdoor heat exchangers during heating overload operation.
	During this control the compressors are operated at a target speed, and Dx valve kit
	PMV is opened to a certain degree. Upon completion of recovery control normal Heating
	operation resumes. Recovery operation normally takes place after defrosting.
Defrost control	In Heating mode a defrost operation can be performed to reduce ice build-up on the
(Full Defrost)	Outdoor unit (based on TE1 & TE2 sensor). During Defrosting the refrigerant cycle is
	reversed temporarily cooling the DX COIL. The defrost operation terminates based
	on TE1 & TE2, and can re-occur every 55 mins. While the outdoor unit is Defrosting
	the Dx valve kit PMV is opened to a certain degree. Heating Recovery operation
	normally takes place after defrosting.
High Pressure release	This control can perform a staged shutdown of the compressors based on PD
control	sensor value and P0 limit:-
	When Pd ≧ P01 compressor No. 2 (the last one of two compressors in terms of startup
	order in a two compressor configuration) is shut down.
	When Pd ≧ P02 compressor No.1 (the first compressor in terms of startup order) is shut down.
	The compressor(s) will automatically re-start after 2 mins 30 secs.
	<heating: p01"3.45mpa",="" p02"3.5mpa"=""> <cooling: p01"3.85",="" p02"3.9mpa"=""></cooling:></heating:>
Case Heater control	There are 2 types of case heaters: a compressor case heater and an accumulator
	case heater. This control function is aimed at preventing the accumulation of
	refrigerant in those cases, and is performed by all outdoor units.
	If the power supply has not been turned on for a specified period before a post installation
	test run, compressor failure may occur. Similarly, when starting compressors after a long
	period of no power supply, it is recommended that the power supply be turned on for a
	while before operation is resumed, just like a post-installation test run.
A3-IPDU control	1) Current Release Control
(A3-IPDU =	To prevent inverter input current from exceeding the specified value, output frequency
Inverter P.C. board	is controlled with AC input current as detected by T02 mounted on the control P.C. board.
for compressor)	2) Heat sink temperature detection control
	This control function is aimed at protecting IPM from overheating via a thermistor.
	This control can increase outdoor fan speed and shutdown the compressors.
	This control can stop the compressor, which will automatically re-start after 2 mins
	30 secs. If the detection is repeated 4 times the unit will not re-start (error code P07).
	3) Overcurrent protection
	When the overcurrent protection circuit on IPDU PCB detects an abnormal current the
	compressor is shutdown. The compressor is re-started after 2 min 30 secs and the
	error count is recorded. If the compressor operates for at least 10 mins the error
	count is cleared. If the detection is repeated 8 times the error is confirmed as final.
	4) High Pressure SW control
	When high pressure switch is activated the compressor is stopped, which will
	automatically re-start after 2 mins 30 secs. If the detection is repeated 4 times the
	unit will not re-start (error check code : P04).


9 Cable specifications

Description	Terminal	Max. Cable Length (m)	Cable Specification
Control wiring between Dx-coil controller and	U1 / U2	1000	Shield wire: ≧ 1.5mm2
outdoor unit		2000	Shield wire: ≧ 2.5mm2
Total wire length of remote controller wiring	A/B	500	Non shield wire:0.75~2.5mm2
and remote controller inter - unit wiring = L			
Analogue Input (0 - 10V) Capacity Demand	A1 / A2	200	Shield wire:0.5~1.0mm2
Mode Input (Cool / Heat)	C23 / C24	100	Non shield wire:0.5~1.0mm2
Digital Output (DO_1,DO_2)	D31/ D32	500	Non shield wire:0.5~1.0mm2
	D33 / D34		


<u>10</u> Interface requirements for controller

10.1 Indoor(DX) P.C board(MCC-1570) function





10.2 DDC(0-10V) interface P.C board(TX-TOS1413) Function





11 Function code (DN code)


▼ Function CODE No.(DN code) table (setting by wired remote controller)

DN	Item	Description	Default(at shipment)
01	Filter display delay timer	0000: None 0001: 150H 0002: 2500H 0003: 5000H 0004: 10000H	0000: None
02	Dirty state of filter	0000: Standard 0001: High degree of dirt (Half of standard time)	0000: Standard
04	Specific indoor unit priority	0000: No priority 0001: Priority	0000: No priority
0F	Cooling only	0000: Heat Pump 0001: Cooling only (No display of [AUTO], [HEAT])	0000: Heat Pump
10	Туре	0055: Dx-coil Interface	0055: Dx-coil Interface
11	Indoor unit capacity 0021 8HP		0000: Unfixed 37 0039 HP 40HP
12	Line address	0001: No.1 unit to 0030: No.30 unit	0000: Unfixed
13	Indoor unit address	0001: No.1 unit to 0064: No.64 unit	0099: Unfixed
28	Automatic restart of power failure	0000: None 0001: Restart	0000: None
33	Temperature unit select	0000: °C 0001: °F	0000: °C
60	Timer setting (by Wired remote controller)	0000: Available(can be performed) 0001: Unavailable(cannot be performed)	0000: Available
92	Fan trouble input release condition	0000: Operation stopped 0001: Release signal received	0000: Operation stopped

(Unit: mm)







Ap	pliance name	Model Name and appearance						
Rem	Remonote Controller							
		RBC-AMT32E	✓					
		RBC-AMS41E	√					
	Wired remote	RBC-AMS54_55E-ES/EN	✓					
	controller	RBC-AS41E	✓					
		NRC-01HE	×					
		RBC-ASC11E	×					
Sche	edule timer and	central remote controller						
	Schedule timer	TCB-EXS21TLE	×					
	Central remote	TCB-CC163TLE2	×					
	controller	TCB-SC643TLE	×					
Rem	onote Controlle	r(TU2C-LINK Controls)						
	Wired remote controller	RBC-AMTU31-E(TR)	✓					
		RBC-AMSU51(-EN/ES)	√					
		RBC-ASCU11-E(TR)	√					

√ :Available × : Prohibition

Appliance name	Model Name and appearance	
Open network and analog interface		
LON Interfac	TCB-IFLN642TLE e	×
Modbus Interface	TCB-IFMB641TLE	×
BACnet IP	BMS-IFBN640TLE	×
Advanced central control		
Smart BMS Manager with data analyze		×
Touch Screen Controller	BMS-CT1280E	√ (*)
	BMS-CT5121E	×
Smart device control interface	BMS-IWF0320E	√ (*)
Individual gateway		
Modbus Interface	BMS-IFMB0TLR-E	×
KNX Interfac	BMS-IFKX1TLR-E	×

(*): Monitoring function only

15 Check Codes

Common Check Codes (Note1 : DDC(0-10V) interface P.C. board is classified as a Remote controller)

(Note2: Regarding outdoor units, refer to their own service manuals)

- E01 : No master remote controller, faulty remote controller communication

The header remote controller has not been set.

Check the settings of SW3 bit1 located on the DDC(0-10V) interface P.C. board(TX-TOS1413).

Check the remote controller inter-unit tie cable(A/B).

- E09: Duplicated master remote controller

Two remote controllers have been set master remote controller.

Check the settings of SW3 bit1 located on the DDC(0-10V) interface P.C. board(TX-TOS1413).

Check the remote controller inter-unit tie cable(A/B).

E13: Indoor(DX) P.C. board(MCC-1570) - DDC(0-10V) interface P.C. board(TX-TOS1413) communication trouble <u>Detected at DDC(0-10V) interface P.C. board</u>

Check connection of tie cables(A/B) between the connector CN41(BLU) located on the Indoor(DX) P.C. board and the connector CN1(WHI) located on the DDC(0-10V) interface P.C. board.

Check for the trouble in indoor(DX) P.C. board.

- E14 : Indoor(DX) P.C. board(MCC-1570) - DDC(0-10V) interface P.C. board(TX-TOS1413) communication trouble <u>Detected at Indoor(DX) P.C. board</u>

Check connection of tie cables(A/B) between the connector CN41(BLU) located on the Indoor(DX) P.C. board and the connector CN1(WHI) located on the DDC(0-10V) interface P.C. board.

Check DDC(0-10V) interface P.C. board power supply at CN4(WHI).

Check for the trouble in DDC(0-10V) interface P.C. board.

F01 : TCJ Sensor trouble

Check connection of TCJ sensor connector and wiring.

Check resistance characteristics of TCJ sensor.

Check for trouble in indoor P.C. board.

- F02: TC2 Sensor trouble

Check connection of TC2 sensor connector and wiring.

Check resistance characteristics of TC2 sensor.

Check for trouble in indoor P.C. board.

- F03: TC1 Sensor trouble

Check connection of TC1 sensor connector and wiring.

Check resistance characteristics of TC1 sensor.

Check for trouble in indoor P.C. board.

- F10: TA Sensor trouble

Check the connection of TA sensor connector and wiring.

Check resistance characteristics of TA sensor.

Check for trouble in indoor P.C. board.

L02 : Outdoor units model disagreement trouble

Check outdoor unit model.

(Check whether the outdoor unit corresponds to Dx-coil Interface or not.)

- L09 : Indoor unit Power Code incorrect

Check the settings of DN Code 11 (See "DX COIL INTERFACE Configuration").

- L22 : Incompatible group combination of indoor units

Check indoor units model.

Check for trouble in indoor P.C. board.

- L30 : Fan Motor operation monitor

Check the operation monitoring of the fan at terminals C7 / C8. If this contact is "CLOSED", the check code "L30" is generated.

- P10 : Safety contact trouble

Check the contact at terminals C5/ C6. If the contact is "OPEN", the check code "P10" is generated.

If this contact is not used, a bridge connection should be installed on the terminals C5/ C6.

16 Related cautions

(1) Installation work

- Secure enough service space for replacement of the Dx-valve KIT and the thermistors.

After the AHU controller is installed, address setting and unit capacity setting is necessary. Refer to the installation manual for the setting method.

Refer to the outdoor unit installation manual or the data book for installation of the outdoor unit.

(2) Test run

- Turn on the main power of the unit at least 12 hours before test run to power the crankcase heater. Insufficient powering time may result in compressor damage.
- Ensure the analogue input is voltage is set to ≥ 4.5V before starting the test run.
- As the capacity setting is made at initial setting, a remote controller is necessary. Remove the remote controller after making the initial settings if it is not used.

(Refer to the installation manual for remote controller for more details.)

(3) Operation control

If the error display appears on the remote controller, do not reset an error by yourself. Contact the service firm or the dealer.

- Refer to the data book for system controller when using the system controller.

(4) Service

- Regular maintenance is required to prolong the life of the units. It is recommended that the maintenance contract be concluded with a maintenance firm.

17 Warranty

- Specifications of AHU and compatibility with National / Local regulations must be confirmed by your company.
- Selection of an appropriate AHU (with appropriate specifications to match those of units connected to the AHU such as configuration, dimension, life-span, vibration, noise level, or features) must be made by your company.
- Toshiba Carrier shall not be liable for any damage to the entire system or the AHU main body caused by connected AHU with wrong specification or wrong usage of AHU.
- Toshiba Carrier shall not be liable for any damage to the outdoor units and Dx-coil interface caused by AHU damage.
- Toshiba Carrier shall not be liable for capacity, responsiveness and accuracy of system.

VRF Dx-coil Interface(DDC type) Design Guideline

DG001-05

June, 2022 5th Edition

Toshiba Carrier Corporation