



#083-#098 System Service Transition For Goodman Furnace To Aspen Slab Coil

Horizontal – Attic Install



- Constructed of ASTM-A653 CS Type B Galvanized Steel
- **Custom fit to the Aspen line of slab coils (See in chart below for model #'s and sizing)**
- 26GA body and door with 30GA flange for easy fit around coil and furnace
- Access door is insulated and sealed with handle and break-away locks
- Lined with R6 – 1.5" (#083) or R8- 2" (#098) ductboard insulation
- Used in horizontal applications
- Sized for A-through-D Furnaces to fit CH24A through CH60B Aspen Slab Coils (See "DX – Treme CH Series Slab Horizontal Coils" spec sheet for specific sizing on slab coils)

Flange: 1/8 " overhang on each side. 1" high.



Access Door: Flush to body,
Size varies depending on model.

Note: W₁ correlates with furnace opening
W₂ correlates with Aspen slab coil opening

OUTSIDE DIMENSIONS (INCHES)

Cody Model #	GDI Furnace Size (W ₁)	Aspen Coil Size (W ₂)	L	H
(083/098)SSTA24A	A(14")	CH24A(16")	21	8
(083/098)SSTA24B36A	A(14")	CH24B/CH36A(24")	21	8
(083/098)SSTB36B48A	B(17.5")	CH36B/CH48A(24")	21	8
(083/098)SSTB48B60A	B(17.5")	CH48B/CH60A(36")	21	8
(083/098)SSTC24B36A	C(21")	CH24B/CH36A(24")	21	8
(083/098)SSTC48B60A	C(21")	CH48B/CH60A(36")	21	8
(083/098)SSTD48B60A	D(24.5")	CH48B/CH60A(36")	21	8
(083/098)SSTD60B	D(24.5")	CH60B(42")	21	8

Furnace Sizing:

A=14" B=17 ½" C=21" D=24 ½"

Submittal Approval:

Job: _____

Location: _____

Engineer: _____

APPROVED for CONSTRUCTION:

PO No: _____

Job No: _____

Representative: _____

By: _____

Title: _____

Date: _____

4200 I 45, P.O. Box 1320, Ennis, TX 75120 Tel. (972) 875-5884 Fax (972) 875-0308

www.codycompany.com