


SIEMENS

SB Encased Systems Breakers 4000 Ampere Frame Rating

Information and Instruction Guide





⚠ DANGER

Hazardous voltages are present inside the enclosures or panels in which the circuit breakers are installed. Serious injury, electrocution, and/or equipment damage will result if circuit breakers are improperly applied or precaution is not used.

De-energize all incoming power prior to installation of circuit breakers or associated accessories.

Only qualified personnel should work on or around this equipment.

Circuit breaker indicators shown in this booklet are for illustration purposes only. Circuit breakers are to be installed in "Discharged" and "Open" positions only.

IMPORTANT

The information contained herein is general in nature and not intended for specific application purposes. It does not relieve the user of responsibility to use sound practices in application, installation, operation, and maintenance of the equipment purchased. Siemens reserves the right to make changes in the specifications shown herein or to make improvements at any time without notice or obligations. Should a conflict arise between the general information contained in this publication and the contents of drawings or supplementary material or both, the latter shall take precedence.

NOTE

***Authorized and qualified personnel—**

For the purpose of this manual a qualified person is one who is familiar with the installation, construction or operation of the equipment and the hazards involved. In addition, he has the following qualifications:

- (a) **is trained and authorized** to de-energize, clear, ground, and tag circuits and equipment in accordance with established safety practices.
- (b) **is trained** in the proper care and use of protective equipment such as rubber gloves, hard hat, safety glasses or face shields, flash clothing, etc., in accordance with established safety practices.
- (c) **is trained** in rendering first aid.

SUMMARY

These instructions do not purport to cover all details or variations in equipment, nor to provide for every possible contingency to be met in connection with installation, operation, or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's purposes, the matter should be referred to the local sales office, listed on back of this instruction guide.

The contents of this instruction manual should not become part of or modify any prior or existing agreement, commitment or relationship. The sales contract contains the entire obligation of Siemens Energy & Automation, Inc. The warranty contained in the contract between the parties is the sole warranty of Siemens Energy & Automation, Inc. Any statements contained herein do not create new warranties or modify the existing warranty.

4000 Amp SB Encased Systems Breakers

Table of Contents

	Page		Page
General Information		Part Three - Monitoring the Electronic Trip Unit	27-34
Introduction	2	Internal Accessories	
Frame Sizes and Frame Ratings	3	Preliminary Installation Procedures	35-36
Rating Plugs	3	Electric Motor Operator	37-44
Interruption and Short Time Ratings	3	Local Electric Close	44
Overcurrent Protection Configurations	3	Remote Close Solenoid Accessory	45-48
RMS Current Sensing	3	Auxiliary Switches	49-50
Accessories	3	Undervoltage Release	51-52
		Shunt Trip	53-54
Description		Electronic Bell Alarm	55-56
Insulated - Encased Construction	4	External Accessories	
Compact Size	5	Key Interlock on Circuit Breaker	57
Bus Spacing and Connections	6	Mechanical Interlock	57
Two-Step Stored Energy Mechanism	6	Padlock Device on Circuit Breaker	57
Centralized Controls and Indicators	6	Padlock Device on Drawout Mechanism	58
Simplified Minimum Depth Drawout Mechanism	7	Closing Blocking Device on SB Breaker	58
Electronic Trip Unit	8	Cell Switches on Drawout Mechanism	59
Overcurrent Protection Configurations	8	Drawout Safety Shutters	60-61
Frame Installation Instructions		Secondary Disconnects	62
Installing the Stationary Drawout Element	9	Control Terminal Blocks	62-64
Installing the Moveable Drawout Element	10	Sliding Secondary Disconnects	65
Installing Fixed - Mounted Circuit Breakers	11	"T" Connectors	65
Installing the Electronic Trip Unit	12-14	Neutral Current Transformer	66-68
Inserting/Removing Rating Plug	14-15	Lifting Bracket	69
Operating Instructions		Rating Plugs	70
Part One - Operating the SB Encased Systems Breaker	16	Display Module	70
Manually Charging the Stored Energy Mechanism	17	Auxiliary Power Source	71
Discharging the Stored Energy Mechanism	18	Universal Test Kit, TS-31	72-73
Locally Closing the Circuit Breaker	18	Outline Dimension Drawings	
Locally Opening the Circuit Breaker	18	4000A Stationary Drawout	74-75
Part Two - Manipulating the Moveable Drawout Element	19	4000A Moveable Drawout	76-77
Racking Controls	20	4000A Fixed Mounted	78-79
Directional Shift Lever	20	Ordering Information	
Racking Pump Handle	21	SB Encased Systems Breakers	80
Drawout Position Indicator	21	Electronic Trip Units	80
Moving Drawout Breaker between:		Rating Plugs	80
Fully Withdrawn and Unlocked Position	22	Shipping Weights	80
Unlocked to Test Position	23	Internal Accessories	81
Test to Connected Positions	24	External Accessories	81-82
Connected to Test Position	25	Accessory Wiring Diagrams	83-85
Test to Unlocked Position	26	UL Listings and File Numbers	82

General Information

Introduction


Siemens SB Encased Systems Breakers bridge the performance gap between Molded Case Circuit Breakers (MCCB) and Low Voltage Power Circuit Breakers (LVPCB). Modern computer-aided design and manufacturing tools were used to effectively blend the technologies of the MCCB and LVPCB. This combination has resulted in a family of encased systems circuit breakers that exhibit the most desirable characteristics of each of the parent technologies. Included in these characteristics are high interrupting capacities, high withstand capabilities (magnetic stress), high short-time capabilities (overcurrent heating), and high mechanical and electrical endurance, without maintenance.

Applications for SB breakers include main, tie, feeder, and emergency source breakers in industrial plants, large commercial complexes, and medical and health care


facilities. The circuit breakers are constructed for either fixed or drawout installation. They can be physically grouped in central distribution switchboards, or used separately in stand-alone applications.

The SB breaker is equipped with a two-step stored energy mechanism for closing and opening the breaker contacts. After a closing operation, sufficient energy is retained in the two-step stored energy mechanism to perform the tripping function. The mechanism may be charged manually with the integrated low-force charging handle or electrically with the optional electric motor operator. Push-buttons, switches and color-coded indicators allow for easy close and open operations.


NOTE: Photographs and illustrations of 2000A breaker used for illustration purposes only.



2000 Ampere Frame



800 Ampere Frame



4000 Ampere Frame

SB Encased Systems Breakers

General Information

Frame Sizes and Frame Ampere Ratings

SB breakers come in three frame sizes with frame ampere ratings ranging from 400 to 4000 amperes. All frames are rated for 100% continuous operation. This particular instruction guide provides detailed SB breaker information for the 4000 ampere frame size. Frame ampere ratings for this size range from 2500 amperes to 4000 amperes.

Frame Sizes and Ratings Combinations

Breaker Frame Size	Breaker Frame Ampere Rating (I _n)
4000 Amperes	2500 Amperes 3200 Amperes 4000 Amperes

Rating Plugs

SB breakers are designed to use interchangeable rating plugs. These rating plugs allow the user to customize the effective ampere rating of the breaker to meet specific applications. The label on the front of the breaker identifies the rating plugs that may be used with that particular breaker.

Available Rating Plugs

Frame Ampere Ratings (I _n)	Rating Plug Values (Amperes) (I ₁)
2500	1600, 2000, 2500
3200	1600, 2000, 2500, 3000, 3200
4000	2000, 2500, 3000, 3200, 4000

Interruption and Short Time Ratings

Two short circuit interruption ratings are available to meet specific applications. The interruption ratings and short time ratings are given in the following table.

UL Listed Interruption and Short Time Ratings

UL Listed Symmetrical Amperes	Frame Size 4000 Ampere	Label Color
Standard Interrupting Rating (kA) @ 240V AC @ 480V AC @ 600V AC	150 100 85	Black (SBS)
High Interrupting Rating (kA) @240V AC @480V AC @600V AC	200 150 100	Red (SBH)
Short Time Rating (kA) T=0.5 sec	65	

The interruption rating of the SB breaker is specified on the front cover label, and is further identified by the use of a "color bar" at the top left of the breaker label. **Black** indicates the "standard" or middle interrupting rating. A **Red** label indicates the highest available interrupting rating for the SB breaker.

Overcurrent Protection Configurations

Siemens Electronic Trip Units for SB breakers are available in six basic overcurrent protection configurations to meet specific protection requirements. All trip units come equipped with Adjustable Continuous Current and Long Time Delay functions. Optional protection configurations are:

Protection Configuration	Identifier
Long Time/Short Time	LS
Long Time/Instantaneous	LI
Long Time/Short Time/Instantaneous	LSI
Long Time/Short Time/Ground Fault	LSG
Long Time/Instantaneous/Ground Fault	LIG
Long Time/Short Time/Instantaneous/ Ground Fault	LSIG

The trip unit that may be used with a specific circuit breaker is identified on the front cover label.

RMS Current Sensing

The Siemens microprocessor controlled Electronic Trip Unit executes the overcurrent fault protection functions of Siemens SB Encased Systems Breakers. The adjustment flexibility provided by the trip unit allows the user to easily accommodate load changes and other protection requirements while still assuring optimum coordination. A standard feature of the trip unit is RMS current sensing. As opposed to peak-current sensing, RMS sensing measures the true heating potential of the current waveform. This allows for more accurate overcurrent protection and eliminates nuisance tripping due to harmonic distortion of the current waveform.

NOTE: For more complete information on other standard and optional features of the Electronic Trip Unit, see Siemens Electronic Trip Unit for SB Encased Systems Breakers Information and Instruction Guide, Bulletin 2.20-3A.

Accessories

A full family of internal, external, and remote accessories are available for Siemens SB Encased Systems Breakers. A breaker may be configured with all of the internal accessories without changing the external physical characteristics. Detailed descriptions of the accessories are contained in the Accessories section, pages 35-73.

Description


In addition to the performance achieved by combining the MCCB and LVPCB technologies, several installation, operation, and safety features have been incorporated into the SB breakers.

Insulated - Encased Construction

The SB breaker's housing, internal barrier, and front cover are molded from a thermoset material with a high-dielectric strength (electrical insulation). The one piece molded case (base and housing) provides enhanced structural integrity. A midbarrier provides outer wall reinforcement, integral arc baffling, and insulation/isolation between the two compartments of the circuit breaker. This patented construction has allowed for a higher interrupting capacity within a smaller size than could have been achieved by more con-

ventional construction. The electrical insulation property of the thermoset material enhances the safety of operation. The insulated case physically isolates and electrically insulates the user from the internal high voltage contacts.

The arc chambers and main contact structure are encased in the back compartment. The trip unit, controls, springs of the stored energy mechanism, and optional internal accessories are located in the front compartment. Access to the front compartment is by the removable front cover. Since the barrier between the two compartments is made from the same insulating thermoset material as the housing, the user is physically isolated and electrically insulated from the main breaker mechanism and contacts when the front cover is removed.




800A SB Encased Systems Breaker Pictured Above (Photo of 2000A frame shown for illustration purposes only)

Description


Compact Size

The 4000A frame size has a width of 23½ inches a depth of only 12¾ inches. This compact packaging is made possible by the insulated-encased construction and thermal performance of the SB breaker. When operated at


100% of the frame rating, 66 sq. in. ventilation is required in top and bottom of front cover for the 4000A frames. Detailed outline drawings of the breakers and drawout elements are included in the Outline Dimensions section, pages 74-79.



4000A Frame Size Drawout



4000A Frame Fixed Mounted



Example: One (1) 4000A Siemens SB Encased Systems Breaker can be mounted in a 90-inch switchboard, with the top section reserved for metering.

Description

Bus Spacing and Connections


Specific installation features of the SB breakers include 7.5-inch pole spacing, and vertical connections. The 7.5-inch pole spacing allows for a standard bus connection as specified in UL 891. Detailed outline drawings are contained in the Outline Dimensions section, pages 74-79.

Two-Step Stored Energy Mechanism

A two-step stored energy mechanism is used to close and open the breaker. Energy is initially stored in the main springs of the stored energy mechanism. When the breaker is closed, spring energy is consumed, and sufficient energy is retained in the breaker to perform the tripping function.

The stored energy mechanism may be charged manually (standard) or electrically (optional). Pushbutton controls allow for easy opening and closing. Color-coded indicators clearly display the opened or closed status of the circuit breaker and charged or discharged status of the stored energy mechanism.


Once the breaker is closed, the mechanism can be recharged. The breaker is now prepared for a rapid open-close or open-close-open operation.



Main stored energy springs located in the front compartment.

Centralized Controls

The manual charging handle, pushbutton control switches, and color-coded indicators are grouped in the central escutcheon on the front cover. The U-shaped construction of the charging handle provides for a firm grip regardless of the position of the breaker in the switchboard. For safety, the charging handle and push-to-close pushbutton are interlocked. This interlock prevents the breaker from being closed unless the charging handle is in the stowed position, the position to which it will automatically return when it is released. The interlock also prevents the breaker from being manually charged if the Close button is depressed. Operating instructions for the stored energy mechanism and controls are in the Operating Instructions section, pages 16-26.



Centralized controls and color-coded indicators.

Description

Stationary and Moveable Drawout Elements

Simplified Minimum Depth Drawout Mechanism

The two elements of a drawout constructed SB Encased Systems Breaker are referred to as the Stationary Drawout Element and the Moveable Drawout Element. The stationary drawout element mounts from the front or bottom into a standard switchboard. Bottom mounting flanges are provided for optional mounting arrangements. The moveable drawout element mounts onto the stationary drawout element's two extension rails. This allows the moveable drawout element to be racked into and out of the stationary drawout element. For inspection purposes, the moveable drawout element must be removed from the extension rails to a work area. Detailed outline drawings of the stationary and moveable drawout elements are in the Outline Dimensions section.


There are four positions of the moveable drawout element: 1.) connected, 2.) test, 3.) unlocked (only), and 4.) unlocked/withdrawn. A "racking" mechanism with a low-force pump handle is used to move the moveable drawout element between the connected, test, and unlocked positions. Since the pump handle is an integral part of the racking mechanism, no auxiliary racking device or

tool is required. In the unlocked position the moveable drawout element is disengaged from the racking mechanism. The moveable drawout element can be easily pulled between the unlocked position and the withdrawn position. A color coded indicator displays the position of the moveable drawout element.


In addition to the integral pump handle, two levers are used to control the movement of the moveable drawout element. A single interlock lever automatically locks the moveable drawout element when it reaches the test or the connected position. The moveable drawout element is released to move to the next position by simply pushing and releasing the interlock lever. **Pushing and releasing the interlock lever with the SB breaker contacts closed will open the breaker.** It is not necessary to hold the interlock lever to rack the moveable drawout element. A directional shift lever determines the direction the moveable drawout element will move when the pump handle is pulled or pushed.

Secondary disconnect sliding terminal blocks for terminating internal accessories are mounted on the sides of the stationary and moveable drawout elements. The secondary disconnects are mated as the moveable drawout element is moved from the withdrawn position to the unlocked position. The terminal points of the secondary disconnects are identified in the Accessories section.


Step-by-step instructions on operating the racking mechanism are contained in the Operating Instructions section.



Stationary Drawout Element



Side View Shown



Moveable Drawout Element

Description

Electronic Trip Units For Siemens SB Encased Systems Breakers

Information

The Electronic Trip Unit is a microprocessor controlled multi-function overcurrent protective device for application with Siemens state-of-the-art family of SB Encased Systems Breakers. The adjustment flexibility provided by the trip unit allows the user to easily accommodate load changes and other protective requirements while still assuring optimum coordination. In addition to the adjustable protection functions, the trip unit is designed to use field interchangeable rating plugs. These rating plugs allow the ampere rating of the breaker to be changed to meet specific applications.

For ease of installation and interchangeability in the field, the trip unit has been designed as a plug-in unit to mount directly into a SB breaker frame.

Current sensors within the SB breakers provide signal currents and operating power for the trip unit. Therefore, when the breaker is closed, the trip unit requires no external connections or control power to perform its protection functions.

Overcurrent Protection Configurations


Trip units are available in six basic overcurrent protection configurations to meet specific protection requirements. All trip units have Adjustable Continuous Current and Long Time Delay. Optional protection configurations are:

Protection Configuration

Long Time/Short Time	(LS)
Long Time/Instantaneous	(LI)
Long Time/Short Time/Instantaneous	(LSI)
Long Time/Short Time/Ground Fault	(LSG)
Long Time/Instantaneous/Ground Fault	(LIG)
Long Time/Short Time/Instantaneous/ Ground Fault	(LSIG)

As standard features, the trip unit has two built-in-test functions and a fault identification function. System Check is a built-in-test function that continuously checks the status of the microprocessor and protective algorithms. A green LED on the front panel blinks approximately every 3 seconds when the microprocessor is properly cycling through its protection routines. Integral Test is a built-in-test that allows the user to exercise the trip unit electronics. LED indicators display the testing status. Trip Status is a fault identification function that stores information when a fault current causes the trip unit to trip the circuit breaker. By pressing the Query button the user can display the cause of the breaker trip by illuminating one of four LED's: OL (overload), ST (short time), SC (short circuit), or GF (ground fault).

Additional optional features include:
Display Module for local current monitoring (field addable)
Zone Selective Interlocking
Communications for remote monitoring



Electronic Trip Unit Adjustment Panel

Frame Installation Instructions

Stationary Drawout Element

	⚠ DANGER
	Hazardous Voltage. Will cause severe injury or death.
	Turn system power off before installing device.

General Instructions

Installation instructions for systems breakers, trip units, and rating plugs are presented in this section. Installation instructions for accessories that may be installed in the field are presented in the Accessories section.

Installing Drawout Constructed SB Breakers


Drawout constructed SB breakers are designed to be installed from the front into a switchboard with a minimum width opening of 28.34 inches. The stationary drawout element may be secured in the switchboard at the front to vertical supports and at the top and bottom to horizontal supports.

Installing the Stationary Drawout Element

Prepare the switchboard for installation of the stationary drawout element in accordance with the outline drawings located in the Outline Dimension Drawings section, pages 74-79. The outline dimension drawing of the stationary drawout element for the 4000A frame is located on pages 74-75. The locations of the mounting holes are depicted on the drawings.

Carefully uncrate the stationary drawout element. Remove all packing material with the exception of the tie wraps holding the extension rails in place. Depending upon the installation scheme, it may be necessary to remove the tie wraps on the extension rails just prior to securing the stationary drawout element in the switchboard. If the stationary drawout element is secured to a pallet, remove the securing device.

The bottom of the stationary drawout must be secured to the switchboard using four (4) $\frac{3}{8}$ " bolts. Additional mounting hardware may be used to attach the top and front of the stationary drawout, but is not required.



Attach lifting device to identified lifting points only.

The stationary drawout element can be manually lifted and held in position as it is being installed. However, if preferred, the two holes identified as lifting points on the outline drawing may be used to attach a lifting device. (NOTE: The two (2) rear holes are located such that the stationary drawout element can be easily balanced as it is being lifted by a crane or hoist. **Do not** lift stationary drawout element by only the two (2) top front holes. If preferred, device can be lifted by utilizing all four (4) top holes.) Lifting devices should not be attached to any other points. The stationary drawout element should not be lifted by the primary stabs.

Lift the stationary drawout element into position and secure it in place. Remove the lifting device.

Remove the tie wraps securing the extension rails. Check to ensure that no packing or other foreign material impedes rail movement.


Frame Installation Instructions

Moveable Drawout Element

Installing the Moveable Drawout Element

The outline drawing of the moveable drawout element for the 4000A frame is located on pages 76-77.


Carefully uncrate the moveable drawout element and remove all packing material with the exception of the colored tape holding the racking pump handle in place. Items such as keys for the SB breaker with a key interlock accessory will be taped to the top of the moveable drawout element. If the moveable drawout element is secured to a pallet, remove the securing device.



Preferred Lifting Arrangement


Attach the lifting device accessory as illustrated. If lifting straps are used instead of the lifting device accessory, the lifting straps should go between the primary contacts. In either of these arrangements, the moveable drawout element may be balanced as it is being lifted by a crane or hoist. The moveable drawout element should not be lifted by the primary contacts.

Pull out the extension rails on the stationary drawout element until they hit a solid stop.



Lift by using rear guide posts (one on left side and one on right side).

Lift the moveable drawout element over the extension rails. Align the moveable drawout element such that the rollers straddle the rails. Carefully lower the moveable drawout element onto the rails. Remove the lifting device. Remove the tape holding the racking pump handle.




Rollers and Rail


Frame Installation Instructions

Moveable Drawout Element and Fixed-Mounted SB Breakers


To properly engage the moveable drawout element with the racking mechanism, the crank pins on the sides of the moveable drawout element must be in the "unlocked" position as illustrated and the interlock lever in the "up" position. During shipping and handling the crank pins may have rotated out of position. If so, rotate them to the proper position. The moveable drawout element may now be moved/racked into the stationary drawout element. Racking instructions are located in the Operating Instructions section.




Crank Pin in Unlocked position.



Crank Pin in Test position.



Crank Pin in Closed or Connected position.




Interlock Lever mechanism

Installing Fixed-Mounted SB Breakers

Prepare the switchboard for installation of the SB breaker in accordance with the outline drawings at the end of this section. The outline drawing for the 4000A frame is located on pages 74-79. The locations of the mounting holes and the recommended screws are depicted on the drawing. All eight mounting screws will be used to secure the breaker to the switchboard.

Carefully uncrate the breaker and remove all packing material. The keys for a breaker with a key interlock accessory will be taped to the top of the breaker. If the breaker is secured to a pallet, remove the securing device.




Lifting straps should go between the stabs.

Attach the lifting straps as illustrated. The breaker should not be lifted by the primary stabs; the lifting straps should go between the stabs. In this arrangement the breaker may be easily balanced while it is being lifted by a crane or hoist.

Lift the breaker into position and secure it with all eight mounting screws torqued to 15 ft. lbs. max. Remove the lifting straps.


Installation Instructions

Electronic Trip Unit and Rating Plug





8.) Replace circuit breaker front cover.

Replace the front cover. Then replace the eight (8) front cover screws.




9.) Re-install the eight screws that hold the front cover in place.




CAUTION: Do not attempt to install a rating plug with the breaker "Closed" or "Charged". Make certain breaker is "Open" and "Discharged" as shown above. Personal injury or mechanical damage may occur.

Check to see that the breaker is open before inserting or removing a rating plug. The breaker should always be in the open position when there is not a rating plug in the trip unit.



1.) Remove the trip unit screws that hold the transparent cover.

The rating plug and adjustments on the front panel of the trip unit are protected by a transparent cover. Prior to installing a rating plug or setting the adjustments on the trip unit, this cover must be removed. Unscrew the two screws that hold it in place.




2.) With a small screwdriver, gently pry the cover loose at one end and remove it carefully.

Installation Instructions

Rating Plug

CAUTION: Do not attempt to force an improper rating plug into a trip unit, mechanical damage may occur.

To prevent the insertion of a rating plug into a trip unit for which it is not intended, the receptacle in the trip unit has been keyed to reject improper rating plugs.



3.) Check label on the rating plug.


Check the rating plug label to verify that it is the proper plug for the trip unit. If it is not a proper plug, the pins will not mate with the plug receptacle.



4.) To insert rating plug, align plug with plug receptacle and press into place.


To **insert** a rating plug in the trip unit, align the plug with the plug receptacle and press the plug into place. The clips on the plug and the compression fit hold the plug in place, eliminating the need for screws or latches.

To **remove** a rating plug, squeeze the clips and pull the plug from the plug receptacle. Since the plug is held in place by compression, some force will be required to remove the plug. **Do not close** the breaker with the rating plug removed from the trip unit.



5.) To replace the cover, bow slightly in the middle, and snap into place.

After the rating plug has been inserted and the necessary setting adjustments have been made (see Fault Protection Adjustments, pages 28-33), replace the cover by sliding the protective shield into the top lip of the trip unit, bow slightly in middle, and press down with thumb on bottom to snap shield into place. Replace the two (2) special retaining screws.



6.) The cover may be sealed with a lead seal for tamper evident protection.

After the cover has been replaced, a wire may be inserted through the holes in the screws and secured with a meter seal. This will help prevent tampering.

Operating Instructions

Part One – Operating the SB Encased Systems Breaker

Discharging the Stored Energy Mechanism Without Closing the SB Breaker

Discharging the energy in the stored energy mechanism without closing the SB breaker creates an abnormally high shock condition on the breaker. **The procedure should be avoided except for safety and/or emergency reasons.** To discharge the energy, push and hold the "Open" push-button then push the "Close" pushbutton.

On electrically-operated SB breakers, the electric operator should be disabled (one way is to remove the fuse) prior to discharging the stored energy. Otherwise, the electric operator will automatically recharge the springs.

Standard closing-prevention devices require that to close the breaker there be a trip unit in the SB breaker, the stored energy mechanism be fully charged and the charging handle be in the stowed position. On drawout constructions, the interlock lever must be in the interlock engaged position.

Accessories that inhibit the breaker from being locally closed are presented in the Accessories section. Included are a closing-blocking device for use with remotely-operated circuit breakers, key interlocks, and other locking devices.




Discharging energy in the stored energy mechanism.


Closing the SB Breaker Locally

Before the breaker can be closed, the stored energy mechanism must be fully charged and all of the closing-prevention devices (and accessories) must be in the non-inhibiting state or position. In this condition, all that is required to close the breaker is to push the "Close" pushbutton. When the breaker is closed the "Contact Closed"/"Contact Open" indicator will point to "Contact Closed."

WARNING - If the "Close" pushbutton is depressed when the breaker is closed and the stored energy mechanism charged, the stored energy will be discharged. This will create an abnormally high shock condition which may result in a nuisance opening of the breaker.



Indicates that the circuit breaker is "closed" with the springs in the charged position.



Indicates that the circuit breaker is "open" with the springs in the discharged position.

Opening the SB Breaker Locally

To locally open the breaker, push the "Open" pushbutton. When the breaker is open, the "Contact Closed"/"Contact Open" indicator will point to "Contact Open."

Built-in safety devices will trip the SB breaker when the trip unit is removed, or if the interlock lever on the drawout mechanism is depressed. Performing the trip unit integral test in the trip mode will also trip the breaker.


Operating Instructions

Part Two – Manipulating the Moveable Drawout Element


Manipulating the Moveable Drawout Element

There are four positions of the moveable drawout element. These four positions are defined as Connected, Test, Unlocked, and Withdrawn. The **connected** position is the normal operating position of the breaker. In this position the primary stabs and secondary contacts are connected and the moveable drawout element is locked into position. In the **test** position, the primary stabs are disconnected, the secondary contacts are connected, and the moveable drawout element is locked into position. The **unlocked** position is a transition position between the test


position and the withdrawn position. Physically, the unlocked position and test position are the same. However, in the unlocked position, the moveable drawout element is disengaged from the interlock mechanism. The breaker should not be tested when the moveable drawout element is in the unlocked position. In the **withdrawn** position, the secondary contacts are disconnected and the moveable drawout element is disengaged from the interlock mechanism. The moveable drawout element can be pulled to the fully withdrawn position where it can be inspected or removed from the stationary drawout element.



Moveable drawout element in the Connected position




Moveable drawout element in the Test or Unlocked position




Moveable drawout element in the Withdrawn position (2000A frame drawout used for illustration purposes.)


NOTE: Relationship of finger clusters and bus will be the same for the 4000A frame drawout.



Connected Position



Test and Unlocked Position





Withdrawn Position

Operating Instructions

Part Two – Manipulating the Moveable Drawout Element

Fully Withdrawn and Unlocked Positions

To move the moveable drawout element from the fully withdrawn position to the unlocked position, push toward the bus connections until the moveable drawout element hits a solid stop. The secondary disconnects on both sides of the moveable and stationary drawout elements will mate as the moveable drawout element moves into the unlocked position. When the moveable drawout element is in the unlocked position, the pointer on the position indicator will point to the unlocked symbol. To move the moveable drawout element from the unlocked position to the fully withdrawn position, pull out the extension rails until they hit a solid stop. Then pull the moveable drawout element out to the ends of the rails.



Pushing and pulling the moveable drawout element between the withdrawn and unlocked positions.

Operating Instructions


Part Two – Manipulating the Moveable Drawout Element

Unlocked Position to Test Position


Racking the moveable drawout element from the unlocked position to the test position engages the moveable drawout element with the stationary drawout element. The physical position of the moveable drawout element will be unchanged.

To rack the moveable drawout element from the unlocked position to the test position:


NOTE: If extension rails are pulled out, push them in until they hit a solid stop.




1.) Set the directional shift lever to the racking-in position;




2.) Pull the interlock lever down to the interlock disengaged position. (Illustrated beneath padlock device.) If the breaker contacts are closed, pulling the interlock lever down will trip the breaker.



3.) Pump the racking pump handle until the moveable drawout element has reached the test position.



4.) When the moveable drawout element reaches the test position, the interlock lever will automatically return to the interlock engaged position, the racking pump handle cannot be pumped, and the position indicator will display that the moveable drawout element is in the test position.



Relative position of finger clusters to bus stabs.


Operating Instructions

Part Two – Manipulating the Moveable Drawout Element


Test Position to Unlocked Position

Racking the moveable drawout element from the test position to the unlocked position disengages the moveable drawout element from the stationary drawout element. The physical position of the moveable drawout element will be unchanged.


To rack the moveable drawout element from the test position to unlocked position:




1.) Set the directional shift lever to the racking-out position.




2.) Pull the interlock lever down to the interlock disengaged position. (Illustrated beneath padlock device.) If the breaker contacts are closed, pulling the interlock lever down will trip the breaker.



3.) Pump the racking pump handle until the moveable drawout element is in the unlocked position.



4.) When the moveable drawout element reaches the unlocked position, the interlock lever will automatically return to the interlock engaged position, and the position indicator will display the unlocked position. Pull out the extension rails until they hit a solid stop before pulling out the moveable drawout.



Relative position of finger clusters to bus stabs.

Operations – Functions and Adjustments

Part Three – Monitoring the Electronic Trip Unit

General Instructions


The trip unit executes its overcurrent protection functions based on the rating plug value and the settings of the current adjustments. Therefore, care should be taken by the user to make proper selections and settings.

An adjustment will automatically revert to its minimum possible setting whenever a change to the adjustment is being made. This may cause inadvertent tripping of the breaker if the adjustment is made with the breaker in the closed position. Therefore, Siemens recommends that all adjustment changes be made with the breaker open.

To set an adjustment, place a slotted screw driver onto the point-to-point adjustment switch and rotate the switch to the desired setting.

The figure on the following page describes the region of the time current curve that is being effected by each adjustment.


For complete information on setting the individual adjustments see the Information and Instruction Guide for the Electronic Trip Unit, Bulletin 2.20-3A. For time current trip curves contact your local Siemens sales office.



4000A Electronic Trip Unit (Photo of 2000A shown for illustration purposes only)


Operations – Short Time Fault Protection

Adjustable Short Time Pickup and Adjustable Short Time Delay



Adjustable Short Time Pickup


The Short Time Pickup adjustment is used to set the level of high current the breaker will carry for a short period of time without tripping. This adjustment, together with the Short Time Delay, allows downstream breakers time to clear short circuit faults without tripping the upstream breakers. On Siemens Electronic Trip Units, the Short Time Pickup may be set to 1.5, 2, 2.5, 3, 3.5, 4, 5, 6, 7, or 8 times I_r .



Short Time Pickup

Adjustable Short Time Delay


The Short Time Delay adjustment is used to set the time interval the breaker will wait before responding to the current value selected on the Short Time Pickup adjustment. There are two modes of operation of this adjustment on all Siemens Electronic Trip Units: one is a fixed delay, the other is an inverse I^2t ramp delay. The I^2t Delay has the characteristic of being inversely proportional to the square of the magnitude of the overcurrent condition. This means that higher overcurrent conditions have shorter delays and conversely lower overcurrent conditions have longer delays. This characteristic allows for better coordination with downstream circuit breakers and fuses. In the fixed delay mode, the Short Time Delay may be set to .07, .1, .15, .2, or .3 seconds. In the inverse I^2t ramp Short Time Delay mode, the delay may be set to a calibrated value of .07, .1, .15, .2, or .3 seconds at a current equal to 8 times I_r .



Short Time Delay


Operations – Instantaneous Fault Protection

Adjustable Instantaneous Pickup



Adjustable Instantaneous Pickup

The Instantaneous Pickup adjustment is used to set the current level at which the breaker will trip without an intentional time delay. Non-delayed tripping, as a result of a severe overcurrent condition, minimizes potential damage to electrical systems and equipment. On Siemens Electronic Trip Units, the Instantaneous Pickup adjustment may be set to 1.5, 2, 3, 4, 5, 6, 7, 8, 9, or 10 times I_r .



Instantaneous Pickup


Instantaneous Override

On all trip units, an instantaneous override function has been provided. It is set nominally at the short time rating of the respective breaker frame size. This allows the breaker to ride through high faults up to its short time capability; however, it is self-protecting above these values.

Breaker Frame Size	Short Time kA Rating (.500 seconds max.)
800A	25
2000A	35
4000A	65

Discriminator Circuit (Making Current Release)


This circuit overrides the short time delay function should the breaker attempt to close into a faulted system, tripping the breaker instantaneously. The discriminator function is enabled for the first 6 cycles of current flow, after which normal short time characteristics operate.



Instantaneous Override (Illustrated with Short Time Fixed Delay)

Operations – Ground Fault Protection

Adjustable Ground Fault Pickup and Adjustable Ground Fault Delay



Adjustable Ground Fault Pickup

The Ground Fault Pickup adjustment is used to set the level of ground current at which circuit interruption will be initiated. Together with the Ground Fault Delay, this adjustment allows selective tripping between main and feeder or other downstream breakers. The available ground fault pickup settings, as a percent of the SB breaker frame ampere rating I_n , are given in the table below. In compliance with the National Electric Code (NEC 230-95), no trip point setting exceeds 1200 amperes.

Frame Ampere Rating I_n	Available Setting % I_n											
400A	20	25	30	40	50	60	70	80	90	100		
800A	20	25	30	40	50	60	70	80	90	100		
1200A	20	25	30	40	50	60	70	80	90	100		
1600A	20	26	32	38	44	50	56	62	68	75		
2000A	20	23	27	30	35	40	45	50	55	60		
2500A	20	23	26	29	32	35	38	41	44	48		
3200A	20	21	23	25	27	29	31	33	35	37		
4000A	20	21	22	23	24	25	26	27	28	30		

Adjustable Ground Fault Delay

The Ground Fault Delay adjustment is used to set the time interval the breaker will wait before responding once the ground fault pickup level has been reached. There are two modes of operation of this adjustment for Siemens Electronic Trip Units; one is a fixed delay and the other is an inverse I^2t ramp delay. In the fixed delay mode, the Ground Fault Delay may be set to 1, 2, 3, 4, or 5 seconds. In the inverse I^2t ramp delay mode, the delay may be set to a calibrated value of .1, .2, .3, .4, or .5 seconds at a current equal to 0.5 times the frame ampere rating I_n . The inverse I^2t ramp delay reverts to a fixed delay of the same value when the ground current (I_g) exceeds 50 percent of the frame rating (I_n).

Ground Fault Memory Circuit


All Siemens Electronic Trip Units with ground fault protection come equipped with a ground fault memory circuit. This circuit effectively integrates ground fault currents with time. This provides an added protection by preventing the ground fault delay circuits from being reset to zero when the ground fault currents are intermittent and erratic. The time constants for the current integration are preset within the trip unit as a function of the Ground Fault Delay.

Ground Fault Sensing Schemes

The trip unit can be configured to accommodate the following ground fault sensing schemes.

- 3-Phase, 3-Wire Residual
- 3-Phase, 4-Wire Residual
- Source Ground
- Zero Sequence

All that is required by the user to configure the trip unit to support these protection schemes is to set the ground fault selection switch to the desired configuration. The selection switch is on the left side of the trip unit and must be set prior to the trip unit being installed in the SB breaker.



Ground Fault Delay

Operations – Ground Fault Sensing Schemes

Ground Fault Sensing Scheme

The following are brief descriptions of the ground fault sensing schemes as they relate to the Siemens Electronic Trip Unit. Detailed technical and application information of the ground fault sensing schemes is contained in NEMA Standard No. PB 2.2 "Application Guide for Ground Fault Protective Devices for Equipment".

Residual (3-Phase, 3-Wire). Under normal system conditions (without ground fault), the vector sum of the phase currents being monitored by the trip unit is zero. This is also true under the condition of an overcurrent phase-to-phase fault and phase-unbalance condition. When a phase-to-ground fault occurs, the vector sum of the phase currents is directly proportional to the magnitude of the fault. The trip unit's microprocessor uses this vector sum data in the execution of the ground fault protection function. The trip unit utilizes the internal breaker current transformers. No external current transformers are required.


Residual (3-Phase, 4-Wire). In the 3-Phase, 4-Wire Residual scheme a fourth current transformer is connected in the neutral conductor to "Sense" normal neutral currents. Under normal system conditions the vector sum of the currents in all phases equals the neutral current. This is also true under the condition of an overcurrent phase-to-phase fault and phase-unbalance condition. When a phase-to-ground fault occurs, the fault current returns via a path other than the neutral. Therefore, the vector sum of the phase

currents no longer equals the neutral current. This current differential is detected by the trip unit and used in the execution of the ground fault protection function.


Source Ground. In this scheme, the phase currents are not used in detecting and processing ground faults. The trip unit executes the ground fault protection function based on data from a ground current sensor. This sensor is located on the neutral connection to ground at the service entrance, and is connected to the neutral transformer input terminals on the trip unit.

Zero Sequence. This scheme is very similar to the Residual Schemes. A core balance type current sensor encircles all phase conductors and neutral on a 4-wire system. Under normal system conditions or a phase-to-phase fault condition, there is no output from the sensor to the trip unit because the vector sum of the currents through the sensor window is zero. If a ground fault occurs, the ground current is not seen by the sensor, which returns to the source by a path other than through the sensor window. The sensor detects this current unbalance and provides the data required by the trip unit to execute the ground fault protection function. The zero sequence sensor is connected to the neutral transformer input on the trip unit.


NOTE: For Neutral Sensor installation, see pages 67-68.



Residual Sensing Circuit Breaker Wiring for Ground Protection (3-Phase, 4-Wire System Shown).



Source Ground Current.



Zero Sequence Ground Fault Protection.


Operating Instructions

Part Three – Monitoring the Electronic Trip Unit

Trip Unit Test and Monitoring Functions

Siemens Electronic Trip Unit is equipped with three standard test and monitoring functions to aid the user in the installation and operation of the SB breaker.


System Check Indicator



The System Check Indicator is a green LED that blinks approximately once every 3 seconds when the microprocessor is properly cycling through its protection routines.

The trip unit derives its operating power from the phase currents in the SB breaker. The phase current required to operate the trip unit is approximately 20 percent of the frame rating (I_r). If the microprocessor is not properly cycling through its protection routines, the phase current is below 20% I_r , the LED will not light.

Trip Status




The trip Query button and Trip Status indicator lights provide the user the means for determining what type of fault caused the trip unit to trip the breaker. Fault indicators are provided for:

- O.L. - Overload or Long Time Fault
- S.T. - Short Time Fault
- S.C. - Short Circuit or Instantaneous Fault
- G.F. - Ground Fault

When a fault occurs, the fault information is stored in the trip unit by latching the appropriate red LED fault indicator to the "On" position. When the Query button is depressed, the latched fault indicator will light. The electrical power to the indicators is automatically stored in the trip unit, eliminating the need for a battery pack. A hole is provided in the transparent cover to allow the user access to the Query button.

NOTE: During trip unit power up, the S.C. fault indicator will latch, providing a means to check that the circuitry is properly operating. In the case of a fault, the proper indicator will be latched to the fault position. The indicator circuitry always latches the most recent event.

Integral Test Modes



The integral test function enables the user to "exercise" the trip unit electronics, the magnetic latch, and the breaker mechanism. The purpose of the integral test function is to provide the user an easy means to conduct a "go/no go" type test before bringing the breaker on-line. After the breaker has been brought on-line, it may be used during routine inspection and maintenance.

Both phase fault current protection and ground fault current protection may be tested. The integral ground fault test function tests the circuit breaker's ground fault protection system in accordance with NEC Article 230-95(c).

Electrical power to operate the integral test function is provided internally, if the breaker is closed and the phase currents are greater than 20% of the frame ampere rating I_r , or by a plug-in power source (see Accessories section).

The user may execute the test function in either a "no trip" mode, which will test only the trip unit electronics, or a "trip" mode, which will also test the magnetic latch and breaker mechanism. The execution of the integral test function in both the "no trip" and "trip" modes is based on the settings of the long time delay and ground fault delay adjustments. Therefore, the Phase Test will take several seconds to execute and the Ground Fault Test will appear to be nearly instantaneous. To execute a test function in the "no trip" mode, depress the appropriate pushbutton test switch, **Phase** or **GF**. As the trip unit is performing the test, the **Testing** Indicator will light. If the trip unit successfully passes the test, the **Pass** Indicator will light. If the Pass Indicator does not light after the Testing Indicator indicates that the test is complete, a more extensive test should be run with Siemens TS-31 Universal Test Kit (see Accessories).



CAUTION: Before conducting a "Trip" test on a SB breaker which is "Closed" and in service, caution should be taken to evaluate effects on downstream loads. The breaker *will* open during testing, resulting in a disruption of service.

Internal Accessories

Preliminary Installation Procedures

	⚠ DANGER
	Hazardous Voltage. Will cause severe injury or death. If practical turn power off and lock out supplying device before manipulating the Moveable Drawout Element.

	⚠ WARNING
	Mechanism can cause severe injury when cover is removed. Before removing cover, push open button, push close button, push open button again.


Spring Charged  Spring Discharged	Contacts Closed  Contacts Open
---	--

CAUTION: All internal accessories should be installed with the circuit breaker removed from service. If accessories are to be installed while circuit breaker is in service, turn off and lockout power supplying the circuit breaker prior to cover removal and accessory installation.

NOTE: The accessory installation procedures outlined in this booklet are general by nature and may not contain the latest up to date information for complete installation. Therefore it is Siemens' recommendation that all accessories be installed utilizing the instruction information accompanying the accessory.




- 1.) Prior to cover removal check to be sure the circuit breaker main contacts are open and the closing springs are discharged by first pushing the open button.



- 2.) Push the close button and then repeat pushing of the open button.

Internal Accessories


Preliminary Installation Procedures




- 3.) Remove the breaker cover by first removing the (4) #10 Phillips head screws at the corners and the (4) 1/4" Phillips head screws in recesses in cover.



- 4.) Remove cover.




- 5.) Remove the trip unit, if installed, by removing trip unit retaining screw.



- 6a.) Slide the trip unit up to clear the support bracket pins.
b.) Remove the trip unit by pulling the trip unit away from the trip unit plug.

Internal Accessories

Preparation For Installation of Electric Motor Operator



CAUTION: Siemens advises that all internal accessories should be added with the breaker removed from service and properly secured to a work surface. Do not attempt to install accessories with the breaker in a "Closed" or "Charged" position. Personal injury or mechanical damage may occur.

Accessories

The full family of accessories available for Siemens SB breakers are presented in this section. The accessories are divided into two groups: accessories that are installed in the front compartment of the circuit breaker (Internal

Accessories) and accessories that are installed or used outside of the front compartment (External Accessories). The External Accessories are installed on the exterior of the circuit breaker, on the drawout elements, or at remote locations. When the installation location is referred to as the "right side" or "left side," it is with reference to the user's right or left side when facing the front of the breaker.

Components required to access or activate an accessory such as a switch or indicator at a remote location are assumed to be user supplied unless otherwise stated.

Group One - Internal Accessories

Secondary connections to remote locations are made to "secondary disconnects" on drawout breakers and to "control terminal blocks" on fixed-mounted breakers. The terminal points for all internal accessories are defined in the External Accessories section, pages 65-66. Control power connections for accessories are made through terminal blocks mounted on the sides of the breaker (see page 65). Drawout constructed breaker control power connections are made through secondary disconnects mounted on the stationary and moving elements.

Electric Operator Troubleshooting Guide

Symptom	Solutions
Motor does not run	1. Check for springs already charged by checking spring charge indicator. 2. Check for rated voltage at LT1 and LT5. 3. Check motor fuse – requires 1.8A Slo-Blo fuse. 4. Check all wiring connections. 5. If the lamp connected to LT4 is blinking slowly (one second on, two seconds off) remove power from LT1 and LT5 then re-apply power.
Motor runs for 20 seconds does not charge springs, lamp on LT4 blinks slowly (one seconds on, two seconds off).	1. Remove power from LT1 and LT5, manually charge breaker. Reapply power to LT1 and LT5 motor should run for less than 10 seconds and shut off. Lamp on LT4 should remain on.
Breaker will not close electrically.	1. Check to see if springs are charged by checking charged indicator flag. 2. Check for power on LT1 and LT5. 3. Check for power on LT2. If power is on LT2, remove and reapply. 4. Check to see if breaker is locked in open position by either padlocking device, kirk key, or drawout interlock. 5. Check to see if breaker handle is fully seated in cover. 6. Check all wiring connections.
Lamp on LT4 blinks slowly (one second on, two seconds off).	1. Remove power from LT1 and LT5. Manually charge breaker springs. Reapply power to LT1 and LT5. Lamp on LT4 should remain on.

Motor Operator Current Draw

Supply Voltage	Motor Rating (Amperes)
120V AC	3
24V DC	3
48V DC	3
125V DC	3


Use 1½A Slo-Blo Fuse.

Remote Close Coil (When Used)

Supply Voltage	In Rush Current (Amperes)
120V AC	9.4
24V DC	20.0
48V DC	10.3
125V DC	3.6

Internal Accessories

Electric Motor Operator




Electric Motor Operator Kit

Electric Motor Operator


An electric operator provides for electric charging of the springs of the stored energy mechanism, remote closing, spring charging status indication, latch checking, and anti-pump functions. The standard wiring scheme of the electric operator is such that the springs are automatically re-charged after each closing operation. This can be modified by the customer if desired.

The electric operator is installed in the front compartment of the SB breaker. The main contact status check switch is installed on the right side, behind the trip unit and beneath the reset plate. All other components of the electric operator are installed on the left side. The motor fuse is accessible from the front panel.

The principal components of the electric operator are a charging motor, motor controller, gear box, cam mechanism, closing solenoid, motor fuse, and check switches to monitor the positions of the mechanical components. The charging motor, gear box, and cam mechanism are integrated into a single assembly at the factory. Electric operators may be selected to operate with a source power of 120V ac or 24, 48, or 125V dc. The microprocessor based controller provides voltage-independent charging time, charging status indication, and software-controlled closing logic for the electric close function.




1.) Install the cam mechanism, gear box and motor assembly.




2.) Align the keyway of the shaft with the keyway of the charging arm.

Internal Accessories


Electric Motor Operator



- 3.) Install the Motor Operator Assembly on the mechanism plate with the three #10 x 1/4" screws. Align the keyway of the charging shaft with the keyway of the charge arm. All mounting screws are Long-Lok® self-locking screws. (Torque screw to 25-32 in. lbs.).




- 4.) Locate and slide the Remote Close Lever on the Closing D Shaft located on the Mechanism. Secure the Lever by tightening the Set Screw to 6-8 in-lbs.



- 5.) Locate the Remote Close Solenoid. Remove the Handle Check Switch from the Solenoid Bracket. Mount the Remote Close Solenoid to the mechanism plate. Make sure that the Solenoid Plunger is seated inside the Solenoid. Secure the assembly with the #6-32 x 1/4" screw (torque to 9-10 in-lbs) and #10-32 x 3/8" screw (torque to 25-32 in-lbs). Reattach the Handle Check Switch to the Solenoid Bracket with the #4-40 x 1/2" screws (torque to 4-6 in-lbs).


NOTE: If the handle check switch was removed from the solenoid bracket, it should be re-installed at this point.




- 6.) Attach the Latch Check Switch on the mechanism plate with the two #6-32 x 1/4" screws. Adjust the switch while holding the Actuator against the switch body.

Internal Accessories


Electric Motor Operator



- 7.) Adjust the switch while holding the Actuator against the switch body. Adjust the switch so that there is .11-.12 inch clearance between the switch Actuator and the Latch Lever. Tighten screws to 9-11 in. lbs. Check adjustment after tightening screws and readjust if necessary.




- 8.) Plug LT6 and LT7 Connectors into the Connector Strip until latch tabs snap into slots. Gently pull wires to ensure they are latched into the Connector Strip.




- 9.) Install the Electric Motor Controller (ECMC Assembly) to the Motor Operator Assembly with the four #6-32 x 1/4" screws and #6 lockwashers. Torque screws to 9-11 in.-lbs.

Internal Accessories

Electric Motor Operator



Mounting of "B" Switch




"B" Switch Assembly

- 10.) Connect the MTR-Connector and the Fuse Connector to the Motor and Fuse Holder. Connect the RC+ Connector and RC-Connector to the Remote Close Solenoid.
- 11.) Install the "B" Switch assembly on the reset mechanism assembly. Make sure to install the Insulator between the Switch and metal bracket. Secure the assembly with the two #4-40 x 1/2" screws. Torque screws to 4-6 in-lbs. Check to be sure the Actuator fits into the slot in the push link and does not bind.
- 12.) Route the two wires attached to the "B" Switch from the right side of the breaker to the left side of the breaker. The wires need to be fed under the mechanism plates.
- 13.) Connect the J1-8 Connector and the J1-9 Connector.

Internal Accessories

Electric Motor Operator




14.) Re-install the side plate mechanism assemblies if they had been removed.


15.) Feed wires through wire opening in side panel as illustrated above.




16.) Replace the trip unit by pushing it onto the plug. Slide the trip unit over the bracket pins.




17.) Secure the unit by replacing the mounting screw. Torque screw to 6-8 in. lbs.



18.) Before replacing the breaker cover remove the fuse hole plug from the inside of the cover as illustrated above. Also cut out the "Fuse not installed" area of the rating label.




19.) Replace front cover (see page 14) being careful not to pinch the wires that are routed to the secondary disconnects or terminal block.



20.) Replace the (4) #10 Phillips head screws at the corners and the (4) 1/4" Phillips head screws in recesses in cover.

Internal Accessories

Electric Motor Operator



Legend

- | | |
|---|-------------------------------------|
| 1. Motor Operator Assembly | 11. #6-32 UNC-2B x 1/4" PHMS |
| 2. Remote Closing Solenoid Switch | 12. #4-40 UNC-2B x 1/2" PHMS |
| 3. Connector Strip | 13. #6 Lockwasher |
| 4. Motor Fuse Connector | 14. #6-32 UNC-2B x 1/4" PHMS |
| 5. UL Label | 15. #6-32 UNC-2B x 1/4" Type F CPHS |
| 6. DC or AC ECMC Assembly | 16. Cable Tie |
| 7. Electric Operator Label | 17. Local Close Switch Assembly |
| 8. "B" Switch Assembly (Motor Operator) | 18. - |
| 9. #10-32 UNC-2B x 1/4" PHMS | 19. Wire Tie Adhesive Mounting Base |
| 10. #10-32 UNC-2B x 3/8" PHMS | |

Internal Accessories

Electric Motor Operator and Local Electric Close


A charging status indication (contact accessible at terminal point <LT4>) provides the capability to remotely monitor the stored energy mechanism. The contact is "on" if the springs are fully charged. The contact will be alternately "on" for 300 milliseconds and "off" for 300 milliseconds as the springs are charging or until 20 seconds have elapsed, approximately twice the time required to charge the springs. If the springs are not charged after 20 seconds, the contact alternates between 1 second "on" and 1 second "off," indicating that there is a problem. SB breakers with an electric operator may be charged manually if the electric operator is disabled for any reason.

Local Electric Close

The local electric close allows the user to electrically interlock a local closing operation. It is available for breakers with either the electric operator or remote closing solenoid. The local electric close is commonly used in conjunction with a manual close-blocking device (See Close Blocking Device, page 58).

The electric close pushbutton switch is installed in the center escutcheon of the front panel, directly below the push-to-close button switch.

The Local Electric Close accessory is **not** field installable.



Electric Motor Operator Schematic Diagram

Electrical Test Information


- 1.) Attach test circuit to accessory leads. Apply rated voltage to the LT1 and LT5 connections. The Electric Operator should charge the breaker. During charging the lamp connected to LT4 should flash. After charging is complete the lamp connected to LT4 should remain lighted.

NOTE: For Trouble Shooting Guide see page 37.

- 2.) With voltage applied to LT1 and LT5, apply voltage to LT2. The breaker should close and the Electric Operator should recharge the breaker spring.
- 3.) If the Electric Operator does not function properly during check procedure check for incorrect installation or wiring.

Internal Accessories

Remote Close Solenoid Accessory



CAUTION: Do not attempt to install an accessory with the breaker "Closed" or "Charged". Make certain breaker is "Open" and "Discharged" as shown above. Personal injury or mechanical damage may occur. Preliminary installation procedures are outlined on pages 35-36.

The purpose of the Remote Close Accessory is to allow the user the ability of closing a manually operated circuit breaker from a remote location. The charging spring must be in a charged position in order to properly employ this device. This device may also be used with a factory installed Local Electric Close Solenoid, as noted on page 44.

Installation Instructions

- 1.) Remove rubber band from the solenoid plunger. Slide the remote close lever on to the closing D-shaft but do not tighten the set screw at this time (see figure 1).
- 2.) Place the return spring over the solenoid plunger and slide the solenoid over the solenoid plunger (see figure 1).
- 3.) Attach the remote close assembly to the mechanism plate using the (2) #10 screws provided. The assembly is aligned by a set-out in the mechanism plate that fits in a hole in the remote close bracket.

NOTE: Torque screws to 24-32 in.-lbs.




Figure 1

Internal Accessories

Remote Close Solenoid Accessory




Figure 2

- 4.) Align remote close link with solenoid and tighten set screw (see top view detail in figure 1).

NOTE: Torque set screw to 6-8 in.-lbs.

- 5.) Install the latch check switch assembly (see figure 2). Secure the latch check switch assembly to the mechanism plate using (2) #6 screws provided. Do not tighten screws until the latch check switch assembly is properly adjusted.




Figure 3

- 6.) Adjust switch (see figure 3). When switch is properly adjusted tighten screws.

NOTE: Torque screws to 8-11 in.-lbs.

- 7.) After tightening screws check to insure that tightening of screws did not affect switch adjustment.






Figure 4

- 8.) Locate the reset mechanism (see figure 5).
- 9.) To mount the "B" switch, first make sure that the switch lever is inside the top cavity of the pusher link (see figure 4).
- 10.) Make sure that the switch lever rests on the pusher link when the breaker main contacts are open (see figure 4). Place insulator between "B" switch and bracket. Secure the "B" switch with the (2) #4 screws provided.
- NOTE: Torque screws to 5-6 in.-lbs.**
- 11.) Route wires from "B" switch (see figure 5). Route wires beneath mechanism plates as shown. Install cable tie mounts and cable ties.
- 12.) Connect wire marked RC from "B" switch to solenoid connector. (See Figures 5 and 6). Connect wires marked LC-B together.
- 13.) Route and tie wires as shown in Figure 6.
- 14.) Replace the trip unit by pushing it onto the plug. Slide the trip unit over the bracket pins. Secure the trip unit by replacing the mounting screw. Torque screw to 6-8 in.-lbs.
- 15.) Apply remote close accessory label to side of the breaker cover. Mark label on the opposite side of the cover to indicate that the remote close has been installed.

Internal Accessories




Remote Close Solenoid Accessory



Internal Accessories

Remote Close Accessory

- 16.) Replace the breaker cover. Check to ensure that wires exit the breaker through the wire guide and are not pinched by the breaker cover. Torque #10 (corner) cover screws to 28-32 in.-lbs. Torque 1/4" cover screws to 68-75 in.-lbs.
- 17.) For fixed mounted breakers connect the insulated terminals to the proper terminal block locations.
- For drawout breakers follow steps 18 and 19.
- 18.) Route wires through the hole in the drawout movable element (see figures 7 and 8).
- 19.) Connect the insulated terminals to the proper secondary disconnect locations (see figure 7).



Electrical Check


- 1.) Charge breaker springs.
- 2.) Attach test circuit to accessory leads (see figure 9). Apply 85 percent of the rated coil voltage. The circuit breaker should close (the main contacts should close).
- 3.) With circuit breaker main contacts closed. Check to make sure coil circuit has been opened. Check to make sure the spring charged indicator circuit is open.
- 4.) If remote close accessory does not function properly, check for incorrect installation or wiring.

Electrical Data for Remote Close


Coil Voltage	Inrush Current (Amperes)	Catalog Number
60Hz AC		
120	9.4	SBRCS120, SB4RCS120
DC		
24	20	SBRCS24, SB4RCS24
48	10.3	SBRCS48, SB4RCS48
125	3.6	SBRCS125, SB4RCS125

Internal Accessories

Auxiliary Switches



CAUTION: Do not attempt to install an accessory with the breaker “Closed” or “Charged”. Make certain breaker is “Open” and “Discharged” as shown above. Personal injury or mechanical damage may occur. Preliminary installation procedures are outlined on pages 35-36.



Auxiliary Switches Kit (6 switches shown)

Auxiliary Switches

Auxiliary switches are used as signal contacts to indicate the open/closed status of the breaker’s main contacts. The status of the main contacts is indicated by the open/closed status of the auxiliary switches as follows:

“A” or “NO” Open when main contacts are open.
Contacts: Closed when main contacts are closed.

“B” or “NC” Closed when main contacts are open.
Contacts: Open when main contacts are closed.


A maximum of six “A” and “B” auxiliary switches can be installed in the breaker. The switch contact ratings are:

Switch Contact Ratings

Supply Voltage	Ampere Rating
120V ac	10 Amps
240V ac	10 Amps
480V ac	6 Amps
24V dc	3 Amps
125V dc	0.5 Amps

If practical, the auxiliary switches should be installed prior to the SB breaker being installed in the switchboard. Before starting the installation, the breaker should be in the open position and the stored energy mechanism should be discharged. A drawout constructed SB breaker, already installed in the switchboard, should be placed in the fully withdrawn position to allow access to the secondary disconnects.


The auxiliary switches are installed on the right side of the front compartment, behind the trip unit and below the reset plate.




Auxiliary Switches are installed on the right side.

Follow these steps to install the auxiliary switches:

- 1.) Position the auxiliary switch assembly so that it is aligned with the retaining slot.
- 2.) Tilt the auxiliary switch assembly forward and slip the switch tab into the retaining slot.




- 3.) Secure the assembly in place.




- 4.) Run the auxiliary switch wires:
 - a.) Run the wires through the access hole to the secondary disconnects or terminal blocks on the right side.
 - b.) Connect the wires to the designated terminal points
 - c.) Secure the wires in place with wiring straps as required. Wires for auxiliary switch(s) exit from the breaker right hand side - photo is for illustration purposes only.

Internal Accessories


Auxiliary Switches



5.) Secure the trip unit in place with the retaining screw located at the top of the trip unit. Torque to 6-8 in. lbs. If trip unit top is not secured properly, the interlock will prohibit closing of the breaker.




6.) Replace the front cover of the breaker, being careful not to pinch wire leads routed to secondary disconnects or terminal blocks. Secure with eight (8) Phillips head screws. Installation of the auxiliary switch is complete.




Internal Accessories

Undervoltage Release (UVR) Solenoid



CAUTION: Do not attempt to install an accessory with the breaker “Closed” or “Charged”. Make certain breaker is “Open” and “Discharged” as shown above. Personal injury or mechanical damage may occur. Preliminary installation procedures are outlined on pages 35-36.



Undervoltage Release Kit

Undervoltage Release

The undervoltage release (UVR) trips the SB breaker in accordance with the pick-up and dropout requirements of UL-489. The monitored voltage is normally the voltage on the line side of the breaker. Available UVR coil ratings are 120, 240, 480, or 600V ac or 12, 24, 48, or 125V dc. The UVR will instantaneously (no intentional delay) trip the breaker when the voltage drops below the trip value. Tripping can be delayed up to 0.5 seconds by using the external time delay undervoltage accessory with the UVR.


The UVR accessory kit consists of a trip solenoid to trip the breaker, mounting hardware, and internal wiring. The trip solenoid is installed on the right side of the front compartment, behind the trip unit and beneath the reset plate.

Notes:


1. Wire markings are shown in brackets <like this>.
2. LT indicates left-top terminal block or secondary connector.

If practical, the UVR should be installed prior to the SB breaker being installed in the switchboard. Before starting the installation, the breaker should be in the open position and the stored energy mechanism should be discharged. A drawout constructed breaker, already installed in the switchboard, should be placed in the fully withdrawn position to allow access to the secondary disconnects. If being installed in a drawout breaker, use access-hole in right side mechanism assembly.

To install the undervoltage release, first remove the SB breaker front cover and trip unit, if previously installed (see page 37).




- 1.) Place UVR solenoid beneath breaker reset plate.
- 2.) Install UVR on top right side of reset mechanism.




- 3.) Route the UVR solenoid wire leads across the back of the stored energy mechanism, located between the wire shield and the mid-barrier to the left side of the breaker.

Internal Accessories


Undervoltage Release (UVR) Solenoid



4.) Re-install the trip unit.



5.) Secure the trip unit in place with the retaining screw located at the top of the trip unit. Torque to 6-8 in. lbs. If trip unit top is not secured properly, the interlock will prohibit closing of the breaker.




6.) Replace the front cover of the breaker, being careful not to pinch wire leads routed to secondary disconnects or terminal block. Secure with eight (8) Phillips head screws. Installation of the undervoltage release accessory is complete.

Undervoltage Release Ratings

Catalog Number	Hold-in Current (Amperes)	Coil Voltage
SB4UV12	.12	12V dc
SB4UV24	.06	24V dc
SB4UV48	.03	48V dc
SB4UV125	.02	125V dc
SB4UV120	.02	120V ac
SB4UV240	.02	240V ac
SB4UV480	.02	480V ac
SB4UV600	.02	600V ac


Wire terminations on terminal block or secondary disconnect arc shown below.




DC Undervoltage Release Solenoid Schematic Diagram

Internal Accessories

Shunt Trip



CAUTION: Do not attempt to install an accessory with the breaker “Closed” or “Charged”. Make certain breaker is “Open” and “Discharged” as shown above. Personal injury or mechanical damage may occur. Preliminary installation procedures are outlined on pages 35-36.




Shunt Trip Kit


Shunt Trip

The shunt trip provides the capability to open the SB breaker from a remote location. Shunt trips are available to operate with a source power of 120, 240, or 480V ac, 12, 24, 48, or 125V dc. The shunt trip accessory kit consists of a trip solenoid to open the breaker, a clearing switch to remove voltage from the solenoid coil upon the breakers opening and mounting hardware.

To install the shunt trip, first remove the breaker front cover and trip unit, if previously installed (see page 36). Pinching wires is not a problem when removing the cover.




- 1.) Align threaded mounting holes in shunt trip with holes in reset mechanism.
- 2.) Maneuver the switch to the bottom side of the switch mounting bracket. Make sure the switch actuator is resting at the end of the upper groove in the reset arm.



- 3.) Route the wires across the mechanism between the shield and mid-barrier. From left side of the breaker, connect to terminal block or secondary disconnect using terminals LT6-LT8.
- 4.) Replace trip unit and breaker front cover, being careful not to pinch wire leads routed to secondary disconnects or terminal block.

Shunt Trip Ratings


Catalog Number	In-Rush Current (Amperes)	Coil Voltage
SB4ST12	2.50	12V dc
SB4ST24	1.75	24V dc
SB4ST48	1.10	48V dc
SB4ST125	1.02	125V dc
SB4ST120	.63	120V dc
SB4ST240	.41	240V dc
SB4ST480	.35	480V dc



Shunt Trip Schematic Diagram

Internal Accessories


Shunt Trip Schematic Layout




Shunt Trip Installation

Internal Accessories

Electronic Bell Alarm - Display Module Relay



CAUTION: Do not attempt to install an accessory with the breaker "Closed" or "Charged". Make certain breaker is "Open" and "Discharged" as shown above. Personal injury or mechanical damage may occur. Preliminary installation procedures are outlined on pages 35-36.




Electronic Bell Alarm Kit


Electronic Bell Alarm or Display Module Relay

The electronic bell alarm module is an internally mounted accessory which interfaces directly with the Electronic Trip Unit. It provides a solid state relay contact for remote indication of breaker tripping due to overload, short time, short circuit, or ground fault. The bell alarm contact is a latching type and remote reset capability is provided.


To install the bell alarm, first remove the breaker front cover and trip unit, if previously installed (see page 36).




- 1.) Align bell alarm mounting holes as shown.



- 2.) With a small screwdriver, press in tab on right side of 36-pin trip unit connector and release from mounting bracket.




- 3.) Connect bell alarm lead wires (#1 and #22) to corresponding numbered holes in pin connector. (Note: If a display module relay is being installed instead of a bell alarm, connect lead wires to #4 and #22 holes respectively.)



- 4.) Route bell alarm lead wires RT9 through RT12 through right side of the circuit breaker.
- 5.) Connect the four lead wires, in numerical sequence, to the bottom four positions of the secondary disconnect or terminal block, with RT12 installed on the bottom position.

Internal Accessories

Electronic Bell Alarm



Electronic Bell Alarm or Display Module Relay Schematic Drawing (only 1 device per breaker)

External Accessories


Key Interlock and SB Breaker Padlock Device

Key Interlock on SB Breaker

Key interlocks are often used to control local sequencing of breakers when multiple power sources are available for a common load. When the key is removed, the key interlock holds the open pushbutton switch in the trip position, preventing the breaker from being closed. Therefore, if the same key is required by each breaker in a multiple power source system, no two breakers in the system can be closed at the same time.

To remove the key from the key interlock, press and hold the "open" pushbutton; turn and remove key.

The breaker key interlock is not field installable. It is installed at the factory in the central escutcheon of the front panel, directly above the push-to-open pushbutton switch.



Key is installed in the central escutcheon.

Mechanical Interlock

The mechanical interlock device provides the capability to prevent simultaneous closing of two SB breakers. The first breaker to close will keep the other breaker in the open/tripped position. The interlock device is available for fixed mounted breakers installed side-by-side or in the same vertical section. On drawout configured breakers, the interlock device is available for breakers installed in adjacent cubicles, either vertically or horizontally.

The mechanical interlock device is **not** field installable.


Padlock Device on Breaker

A padlock device on the breaker allows the breaker to be padlocked in the open position, preventing the breaker from being closed. It will accommodate three padlocks.


The accessory kit consists of a padlock device and one-way self-tapping screws to prevent its removal. The device is installed over the open pushbutton switch. Blind holes for the self-tapping screws are located above and to the left, and below and to the right of the open pushbutton switch.

Before starting the installation, the breaker should be in the open position, and the stored energy mechanism should be discharged.

To install the device, secure it in place with the screws as provided.



SB Breaker Padlock Device Kit



The padlock device is installed over the open pushbutton.

External Accessories

Drawout Padlock and Close Blocking Devices


Padlock Device on Drawout Mechanism

A padlock device on the drawout mechanism provides the means to padlock the moveable drawout element in the connected, test, or unlocked position. The padlock device can also lock the interlock lever in the interlock disengaged position to prevent the breaker from being closed. This is an important feature. When padlocked in the unlocked position, the moveable element can be pulled to the fully withdrawn position. The device will accommodate three padlocks.


The accessory kit consists of a padlock device and one-way self-tapping screws to prevent its removal. It is installed on the left side of the moveable drawout element, just above the interlock lever.

Before starting the installation, the breaker should be in the open position and the stored energy mechanism should be discharged.

To install the device, secure it in place with the one-way screws as provided.



Drawout padlock device kit



Padlock device is installed above the interlock lever.


Close Blocking Device on SB Breaker

A close blocking device is used to prevent local close of the breaker under normal operating conditions. The device is a cover that mounts over the push-to-close pushbutton, blocking normal access to this switch. A small hole in the center of the cover provides a means to defeat the blocking device in case of an emergency or for test purposes. A small screw driver or similar object may be inserted through the hole to depress the close pushbutton.


The accessory kit consists of a blocking device and one-way self-tapping screws to prevent its removal. Blind holes for the self-tapping screws are located above and to the left and below and to the right of the close pushbutton switch.

Before starting the installation, the breaker should be in the open position and the stored energy mechanism should be discharged.

To install the device, secure it in place with the screws provided.





Close Blocking Device Kit




Close Blocking Device is installed over the close pushbutton switch.

External Accessories

Cell Switches



CAUTION: Do not attempt to install an accessory with the breaker "Closed" or "Charged". Make certain breaker is "Open" and "Discharged" as shown above. Personal injury or mechanical damage may occur.



Cell Switch Accessory Kit

Cell Switches on Drawout Mechanism

Cell switches are used on drawout SB breakers as signal contacts to indicate when the moveable drawout element is in a position other than the connected position. The position of the moveable drawout element is indicated by the open/closed status of the cell switches as follows:

"A" or "NO" contacts - Open when the moveable drawout element is in the test, unlocked, or withdrawn position.
Closed when the moveable drawout element is in the connected position.

"B" or "NC" contacts - Closed when the moveable drawout element is in the test, unlocked, or withdrawn position.
Open when the moveable drawout element is in the connected position.

A maximum of four "A" and "B" cell switches may be installed in a breaker. The switch contact ratings are given in the following table.


Switch Contact Ratings

Supply Voltage	Ampere Rating
120 VAC	10 Amps
240 VAC	10 Amps
480 VAC	6 Amps
24 VDC	3 Amps
125 VDC	0.5 Amps

The cell switches are installed on the left-rear flange of the stationary drawout element.

The cell switch assembly should be installed prior to the moveable drawout element being installed in the switchboard. If the drawout elements have already been installed, the moveable drawout element will have to be removed from the switchboard to allow access to the installation location.



To install the cell switch assembly, attach assembly to the left-rear flange with two (2) 8/32" panhead screws with lock washers in the threaded holes on the flange.




Cell Switches are installed on the left-rear flange of the stationary drawout element.

External Accessories

Drawout Safety Shutters



CAUTION: Siemens recommends Shutter installation prior to placing Stationary Drawout Element into a switchboard or panelboard.



Drawout Safety Shutters Accessory Kit


Drawout Safety Shutters

Drawout safety shutters prevent inadvertent contact with the primary stabs. As the moveable drawout element is moved from the unlocked to the withdrawn position, the shutters automatically cover the primary stabs. The shutters automatically retract to expose the stabs, as the moveable drawout element is moved from the withdrawn to the unlocked position.


The drawout safety shutters kit consists of two shutter assemblies and mounting hardware. The shutters are symmetrical so that either shutter can be used to cover the line or load stabs. The shutters are installed on the sides of the stationary drawout.

If practical, the drawout safety shutters should be installed prior to the stationary drawout element being installed in the switchboard. If the drawout elements have already been installed, the moveable drawout element will have to be removed from the switchboard to allow access to the installation location.

To install the safety shutters:




- 1.) Install four (4) shutter mounting assemblies. (Two (2) per side, use #8-37 hardware.)




- 2.) Secure the shutter to the shutter mounting assemblies. One top and one bottom. (Use #10-32 hardware.)

External Accessories


Drawout Safety Shutters




3.) Install four (4) shutter drive assemblies (two (2) per side) to the left and right cradle plates. (Use #8-32 hardware.)




4.) Connect the shutter link with the shutter drive arm by installing the 5/32" pin and E-ring.




5.) Install shutter springs (zinc silver spring is used on top shutter, white springs are used for the bottom shutter). Installation of the bottom shutter is similar to the top.



6.) Top left shutter assembly installed.




7.) Drawout safety shutters shown installed.



8.) Install four (4) plate extensions to the rear of the moveable drawout breaker. (Extension plates must be flush with the left and right mechanism plates top and bottom.)

External Accessories


Secondary Disconnects and Control Terminal Blocks




CAUTION: Do not attempt to install an accessory with the breaker “Closed” or “Charged”. Make certain breaker is “Open” and “Discharged” as shown above. Personal injury or mechanical damage may occur.

Secondary Disconnects

Secondary wiring connections to remote locations are made to “secondary disconnects” on drawout breakers and to “control terminal blocks” on fixed-mounted breakers. The secondary disconnects and terminal blocks are located along the sides of the breakers, as many as two on each side. They are referenced as left top (LT), left bottom (LB), right top (RT), and right bottom (RB). Left and right are with respect to the user facing the breaker. The terminal points of factory installed internal accessories are identified on page 65. The same terminal point locations should be used when an accessory is installed in the field.



Secondary Disconnects terminal points



Control Terminal Block mounted on fixed-mounted breaker.


Control Terminal Blocks

Control terminal blocks provide electrical access to the internal accessories and trip unit of a fixed-mounted breaker. A breaker can be equipped with up to four control terminal blocks, each with 12 terminal points. The terminal blocks accept #12 AWG user wiring. They are rated for 600 volts application.

The terminal blocks are designed to be installed along the sides of the breaker. They must be installed with a terminal block mount. To install the terminal block assembly(s), attach them with screws to the breaker as illustrated.

The control terminal blocks are referenced as left-top (LT), left-bottom (LB), right-top (RT), and right-bottom (RB). Left and right are with respect to the user facing the breaker. The recommended terminal points for accessories added in the field are illustrated below.

NOTE: The addition of terminal blocks to a fixed mounted circuit breaker adds 1.5 inches to each side or 3 inches overall.



Wires mounted on terminal block.

External Accessories

Control Terminal Blocks

Installation Instructions

	⚠ DANGER
	Hazardous Voltage. Will cause severe injury or death.
	Turn off and lock out all power supplying the circuit breaker prior to cover(s) removal or while cover(s) are removed and when installing any internal or external accessory.
	Replace the cover(s) and shield(s) before power supplying this device is turned on.


Safety Instructions

NOTE: These instructions outline the recommended installation procedure.

Mounting of Terminal Block Mount

Catalog Numbers: SBTBM

- 1.) Accessory installation should be completed before the breaker is mounted and connected. If breaker is installed, turn off and lock out all power supplying the circuit breaker when installing any internal or external accessories.
- 2.) Installation of this device does not require removal of the breaker cover.
- 3.) Remove the four (4) Phillips head screws on the breaker cover. Place the Terminal Block Mount over the screw holes. Reinstall the screws.
- 4.) Secure the assembly by tightening the Breaker Cover screws. Tighten screws up to 8 to 32 in.-lb. torque.



Mounting of Terminal Block Mounts


External Accessories

Control Terminal Blocks


Mounting of Terminal Block Assembly

Catalog Numbers: SBTBLT, SBTBLB, SBTBRT, SBTBRB


- 1.) The Terminal Block Mounts should be installed before installing the Terminal Block Assemblies. If the Terminal Block Mounts are not installed see the Terminal Block Mount Instructions on page 63.
- 2.) After the Terminal Block Mounts are installed, insert the Terminal Block Assembly as shown in Figure 2.
NOTE: Each Terminal Block Assembly contains four Terminal Blocks and one label.
- 3.) To ensure proper positioning of the Terminal Block Assemblies see Figure 3.
- 4.) Insert label into the groove of the Terminal Block (See Figure 2).



Terminal Block Interlock




Mounting of Terminal Blocks



Terminal Block Location

External Accessories

Sliding Secondary Disconnects




Sliding Secondary Disconnects

Sliding secondary disconnects provide electrical access to the internal accessories and trip unit of a drawout constructed SB breaker. They are installed along the sides of the drawout elements such that the electrical connections are made as the moveable drawout element is moved/racked into the stationary drawout element.

A breaker can be equipped with up to four secondary disconnects, each with 12 terminal points. Each secondary disconnect consists of an A and a B block. On the right side of the stationary drawout element the A block is at the top and the B block is at the bottom. They are reversed on the left side: B at the top, A at the bottom. On the right side of the moveable drawout element, the B block is at the top and the A block is at the bottom. These are also reversed on the left side: A at the top, B at the bottom. The blocks and drawout elements are keyed to prevent improper installation.

Disconnects must be affixed to stationary and moveable drawout elements prior to racking-in the moveable element. The secondary disconnects are attached with screws to the stationary and moveable drawout elements.


Secondary Disconnects and Terminal Block Terminal Points




External Accessories

Sliding Secondary Disconnects and Neutral Sensor

To install the secondary disconnects:



- 1.) Engage Secondary Disconnect molded tabs into factory formed slots as indicated.




- 2.) Prior to final installation of the secondary disconnect, it is recommended that a drop of LocTite #271 be put on the 8-32 x 5/16-inch long counter-sunk screws.

The secondary disconnects are referenced as left top (LT), left bottom (LB), right top (RT), and right bottom (RB). Left and right are with respect to the user facing the breaker. The recommended terminal points for accessories added in the field are illustrated below.

	⚠ DANGER
	Hazardous Voltage. Will cause severe injury or death.
	Do not attempt to install accessories with voltage present.

“T” Connectors

“T” connectors are used to connect power buses to the SB breakers.



“T” connectors with mounting hardware (1 connector and appropriate hardware shipped with each kit)

To install the “T” connectors:

1. Mount the “T” connectors to the terminal pads with the mounting bolts. Use torque value supplied with the “T” connector kit.

External Accessories

Neutral Sensing Transformer



⚠ DANGER

Hazardous Voltage.
Will cause severe injury or death.

Turn off and lock out all power before installing this device.

Replace all covers and shields before power supplying this device is restored.



⚠ CAUTION

Incorrect neutral sensor transformer could cause nuisance tripping or improper operation of the ground fault function.

Use only the above series of neutral sensors.

The Ampere Rating of the neutral sensor must match the Maximum Frame rating of the Circuit Breaker.

⚠ Safety Instructions

- 1.) Turn off power feeding this device before starting the installation.
- 2.) Also turn off any line power within the immediate vicinity to prevent the incidental or accidental contact of tools by the installer.

Use transformers with the following breaker frame ratings only.


N25SB	N32SB	N40SB
SBS2500	SBS3200	SBS4000

Introduction

This neutral sensing transformer is designed to be mounted on a bus bar with maximum dimensions of 5.00" x 1.25".

Neutral Sensing Transformer


Neutral sensing transformers are used with 4-wire residual ground fault protection and ground source schemes.



Neutral Sensing Transformer

Mounting

Position the neutral sensor as close as possible to the associated circuit breaker and fabricate four .312 diameter holes 1.50" x 4.00" inches apart in bus, as shown below. Mount the neutral sensor to the bus as shown with 1/4-20 hardware (not provided).




Bus Mounting

External Accessories


Neutral Sensing Transformer

Important


The SB series of electronic trip circuit breakers equipped with ground fault protection may be used in the Residual or Ground Return modes. When used in the Residual mode the orientation of the neutral sensing transformer is important for proper operation. See illustrations below for proper orientation of the neutral sensor for Residual mode Ground Fault. Orientation of the neutral sensor is not required when used in the Ground Return mode of Ground Fault.



Standard Connection



Reverse Connection




Installation of neutral transformer

Terminal Connections

If secondary disconnects or terminal block has been factory mounted and the transformer has been properly oriented and mounted, connect transformer terminal X1 to LT11 and X2 to LT12 using #18 AWG stranded copper wire.

If left top secondary disconnects or terminal blocks are field added, user must remove the circuit breaker cover following instructions on page 35 and 36. Locate the two ground wires marked LT11 and LT12. Properly connect these wires to the secondary disconnect or terminal block terminals LT11 and LT12.

Following instructions steps 19 and 20 on page 42, replace the cover being careful not to pinch the wire leads.



A + 20
- 3

B + 16
- 7


C + 12
- 11

N + 8 - LT11 - X1
- 15 - LT12 - X2

4600 485 - 520 Ω
3200 280 - 325 Ω
2500 170 - 200 Ω

External Accessories

Lifting Device Bracket




CAUTION: SB breakers and Stationary Drawout Elements are heavy. Personal injury or mechanical damage may occur if care is not used in lifting these pieces of equipment.


Lifting Device Bracket

A lifting device is used in conjunction with a hoist or crane to lift a moveable drawout element. Provisions are provided on the drawout elements to attach a lifting device. The attachment location allows the elements to be balanced as they are being lifted and installed.

The instructions for attaching the lifting devices are contained in the Installation Instructions section.




Lifting Device Bracket



Preferred lifting arrangement. Connecting points for lifting device are shown in figure on page 10.

External Accessories


Rating Plugs and Display Module



CAUTION: Do not attempt to install an accessory with the breaker “Closed” or “Charged”. Make certain breaker is “Open” and “Discharged” as shown above, otherwise, personal injury or mechanical damage may occur.

Rating Plugs


Rating plugs provide the capability to set the ampere rating of the breaker to meet specific applications. Available rating plugs, as a function of the frame rating, are given in the table on page 84 in the Ordering Information section. The procedure for inserting and removing the rating plugs is located on pages 14-15 in the Installation Instructions section.



Rating Plug installation

Display Module

The Display Module provides features for allowing the user to locally monitor the phase currents. The switch to set and select the display is accessible to the user through a hole in the transparent cover of the trip unit.



Display Module

Maximum Current Demand

This feature provides a display of the maximum current demand since the unit was last reset. The unit is reset by depressing both the phase and ground fault test pushbuttons simultaneously. Phase and ground fault pushbuttons are located on the SB Electronic Trip Unit in the integral testing section.

Present Current Demand

This feature provides a display of the present current demands. The present current demands are calculated averages over thirty (30) minute intervals. The user may display the most recent stored values by setting the switch to the present demand position for the 30-minute interval.

Local Monitor Relay

This feature provides a local alarm display and an output signal for an external alarm when the average of the phase currents exceeds the alarm set point. The display automatically resets itself when the alarm condition ceases. The output alarm signal is a 5-volt DC level. The signal may be used to display an alarm on a remote indication panel or by using an internal Systems Breaker Modular Relay (SBDMR). The alarm set point may be set to 60, 70, 80, 90, or 100 percent of the continuous current setting.

Load Current Meter

This feature provides a local display of the present 3-phase currents. The user may display the current value by setting the switch to the I_A , I_B , or I_C positions.

External Accessories

Auxiliary Power Supply

Before installing the display module, the breaker should be placed in the open position.

The display module is a plug-in unit. To install the module:

1. Remove the trip unit's transparent cover.
2. Remove cover from the display module receptacle.
3. Insert the module into the receptacle.
4. Replace and seal the transparent cover.

Auxiliary Power Supply

The auxiliary power supply is a plug-in supply for bench testing the Electronic Trip Unit. The supply may also be used to power the trip unit during the execution of a "go/no-go" type test before bringing the SB breaker on-line (see Monitoring the Trip Unit in the Operating Instructions section). The auxiliary power supply operates from 120V ac source power.



Auxiliary Power Supply

External Accessories

Universal Test Kit (TS-31)

General Information

(detailed instructions supplied with kit)



⚠ DANGER

Hazardous Voltage.
Will cause severe injury or death.
Turn power off and lock out all power supplying breaker to be tested before removing cover(s) and during testing.
Replace all covers and shields before power supplying breaker is turned on.

⚠ Safety Instructions



TS-31 Procedures

Operating Instructions

- A. Remove electrical loads from circuit breaker.
- B. Plug the TS-31 test set into a grounded 120 VAC receptacle and turn it on. You will be greeted by the identifying turn-on message:

Siemens Energy & Automation, Inc.
TS-31 Test Set. Press any key to continue.

- C. Select the appropriate ribbon cable assembly and connect it between the TS-31 and the circuit breaker, making sure of alignment and polarity. After pressing ENTER, the TS-31 will prompt:

Enter catalog number:

- D. Type in the catalog of the circuit breaker if a JD, LD, MD, ND, PD FRAME. If the unit being tested is a SB ENCASED BREAKER, type in the catalog number of the trip unit (currently on the side of the trip unit proper and the side of the circuit breaker if the unit was factory installed.)

After entering the catalog number information, press the ENTER key. The TS-31 will respond with:

Searching Catalog . . .
Searching Family/Series . . .

If an invalid catalog number has been entered, the TS-31 will respond with:

XXX...NOT found.
Press any key to continue.

and you will be asked to enter another catalog number.

- E. If valid catalog number has been entered, the TS-31 will prompt for the breaker settings. The TS-31 will respond with:

Enter Continuous Current Setting in %:

If the unit being tested is a SB ENCASED BREAKER trip unit set the continuous setting to 100% (this equals the value of the rating plug which is referred to as I_n .)

Enter Long Time Delay in Seconds:

Enter Instantaneous Pickup Setting:

For breakers with short time functions you may be asked one of the following:

Enter Short Time Pickup:

Select Short Time Delay 1-Fixed 2- I^2t :

Enter Short Time Delay in Seconds:

For breakers with ground fault you will be asked:

Select Ground Fault Type: 1 - Residual
2 - Gnd. Return 3 - Unsure:

Enter Ground Fault Pickup Setting in %:

Enter Ground Fault Delay: 1-Fixed 2- I^2t :

Enter Ground Fault Delay in Seconds

In each case, enter your breaker's switch settings. For example if your breaker is set for 70%, type 70 and then press ENTER. Entry of erroneous data in the above steps will result in false tests and results.

- F. After entering the breaker switch settings, you must select the test you wish to have performed:

Enter test: L - Long S - Short I - Inst.
G - Gnd. Fault C - CT Cont.?

"L" - Long time or overload test.

"S" - Short time test.

"I" - Instantaneous test.

"G" - Ground fault test.

"C" - Current transformer continuity test.

- G. If you press ENTER, you will be prompted for the phase to be tested: The TS-31 will display:

Enter Phase to Test:

External Accessories

Universal Test Kit (TS-31)

Enter one of the following letters:

- "A"—Phase A or Left Pole
- "B"—Phase B or Center Pole
- "C"—Phase C or Right Pole

- H. The TS-31 will report the type of test you selected and give you a chance to abort the test. For example, if "I" was pressed above. The TS-31 will display:

Instantaneous Test
Press ENTER to Continue or A to Abort.

If you pressed the letter "A" to abort, you will be asked to enter again.

Change: 1 - Test 2 - Catalog 3 - Settings:

- I. Press Enter again to start the test. Press any other key to STOP the test. Once a test has been started, the TS-31 will respond with:

Trip test. Press Any Key to Abort.
Time Remaining: xx.xxx Sec.

Be careful at this time. Any key press will abort the test.

- J. The test may take anywhere from a fraction of a second to minutes to complete, depending on which procedure was run. If the test passes, the display will show the following, depending on whether the breaker tripped or not.

Test Passed. xxx.xx seconds
Press any key to continue.

If the breaker tripped during the test, RESET the circuit breaker before continuing.

- K. The TS-31 will prompt for the next instructions. The display will show:

Change: 1 - Test 2 - Catalog 3 - Settings

Enter one of the following numbers:

- "1" – select a new test
- "2" – enter a new catalog number
- "3" – enter a new switch setting

If you enter "1" you will be sent to step F. Choosing a "2" will send the program back to step E. Entering "3" which sends you back to step E, will be slightly different the second time through. On the second line after the prompt for the setting, a number or text in brackets will appear. This will indicate the last setting you entered. If you DON'T wish to change a setting, just press ENTER. If you DO wish to change a setting, type in the new setting and press ENTER.

- L. If you pressed "C" when asked. You will first be prompted by:

Current Transformer Test
Press ENTER to Continue or A to abort.

and then for the phase to test. A message will then appear stating the test results. For example:

CT Resistance Test. Phase X PASSED.
Press any key to continue.

- M. There are additional ERROR messages which may appear on the display during this operation which were not covered previously:

Test Not Running — Check Test Cable.
Press enter to continue.

The test set has sensed that current is not flowing properly in the breaker under test and that there is either an open or short circuit between the TS-31 and the breaker trip unit.

Ground Fault is NOT available on a SJD69300.
Press any key to continue.

You will get this error message if you enter a choice that is not available, such as entering "G" in step F for ground fault test on a catalog number that does have ground fault.

Inconclusive Test, Check Settings.
Press any key to continue or A to abort.

Note: This warning will appear if you attempt to run a short time test with the instantaneous pickup set equal to or below the short time pickup. It would also appear if you tried to run a long time test with short time pickup set to 2. This is only a warning; the test can still be run. However, passing or failing the test may not be conclusive.

XX is NOT a Valid Setting.
Press any key to continue.

Note: This message will appear if you enter a setting value that does not exist. For example a SMD69700ANGT has continuous current settings of 20, 30, 40, 50, 60, 70, 80, 90, 100 percent. If you were to enter any other value than those listed, the above message will appear.

Test Exceeds Capability of TS-31.
Press any key to continue.

Note: This message is not likely to occur. If it does, it means that a test requires more current to run than the TS-31 can produce.


Unit Too Hot, Please Wait.

Note: Running many successive high-current long time tests may over-heat the test set. It will protect itself from damage by preventing further tests until it has had a chance to cool down. The display will indicate when testing can resume.


Outline Dimension Drawing

4000A Stationary Drawout Element

4000 Amp Stationary Drawout Element
Top View




4000 Amp Stationary Drawout Element
Side View





Outline Dimension Drawing

4000A Stationary Drawout Element




Outline Dimension Drawing

4000A Moveable Drawout Element





Outline Dimension Drawing

4000A Moveable Drawout Element




4000 Amp Drawout Moveable Element Front View




Outline Dimension Drawing

4000A Fixed Mounted



4000 Amp Fixed Mounted Side View



4000A Fixed Mounted

Technical drawing of a three-bay bridge cross-section. The drawing shows the structural layout with dimensions and reinforcement details. Key dimensions include:

- Overall width: 23.50
- Span length: 20.00
- Bay length: 12.50
- Deck width: 5.00
- Deck thickness: .50
- Typical deck thickness: 1.50 Typ.
- Deck thickness: .87
- Deck thickness: .63
- Deck thickness: 11.13
- Deck thickness: 11.38
- Deck thickness: 11.63
- Deck thickness: 12.13
- Deck thickness: 12.75

The drawing also shows the reinforcement details, including the distribution of reinforcement bars and the placement of the deck slabs.

[illegible]

Ordering Information

Encased Systems Circuit Breakers, Electronic Trip Units and Rating Plugs

Type SB Encased Systems Breaker Frames, Standard Interrupting Rating

Breaker Type		Fixed Mounted Catalog Number	Drawout Breaker with Moveable Mechanism	Stationary Drawout Mechanism
Ampere Rating	Frame Size		Vertical Bus Catalog Number	Vertical Bus Catalog Number
2500	4000	SBS4025F	SBS4025DV	SBS40DFV
3200	4000	SBS4032F	SBS4032DV	SBS40DFV
4000	4000	SBS4040F	SBS4040DV	SBS40DFV

Type SB Encased Systems Breaker Frames, High Interrupting Rating

Breaker Type		Fixed Mounted Catalog Number	Drawout Breaker with Moveable Mechanism	Stationary Drawout Mechanism
Ampere Rating	Frame Size		Vertical Bus Catalog Number	Vertical Bus Catalog Number
2500	4000	SBH4025F	SBH4025DV	SBH40DFV
3200	4000	SBH4032F	SBH4032DV	SBH40DFV
4000	4000	SBH4040F	SBH4040DV	SBH40DFV

Electronic Trip Unit, 4000A Frame

Catalog Number	Frame Ampere Rating	Continuous Current Setting	Long Time Delay	Instantaneous Pickup	Short Time Pickup/Delay	Ground Fault Pickup/Delay
SB25TLI	2500	x	x	x		
SB25TLS	2500	x	x		x	
SB25TLSI	2500	x	x	x	x	
SB25TLIG	2500	x	x	x		x
SB25TLSG	2500	x	x		x	x
SB25TLSIG	2500	x	x	x	x	x
SB32TLI	3400	x	x	x		
SB32TLS	3400	x	x		x	
SB32TLSI	3400	x	x	x	x	
SB32TLIG	3400	x	x	x		x
SB32TLSG	3400	x	x		x	x
SB32TLSIG	3400	x	x	x	x	x
SB40TLI	4000	x	x	x		
SB40TLS	4000	x	x		x	
SB40TLSI	4000	x	x	x	x	
SB40TLIG	4000	x	x	x		x
SB40TLSG	4000	x	x		x	x
SB40TLSIG	4000	x	x	x	x	x

Rating Plugs, 2500 Ampere Frame Rating

Catalog Number	Plug Rating
25SB1600	1600
25SB2000	2000
25SB2500	2500

Rating Plugs, 3200 Ampere Frame Rating

Catalog Number	Plug Rating
32SB1600	1600
32SB2000	2000
32SB2500	2500
32SB3000	3000
32SB3200	3200

Shipping Weights

Product	Weight (lbs.)
Stationary Drawout Element	150
Moveable Drawout Element (includes assembled breaker)	455
Fixed Mounted Circuit Breaker	380

The addition of factory installed accessories will increase breaker weight.

Rating Plugs, 4000 Ampere Frame Rating

Catalog Number	Plug Rating
40SB2000	2000
40SB2500	2500
40SB3000	3000
40SB3200	3200
40SB4000	4000

Ordering Information

Internal Accessories/External Accessories

Electric Motor Operator

Operating Voltage	Catalog Number
120 VAC	SB4EO120
24 VDC	SB4EO024
48 VDC	SB4EO048
125 VDC	SB4EO125

Electric Operator With Electric Close Interlock

Operating Voltage	Catalog Number
120 VAC	SB4EO120CCX
24 VDC	SB4EO024CCX
48 VDC	SB4EO048CCX
125 VDC	SB4EO125CCX

Remote Closing Solenoid

Operating Voltage	Catalog Number
120 VAC	SB4RCS120
24 VDC	SB4RCS24
48 VDC	SB4RCS48
125 VDC	SB4RCS125

Remote Close Solenoid with Local Electric Close

Operating Voltage	Catalog Number
120 VAC	SB4RCS120LEC
24 VDC	SB4RC24LEC
48 VDC	SB4RC48LEC
125 VDC	SB4RC125LEC

Electric Operator with Local Electric Close

Operating Voltage	Catalog Number
120 VAC	SB4EO120LEC
24 VDC	SB4EO024LEC
48 VDC	SB4EO048LEC
125 VDC	SB4EO125LEC

Electric Operator with Local Electric Close and Electric Close Interlock

Operating Voltage	Catalog Number
120 VAC	SBEO120LECCCX
24 VDC	SBEO024LECCCX
48 VDC	SBEO048LECCCX
125 VDC	SBEO125LECCCX

Shunt Trip

Operating Voltage	Catalog Number
120 VAC	SB4ST120
240 VAC	SB4ST240
480 VAC	SB4ST480
12 VDC	SB4ST12
24 VDC	SB4ST24
48 VDC	SB4ST48
125 VDC	SB4ST125

Undervoltage Release

Operating Voltage	Catalog Number
120 VAC	SB4UV120
240 VAC	SB4UV240
480 VAC	SB4UV480
12 VDC	SB4UV12
24 VDC	SB4UV24
48 VDC	SB4UV48
125 VDC	SB4UV125

Auxiliary Switches

Contact Configuration	Catalog Number
1A & 1B	SB4AS2
2A & 2B	SB4AS4
3A & 3B	SB4AS6
4A & 4B	SB4AS8
5A & 5B	SB4AS10
6A & 6B	SB4AS12

Electronic Bell Alarm

Accessory	Catalog Number	Voltage
Bell Alarm	SBBA24 SBBA48 SBBA125 SBBA120	24V DC 48V DC 125V DC 120V AC

Local Load Monitor Relay

Accessory	Catalog Number	Voltage
Display Module Relay	SBDMR24 SBDMR48 SBDMR125 SBDMR120	24V DC 48V DC 125V DC 120V AC

Time Delay Undervoltage

Accessory	Catalog Number
Time Delay Undervoltage	SB4TDUV

Drawout Safety Shutters

Accessory	Catalog Number
4000A Envelope	SBSS40

Sliding Secondary Disconnects ^①

Accessory	Catalog Number
Sliding Secondary Disconnects	SBSDLT, SBSDLB, SBSDRT, SBSDRB

① The catalog number for the secondary disconnects include one each 12-point A and B block.

Control Terminal Blocks ^②

Accessory	Catalog Number
Control Terminal Blocks	SBTBLT, SBTBLB, SBTBT, SBTBRB
Terminal Block Mount	SBTBM

② The catalog numbers for the control terminal block consists of one 12-point fixed terminal strip.

"T" Connectors

Accessory	Catalog Number
4000A Envelope	SB40TCON

Lifting Device Bracket

Accessory	Catalog Number
Drawout Circuit Breaker	SBLD4

Neutral Current Transformers

Accessory	Catalog Number
2500 Amps Frame Rating	N25SB
3200 Amps Frame Rating	N32SB
4000 Amps Frame Rating	N40SB

Ordering Information

External Accessories

Key Interlocks

Accessory	Catalog Number
Installed on Breaker Provision Only	KISB
Circuit Breaker Drawout	40KIPOF 40KIPOD

Padlock Devices

Accessory	Catalog Number
Installed on Breaker	SBPLB
Installed on Drawout	SBPLD

Breaker Close Blocking Device

Accessory	Catalog Number
Breaker Closing Blocking Device	SBBD

Capacitor Trip

Accessory	Catalog Number
Capacitor Trip	SBCAP

Cell Switches

Accessory	Catalog Number
1A & 1B	4CEL1
2A & 2B	4CEL2
3A & 3B	4CEL3
4A & 4B	4CEL4

Mechanical Interlock

Accessory	Catalog Number
4000A Envelope Fixed Circuit Breaker	SBMIF40
Drawout Circuit Breaker	SBMID40

Dead Front Shield

Accessory	Catalog Number
4000A Envelope Drawout Circuit Breaker	SB40DF

Remote Indication Panel

Accessory	Catalog Number
Remote Indication Relay Panel	SBRIIP

Display Module

Accessory	Catalog Number
Display Module	SBDM

Auxiliary Power Source For Electronic Trip Unit

Accessory	Catalog Number
Auxiliary Power Source	SBAPM


Universal Trip Unit Test Kit

Accessory	Catalog Number
Test Kit	TS31


UL Listings and File Numbers

UL Listing	File Number
Trip Unit	E9896
Breaker	E9896
Drawout Assembly	E135453
Accessories	E57501
CSA Guide	LR57039


Electrical Diagrams



Electrical Diagrams




Motor Operator Wiring Diagram




Bell Alarm/Display Module Relay

Electrical Diagrams



Auxiliary Switch



Neutral Transformer/EP/Remote Indicator Panel

Siemens Energy & Automation Sales Offices

Alabama

Birmingham
(205) 879-7030
Mobile
(205) 621-0822
Montgomery
(205) 271-4486

Alaska

Anchorage
(907) 346-2489

Arizona

Phoenix
(602) 944-7900

Arkansas

Little Rock
(501) 661-9008

California

Fresno
(209) 264-5018
Los Angeles
(714) 979-6600
Sacramento
(916) 631-9433
San Diego
(619) 569-8015
San Francisco
(510) 429-1200
Stockton
(209) 478-9596

Colorado

Colorado Springs
(719) 473-7880
Denver
(303) 694-3770
Ft. Collins
(303) 223-2712

Connecticut

Wallingford
(203) 265-5003

Florida

Ft. Lauderdale
(305) 484-3888
Fort Myers
(813) 656-3605
Jacksonville
(904) 363-0087
Miami
(305) 592-4106
Orlando
(407) 894-7771
Tampa
(813) 287-2356
West Palm Beach
(407) 683-5185

Georgia

Atlanta
(404) 458-4353
Macon
(912) 743-8994
Savannah
(912) 354-5092

Hawaii

Honolulu
(808) 533-7135

Idaho

Boise
(208) 342-6852

Illinois

Chicago
(708) 330-4320
Peoria
(309) 688-8729

Indiana

Evansville
(812) 422-9176
Fort Wayne
(219) 483-6999
Indianapolis
(317) 788-5500
South Bend
(219) 232-6050

Iowa

Davenport
(319) 359-1357
Des Moines
(515) 280-1614

Kansas

Kansas City
(913) 491-3740
Wichita
(316) 942-1409

Kentucky

Louisville
(502) 426-4647

Louisiana

Baton Rouge
(504) 293-6874
New Orleans
(504) 837-8500
Shreveport
(318) 424-0720

Maine

Portland
(207) 854-0021

Maryland

Landover
(301) 459-2044

Massachusetts

Boston
(508) 658-0142
Springfield
(413) 562-7994
Worcester
(508) 792-4566

Michigan

Detroit
(313) 597-7400
Grand Rapids
(616) 247-7611

Minnesota

Edina
(612) 942-8888

Mississippi

Jackson
(601) 936-9360

Missouri

Kansas City
(913) 491-3740
St. Louis
(314) 567-3900
Sunrise Beach
(314) 374-2737

Nebraska

Omaha
(402) 397-1940

Nevada

Las Vegas
(702) 739-7900

New Hampshire

Manchester
(603) 626-0701

New Jersey

Union
(908) 687-7672

New Mexico

Albuquerque
(505) 881-1611

New York

Albany
(518) 482-0790
Buffalo
(716) 834-3815
Long Island
(516) 484-3590
New York
(800) 677-1125
Syracuse
(315) 453-3780

North Carolina

Charlotte
(704) 536-1201
Greensboro
(919) 852-1758
Raleigh
(919) 782-3365
Wilmington
(919) 763-1359

North Dakota

Bismarck
(701) 258-9555
Fargo
(701) 293-7709

Ohio

Cincinnati
(513) 891-8717
Cleveland
(216) 642-0701
Columbus
(614) 766-2204
Dayton
(513) 279-0458
Toledo
(419) 893-7197
Wooster
(216) 262-3268

Oklahoma

Oklahoma City
(405) 235-7515
Tulsa
(918) 665-1806

Oregon

Eugene
(503) 683-2111
Portland
(503) 635-6700

Pennsylvania

Philadelphia
(215) 646-3800
Pittsburgh
(412) 788-8060
York
(717) 854-9776

Rhode Island

Providence
(401) 943-6990

South Carolina

Columbia
(803) 254-7095
Greenville
(803) 288-3490

Tennessee

Chattanooga
(615) 267-7412
Johnson City
(615) 282-2718
Knoxville
(615) 690-5172
Memphis
(901) 761-2123
Nashville
(615) 367-9403

Texas

Austin
(512) 892-0278
Dallas
(214) 247-4481
Fort Worth
(817) 838-9770
Houston
(713) 690-3000
Lubbock
(806) 892-2354
McAllen
(512) 687-2072
San Antonio
(512) 377-3292

Utah

Salt Lake City
(801) 266-9612

Virginia

Richmond
(804) 288-8311
Roanoke
(703) 982-2776
Virginia Beach
(804) 486-0174

Washington

Seattle
(206) 828-6600
Spokane
(509) 325-2582

Washington, D.C.

(301) 459-2044

Wisconsin

Green Bay
(414) 336-1144
Milwaukee
(414) 774-9500

Canada

Mississauga,
Ontario
(416) 564-1995
Pointe Claire,
Quebec
(514) 695-7300
Vancouver,
British Columbia
(604) 321-8687

International

TLX: 822024SEA
IBU UF
Fax: (404) 751-2496
Phone: (404) 751-2291