



## Installation Manual




### Notes

- This fitting requires 100-240V AC/50Hz power input to the driver.
- Installation must be performed only by qualified electrician. Do not interchange any parts of this fitting.
- Do not touch fitting when in use. Make sure it is disconnected from AC supply.
- This luminaire is to be installed on 4-wires/ 3-phase track rail.
- If you have any questions about the installation of this product, please contact Mondolux



### Installation Steps

1. Ensure the mains power is turned off.
2. Make sure the luminaire is adjusted as per desired power and phase settings. See Pictures 1,2.
3. Secure the luminaire by inserting the track adaptor into the Track and lock the knobs. The luminaire is compatible with most of the standard tracks including the Mondolux Brand. See Pictures 3,4.
4. Driver can be adjusted to 4 different positions. Fixing lock can be adjusted to 2 positions. Make sure the driver and fixing lock are adjusted accordingly when connected to a continuous Track system, to avoid installation on the track joints. See Pictures 5 through 10.
5. Installation is complete.



- L1** L1 as a phase
- L2** L2 as a phase
- L3** L3 as a phase
- N** Neutral Conductor

