BEOK CONTROLS

RGB Colorful LCD Screen Smart Thermostat

✓ Scan QR code to finish network configuration swiftly, easy and convenient.

✓ Programmable device, multiple periods allowed to set per day.

✓ 2.8 inches ultra-large colorful LCD screen, delicate visual effect.

✓ Work with TmallGenie, voice control available.

Parameter

Supply voltage	AC100~240V;50~60Hz
Power consumption	1W Max (Wi-Fi 3W Max)
Temp. setting range	5~95°C
Floor limited range	20~90°C
On/off deviation	0.5~10°C, Factory setting ±1°C
Ambient temperature	−5~50°C
Protection level	IP20
Shell material	Anti-Flammable PC

Version:TCR7 1.0(04/2021)

Product Overview

This series of thermostat has Floor Heating, Fan Coil, and Integrated version, meeting the requirements under different scenarios.

Version	System mode	Model	Application
Floor heating	Heating	EP	Built-in & floor sensor, floor limit sensor + Weekly programming
		WP	A NC/NO dual-output + Weekly programming
		WPB	A NC/NO dual-output + Weekly programming+ Potential-free output
Fan Coil	Heating /Cooling / Ventilation	Ac2	Timer task + 2-pipe system
		Ac2-485	Timer task + 2-pipe system + 485Modbus (optional)
		Ac4	Timer task + 4-pipe system + 485Modbus (optional)
Integrated	Heating / Cooling / Ventilation/Floor heating / Floor heating + Heating	AWY	Floor heating & fan coil, weekly programming + Potential-free output + Timer task + 485Modbus (optional) + Door card (optional)

Display Symbols

- Time Display
- Date Week
- Outdoor temperature
- Humidity
- Fan Col valve
- Floor Heating valve
- Power on/off
- Mode
- Child-lock
- WiFi
- Room Temp.
- Current mode
  - ❄ Fan
  - Ⓐ Auto Mode
  - ⟳ Manual Mode
  - ⊠ Temporary Mode
- Fan Speed
- Knob

Temperature Control Mode(Floor Heating/Integrated)

Ⓐ Auto Mode
Weekly-circled programme, up to 6 heating events can be set per day. Heating events, workdays and temperature can be separately customized based on personal routines.

⟳ Manual Mode
Thermostat works based on manually-set temperature, disconnecting from auto mode.

⊠ Temporary Mode
Thermostat works based on manually-set temperature temporarily and then shifts back to auto mode till next event.

User Operation

Power on/off : Press " ⊞ " shortly to turn on/off the thermostat.

Temp setting: Rotate handwheel" ◯ "to change setting temperature by 0.5°C.

System mode: Press " ⊞ " shortly to switch cooling/heating/ventilation. (Fan Coil)
Press " ⊞ " shortly to switch cooling/heating/ventilation/floor heating/ floor heating + heating. (Integrated)

Enter menu: Press " ◯ " enter the menu interface.

Temp control mode: Press " ⊞ " shortly to switch manual/auto mode. (Floor heating)
Press " ❄ " shortly to switch manual/auto mode. (Integrated, floor heating)

Child-lock: Press " M " + " ⊞ " for 3 seconds to activate child-lock.

Auto-mode Setting

When device is off, press " ◯ " to enter menu page, choose "period setting" to set parameters, then press " ⏻ " to save and exit.

Events		Time		Temperature	
		Default value	Modify	Default value	Modify
Workdays	Sunrise	06:00		20°C	
	Morning	08:00		15°C	
	Nooning	11:30		15°C	
	Afternoon	12:30	Rotate handwheel	15°C	Rotate handwheel
	Evening	17:00		22°C	
	Night	22:00		15°C	
Weekends	Sunrise	06:00		20°C	
	Night	22:00		15°C	

Advanced Setting (Usually for Professional Technicians)

Choose "advanced setting" on menu page and put in password 123456 to enter advanced setting page, set parameters then press " ⏻ " to save and exit.

Meaning	◯ Rotate handwheel	Default value
Sensor Mode	Built-in Sensor / Floor Sensor / Built-in Control&Floor Limitation	IN
Buit-in Sensor Calibration	−5~5°C	−3°C
Buit-in Max Setting Value	5~95°C	50°C
Floor Max Setting Value	10~95°C	50°C
Limitation Value	20~95°C	35°C
Output Jitter Control	0~5°C	1°C
Anti−Freeze Protection	ON/OFF	OFF
Linkage Mode	Noninverting / Inverting / Inverting / Inverting and Anti-Freeze closed	Noninverting
Linkage Time Delay	0~5Min	0Min
Weekday Mode	Monday to Friday/Monday to Saturday /Monday to Sunday/	2−day
Boot Type	Function Off/Function On/Function Saved	OFF
Temperature Unit	°F/°C	°C
Child Lock Type	None / Lock All / All but power	None
Control Mode	All/Air/Floor	Floor
Cloud Region	CN/US/EU	CN
Reset All Settings	/	/

Sensor failure

Please select work mode of sensors correctly. When it shows E0/E1 error, thermostat will stay power-off till the error is eliminated.E0: built-in sensor is short-circuited or disconnected. E1: floor sensor is short-circuited or disconnected.

Timer Task Setting (Fan Coil/Integrated)

Press" ◎ "to enter the menu . Turn the knob" ◎ ", choose "Auto Mode", and then choose "Schedule". Set the parameters by turning the knob, then press " ⊞ " to save and exit to home page.

‹ Schedule Task	
Time Setting	00:00 ›
Repeat	Everyday ›
Action	OFF ›

Dimensions (Unit: mm)

Floor Heating
#EP
#WP
#WPB
#AC2

11.2 32.6 51 51

Integrated
#AC2-485
#Ac4
#AWY

11.2 24 64 66

Mounting Steps

The thermostat adopt pre-guide and limited snap-fit design. It is easy to mount.

1）Release front cover by inserting a head screw-driver into bottom crack.

2）Insert the wires and then fix these wires with screws. Suggested wire-stripping length is 7-9mm.

3）Mount backing plate into wall-cassette, put screws and then fix thermostat. Make sure that the thermostat is fixed without deformation. Suggested torque is 0.2~0.4N.m (2.0~4. 1kgf.cm).

4）Re-mount the front cover via snap-fit connection.

Connecting Diagram

The thermostat operates in full capacity in areas with the altitude of less than 2500 above sea level. Power rating of external load should be less than or equal to 80% rated power of the thermostat in areas with altitude of 2500m to 4200m.

Floor Heating

#TCR7-WIFI-EP
#TCR7-EP

#TCR7-WIFI-WP
#TCR7-WP
#TCR7-WIFI-WPB
#TCR7-WPB

Fan Coil

#TCR7-WIFI-AC2
#TCR7-AC2

#TCR7-WIFI-AC2-485
#TCR7-AC2-485

#TCR7-WIFI-AC4
#TCR7-AC4

Integrated

#TCR7-WIFI-AWY
#TCR7-AWY