



9003V Installation Instructions

Customer Service: 1-877-671-7011
www.allegion.com/us

⚠ Caution: Edges of aluminum parts may be sharp. Wear gloves and handle with care.

1. **Measure the Door Frame Head:** Determine the full width of the door frame opening.
2. **Cut the Top Gasketing Piece:** Trim the part to the full width. Let the gasketing extend slightly beyond the metal retainer for a tight seal.
3. **Close the Door:** Allow the self-closing door to shut fully.
4. **Position the Gasketing:** Press the gasketing lightly against the door for a good seal.
5. **Attach:** Use the provided sheet metal screws in the holes or slot centers.
Do not tighten screws fully—allow room for adjustment.
6. **Install Side Jambs:** Measure door sides and attach side gasketing using steps 2–5. Side pieces have slotted holes for easier alignment.
7. **Tighten All Screws:** Once properly aligned, tighten all fasteners securely.
8. **Test Door Operation:** Open and close the door to confirm that gasketing doesn't interfere with self-closing or latching. Adjust as needed.



Positive Pressure Tested Gasketing Materials for Fire Doors. Intended for Application to/ with listed steel frames and/or classified steel covered composite, hollow metal type fire doors rated up to 3 hours, wood and plastic covered composite type fire doors rated up to 1-1/2 hours, and wood core type fire doors rated up to 20 minutes. Meets UL10B, UL10C and CAN4-S104-2010 Category J .17L5 9903