

Tender text Article number 353-652521

Presence detector P49MR, DALI-2, BMS, 12-13 m, for surface mounting, white



Proposed product description according to BIPS 4.7.9

Presence detector P49MR, DALI-2, BMS, 12-13 m, for surface mounting, white

SPECIFICATIONS

Configuration BMS
Detector technology PIR

Mounting method surface mounting Input voltage via the DALI bus

Detector output DALI-2

Light intensity range 0 lux – 10360 lux

Maximum current consumption 10 mA
Detection angle 360°

Detection range (PIR) ø 12 m from a height of 3 m

Ambient temperature $-25 - +40 \,^{\circ}\text{C}$ Mounting height $2 - 3.5 \, \text{m}$ Impact resistance IK02

Protection degree IP54

Marking CE

Proposed functionalities description according to BIPS 4.7.10

Mounting method

The detector is suitable for surface mounting on all types of ceilings.

Configuration

The detector is DALI-2 certified (in accordance with EN/IEC 62386-301/302/303/304) and must be connected to a DALI bus of a DALI-2 application controller (BMS system). The detector is to be commissioned via the BMS software.

Configuration app

Local adjustment of the sensitivity in 4 levels can be configured via the app using 2-way Bluetooth® communication between a smartphone or tablet and the detector. The firmware of the detector can be updated via the app.



Bluetooth® communication

Via the BMS software Bluetooth® communication is to be disabled.

PIN code

The detector can be protected with a 4-digit PIN code in the app to prevent others from controlling the detector or modifying its settings.

Wire connectors

The wires are connected using plug-in terminals.

Event log

The event log in the app shows all the changes you made to the settings of a specific detector.

Documentation

Documentation is available in digital format on an online portal. This portal also allows to store, review and share settings in PDF and/or Excel format. The detectors can be organised into specific projects or groups. Existing detector settings can be used as a template for new detectors.

Detection range

The detection range is documented in accordance with EN/IEC 63180.