



25 Interchange way, Vaughan, Ontario. L4K 5W3
Phone: 905.660.4655; Fax: 905.660.4113
Web: www.mircom.com

INSTALLATION AND MAINTENACE INSTRUCTIONS

MIX-4003-R Relay Base

CAUTION / ATTENTION
DO NOT PAINT OR ALTER
FACTORY APPLIED FINISH IN ANY WAY
NE PAS PEINDRE OU MODIFIER
LA FINITION ORIGINALE

ABOUT THIS MANUAL

This manual is included as a quick reference for installation and should be left with the owner/operator of this equipment. For further information on the use of this device with a FACP, please refer to the panel's manual.

Note: This manual should be left with the owner/operator of this equipment.

RELAY BASE DESCRIPTION

The MIX-4003-R relay base is designed to meet UL268/ULC S529 requirements for smoke detector, UL521/ULC S530 requirements for heat detector.

The MIX-4003-R must be used with a compatible MGC control panel. The device can control one independent circuit while using one address.

The MIX-4003-R provides one form C (SPDT) contact rated at 2A at 30Vdc, or 0.5A at 125Vac and a compatible panel can switch discrete contacts by code command. Circuit connections to the relay contacts are not supervised by the base. MIX-4003-R supports group activation capability for fast reaction time.

Figure 1 MODEL FRONT AND SIDE VIEW
WITH MIX-4000 SERIES DETECTOR




Table 1 SPECIFICATION

Operating temperature	0°C to 49°C (32°F to 120°F)
Humidity range	0% to 93%
SLC Standby Current	1.16 mA
SLC Alarm Current	1.18 mA
Base Diameter	182mm [7-3/16 in]
Base Height	32mm [1-1/4 in]
Terminal wire gauge	12-22 AWG

KEY COMPONENT

Figure 2 RELAY BASE ASSEMBLY COMPONENTS





Figure 3 MIX-4000 SEREIS DETECTOR




A mounting plate in figure 2 is mounted first on the electrical box and all wiring is done on integral screw connectors. The connections are apparent and can be visually inspected before the sounder base itself is mounted. Then, the enclosure containing the electronics, the sounder and the detector base can plugged-in and secured.

Note: This device should be installed as per applicable requirements of the authorities having jurisdiction.

WIRING

Before installing this device seek guidance from the compatible control panel instructions for the device operation modes and the configuration requirements. It is recommended to remove power from SLC and NAC lines before performing installation.

Figure 4 WIRING TABS



Use the information in this document to determine the total current draw of the devices. The total current draw of the devices must not exceed the NAC output capacity of the panel. In all cases, the installer should consider the voltage drop to ensure that the last device on the circuit operates within its rated voltage. Please consult fire panel installation manual for guidance on wire resistance and length. For maximum strobe operating current, please refer to Table 4.

Do not loop signal circuit field wires around terminals. Electrical supervision requires wire run to be broken at each end.





Figure 5 DEVICE CONNECTION



Note: Wiring must be in accordance with CSA C22.1, Canadian Electrical Code, Part I, Safety Standard for Electrical Installations, section 32 and/or NFPA 70.

CAUTION

FOR SYSTEM SUPERVISION, FOR ALL TERMINAL TAPS, DO NOT USE LOOPED WIRE UNDER TERMINALS. BREAK WIRE RUN TO PROVIDE SUPERVISION OF CONNECTIONS.

ATTENTION

NE PAS UTILISER DE FILS EN BOUCLE SOUS LES BORNES. POUR FOURNIR UN BON SUIVI DES CONNEXIONS. INTERROMPRE LA CONTIUITÉ DES CÂBLES.


MOUNTING

MGC recommends spacing speaker strobe appliances in compliance with CAN/ULC S524 and/or NFPA72.

The mounting plate is compatible with 3" by 2" single gang device boxes, 3-3/4" by 4" double gang boxes, 4" by 2" single gang utility boxes, standard 4" by 4" boxes, and standard 4" octagon boxes.

1. Attach the mounting plate to electrical box with two mounting #8-32 x 3/4" screws.
2. Slide down the sounder base enclosure until the connection blades touch the clips on the mounting plate.
3. Secure the mounting plate with securing M3 x25 mm screws.


Figure 6 MOUNTING DIAGRAM



MOUNTING DETECTOR

If the detector type and address has be visible from the outside, break the address tab inside the detector base and insert it in the outer rim of the base. See figures 7.

Figure 7 ADDRESS TAB INSERT



The detector can then be placed on the top base using the following steps (figure 8):

1. Position the detector centrally on its adapter base ensuring it is level.
2. Rotate clockwise applying gentle pressure. The detector will drop into its keyed location.
3. Continue to rotate clockwise a few degrees until the detector has fully engaged in the adapter base.
4. When the detector is firmly engaged, check the alignment of the raised reference marks on the detector and on the base (figure 9).

Figure 8 MOUNTING DETECTOR





Figure 9 DETECTOR ALIGNMENT MARK



Model Numbers

MIX-4003-R 4000 SERIES RELAY BASE

Accessories

4000 SERIES DETECTORS:

MIX-4010	Non-isolated photoelectric detector
MIX-4011	Non-isolated photoelectric detector Rev7
MIX-4010-ISO	Isolated photoelectric detector
MIX-4011-ISO	Isolated photoelectric detector Rev7
MIX-4020	Non-isolated photoelectric/heat detector
MIX-4021	Non-isolated photoelectric/heat detector Rev7
MIX-4020-ISO	Isolated photoelectric/heat detector
MIX-4021-ISO	Isolated photoelectric/heat detector Rev7
MIX-4030	Non-isolated heat detector
MIX-4030-ISO	Isolated heat detector