


## REFLECTOR SIDE EXTENSION KIT INSTALLATION FOR GAS-FIRED LOW-INTENSITY RADIANT TUBE HEATERS

### OPTION CD28 FOR MODELS VZ AND VZH

**NOTE:** If the installation requires side extensions to reflect heat in a desired direction, refer to these instructions along with the installation manual provided with the heater for complete heater installation instructions.

- Refer to the installation manual provided with the unit for important safety information.
- Ensure that all components shown in **Figure 1** and listed in **Table 1** are available before beginning installation.



**Figure 1. Reflector Side Extension Installation (Refer to Table 1)**

**Table 1. Reflector Side Extension Kit (PN 02712700) Components**

Item No.	Component	PN (Quantity)
1	Support bracket, reflector side extension	01329911 (2)*
2	Reflector side extension, 96-inch (244 cm)	01368000 (1)
3	Retainer clip	02751200 (2)
4	Sheet metal screw, #8 × 3/8	94118106 (2)

\*Quantity is two (2) per side extension. Use additional support brackets as necessary for installation locations with high air movement.

1. Install support brackets (1) as shown in **Figure 1** and tighten wingnut on each bracket to secure bracket to tube.
2. Cut notch(es) as necessary in reflector side extension (2) as shown in **Figure 1** to provide clearance for suspension hardware.
3. Slide bottom of reflector side extension (2) through support brackets (1) as shown in **Figure 1** and secure retainer clips (3) at top of side extension to reflector using sheet metal screws (4).

Specifications and illustrations subject to change without notice or incurring obligations.

Latest version of this manual is available at [www.reznorhvac.com](http://www.reznorhvac.com).

©2024 Nortek Global HVAC LLC, O'Fallon, MO. All rights reserved.

VZ-VZH-CD28 (06-24) 1047440-0



**DO NOT DESTROY. PLEASE READ CAREFULLY. KEEP IN A SAFE PLACE FOR FUTURE REFERENCE.**