



Manual

DISTRIBUTOR OF SALUS CONTROLS:

QL CONTROLS Sp. z o.o., Sp. k.
Rolna 4,
43-262 Kobielice,
Poland

Importer:

SALUS Controls Plc
Units 8-10 Northfield Business Park
Forge Way, Parkgate, Rotherham
S60 1SD, United Kingdom



Computime



www.salus-controls.eu

SALUS Controls is a member of the Computime Group.

Maintaining a policy of continuous product development SALUS Controls plc reserve the right to change specification, design and materials of products listed in this brochure without prior notice.



Introduction

A programmable timers EP110, EP210, EP310 are used to switch ON/OFF the heating system, the hot water or any electronical device like pumps or lights as needed. It works by controlling with programmed schedules (24H or 5-2 schedule types) which contain 3 time programs each.

Product Compliance

EU Directives: 2014/30/EU, 2014/35/EU and 2011/65/EU.
Please check www.saluslegal.com for the full information.



Safety Information

Use in accordance with the EU and national regulations. For indoor use only. Keep your device completely dry. This product must be installed by a competent person and in accordance with all the EU and national regulations.

Technical data


	EP110	EP210	EP310
Power Supply	230 V AC	230 V AC	230 V AC
Max load	3 (1) A	3 (1) A	3 (1) A
Output	NO / COM / NC volt free	2 x SPDT 230V AC	3 x SPDT 230V AC
Number of channels	1	2	3
Dimensions [mm]	120 x 98 x 27	120 x 98 x 27	120 x 98 x 27

Buttons functions

Button	Function
MODE	Select operating mode (ON, ONCE, AUTO, ADV, OFF)
+Hr	Activate/deactivate BOOST function
 	Turn on the LCD backlight Press for 3 sec to activate HOLIDAY mode
	Increases the selected setting
	Decreases the selected setting
SELECT	Select a clock or programme setting
SET	Sets a clock or programme setting
	Reset to Factory settings


LCD display icon description

EP110




1. Device operation (animated icon)
2. Number of hours for the BOOST function
3. ON/OFF indicator
4. Work mode
5. AM/PM
6. Holiday mode
7. Clock
8. The day of the week
9. Program number

EP210



1. Zone I operation mode
2. Day of the week
3. Program number
4. ON/OFF indicator
5. Zone II operation mode
6. Zone II work status
7. AM/PM
8. Number of hours for the BOOST function for Zone II
9. Number of hours for the BOOST function for Zone I
10. Zone I work status
11. Clock
12. Holiday mode

EP310



1. Zone I operation mode
2. Zone II operation mode
3. Zone III operation mode
4. Program number
5. ON/OFF indicator
6. Holiday mode
7. AM/PM
8. Number of hours for the BOOST function for Zone III
9. Zone III work status
10. Zone I work status
11. Number of hours for the BOOST function for Zone II
12. Zone II work status
13. Number of hours for the BOOST function for Zone I
14. Clock
15. Day of the week

Jumpers settings

The parameters can be changed using the jumpers on the back of the device.



Note: Disconnect power supply before working with the device.

EP110 / EP310		EP210		Description
		P	G	System selection: P - systems work separately G - HW dependent on CH (CH switching causes switching HW)
5-2	24 h	5-2	24 h	Schedule mode selection: • business days + weekend (5-2) • each day separately (24 h)
wył.	wł.	wył.	wł.	Memory support






Note: After changing the settings, it is necessary to reset the device using  RESET button.

Wiring diagram

All wire connectors are located on the back of the device. To remove the cover, loose two screws located at the bottom of the device and then remove the back of the housing.



Note: Disconnect power supply before working with the device.




Setting time and date

1. Hold SELECT and SET buttons at the same time for 3 seconds. The display shows 12:00.
2. Press  or  button to choose the time format (12hr or 24hr). The display shows 12 hr.
3. Confirm selection using SELECT button. The display shows 24 hr.
4. Press  or  button to set hour. The display shows 00:00.
5. Confirm selection using SELECT button. The display shows 13:00.
6. Press  or  button to set minutes. The display shows 13:00.
7. Confirm selection using SELECT button. The display shows 13:56.
8. Press  or  button to set year. The display shows 4 16.
9. Wybór zatwierdz przyciskiem SELECT. The display shows 4 17.
10. Press  or  button to set month. The display shows m 01.
11. Confirm selection using SELECT button. The display shows m 11.
12. Press  or  button to set day. The display shows d 01.
13. Confirm selection using SELECT button. The display shows d 15.
14. Press  or  button to set the summer time change function DST*. Press the SET button to end the time/date setting. The display shows d 5t.


*When the Daylight Saving Time (DST) function is on (ON), controller will automatically change the time from winter to summer.

Operation modes


There are 5 different work modes available. Using **MODE** button, you can change modes directly according to the following sequence:




ON mode




Controller works continuously:



ONCE mode




Controller works from the beginning of Program 1 to the end of Program 3:



AUTO mode



Controller works according to previously defined programs:




ADV mode

The ADV mode can be activated if the ONCE or AUTO mode is selected when it is activated.




To turn the ADV mode on or off, press the **MODE** button for 3 seconds. The mode of operation of the mode has been presented in the chart below



OFF mode



Controller is turned off.




Programming EP110 controller

You can create 3 independent time schedules. There are 2 work models to choose from:

- business days + weekend (5-2)
- each day separately (24 hours)

Controller works by default in working days + weekend mode (5-2).

To set each day separately (24 hours), change the jumper position according to the diagram on previous page.




Programming EP210/EP310 controller

You can create 3 independent time schedules for each zone. There are 2 work models to choose from:

- business days + weekend (5-2)
- each day separately (24 hours)


Controller works by default in working days + weekend mode (5-2).

To set each day separately (24 hours), change the jumper position according to the diagram on previous page.




HOLIDAY mode

Holiday mode is used to disable all controller outputs for a specified number of days (up to 31 days). When HOLIDAYS mode is active, aircraft icon will appear on the display.



Disabling the Holiday mode



BOOST Function

BOOST function extends the active program time to 1-9 hours. Press **+Hr** button to activate BOOST mode (each press of the button extends the active program by 1 hour).



Factory Settings

If you made a mistake, want to change controller parameters or return to its factory settings, you can reset controller with **RESET** button.

Note: RESET button will permanently delete your existing settings.

