

Installation Guide and Support Manual

PHOENIX

Phase Converters

GP75PL





GENERAL SPECIFICATIONS	
HP	75
KW	56
KVA	65.06
HZ	50/60
ENCL	TEFC/NEMA 4
FRAME	365T
IDLER WEIGHT	873
PANEL WEIGHT	80

CONSTRUCTION, DIMENSIONS, WEIGHT	
ELECTRICAL PANEL	
ENCLOSURE TYPE	NEMA 4
ENCLOSURE CERTIFICATIONS	UL 508A (CSA C22.2 No. 14-13.), TUV, CE.
COLOR	Light Gray
HEIGHT	26
WIDTH	26
DEPT	10
MOUNTING	WALL MOUNT

SINGLE PHASE ELECTRICAL SPECS	
VOLTAGE INPUT	208-250V
MOTOR LOAD BREAKER Minimum Size	125
MOTOR LOAD BREAKER Maximum Size	350
SERVICE KVA Minimum Size	100
SERVICE AMPS Minimum Size	416.7
COPPER WIRE Minimum Size	4/0

THREE PHASE ELECTRICAL SPECS	
VOLTAGE OUTPUT	208-230 Volts Delta
MAX OUTPUT INDUCTIVE LOAD AMPS	182
MAX OUTPUT RESISTIVE LOAD AMPS	105
VOLTAGE BALANCING	+/- 2%
WIRE SIZE MIN Idler/Generator	1/0
LARGEST SPINDLE MOTOR START	37.5
LARGEST COMPRESSOR LOAD START	30
TOTAL COMBINED HORSEPOWER RUN	75

- Optional Feature
- 208, 460 Volt Output (includes transformer)
 - AutoStart and AutoOff with load detection
 - PL Model (includes Start and Stop with Built-in Mag Starter)
 - GPX Model (includes WFI Cloud Controls, Timers, Energy Monitor)
 - Wireless Remote ON/OFF

PHOENIX PHASE CONVERTERS

800-417-6568

CAUTION

READ INSTRUCTIONS BEFORE OPERATING

READ FIRST - BEFORE INSTALLATION

- **Most important step to know.**
- NEVER Start the phase converter with a load, this includes transformers.
- Make sure you have the incoming service to start the phase converter, call your electric company verify the KVA size of the transformer, that KVA number should be larger then the HP of the idler motor.
- **DO NOT use WIRE NUTS for any connection, use the bolt down lugs. Check all make sure all connections even factory connections to the power block are secure, also recheck connections after a few week of using the converter.**
- **When powering up the unit, if the idler does NOT come up to FULL SPEED, then shut the phase converter down right away. If you don't understand then call us or a qualified electrician. if you do not turn the unit off you have a chance to damage the idler motor that will not be covered under warranty.**
- Must be installed by a license industrial electrician, our guidelines are not to supersede local and state laws.

Power requirements

- You will need to use a **motor load** type breaker. NOT a quick blow or trip breaker.
- Sizing a breaker for a single machine with an inductive load (motors) double the amps size of the machine. Example if the equipment pulls 20 amps use a 40 amp breaker.
- Sizing the equipment for multiple machine double the amp of the largest machine and add the the other machine that will run at the same time. Example; 20 AMP Lathe. 9 amp saw, 6 amp milling machine. $20 \times 2 = 40 + 9 + 6 = 45$ amps, use the next standard size breaker which would be 50 Amps two pole breaker.
- Use the chart to make sure you don't go over or under the Minimum and maximum size allowed. For rural areas increase the minimum size breaker by 20% Click on the next picture to see this chart.

GP75

WIRE AND BREAKER SIZES	
SINGLE PHASE	4/0 AWG Copper under 50 feet
IDLER MOTOR	1/0 AWG COPPER
BREAKER/FUSE	125 MIN / 350 MAX

Mounting the Phase Converter Panel

Mount the enclosure first, to a non-vibrating surface, there are two options provided for mounting, next install the back plate with the four nuts provided. Mounting the phase converter panel near the breaker panel is recommended the larger wire is you single phase line, that is best to keep as short as possible. Every 50 feet you will need to increase the size of the single phase wire.



Additional mounting brackets and hardware are inside the enclosure.




Indoor or outdoor enclosure



CONNECTING THE IDLER MOTOR WIRES


THIS IS JUST A ILLUSTRATION OF WHAT WIRES GET CONNECTED TOGETHER, **DO NOT USE WIRE NUTS**, USE BOLT DOWN LUGS


IF YOU HAVE 9 LEADS AT
THE MOTOR CLICK HERE



IF YOU HAVE 12 LEADS AT
THE MOTOR CLICK HERE







**Dimensions for
Nema 4 Enclosure
For GP50, GP60
GP75, GP100**

75 HP Rotary Phase Converter Components

Item Number	Description (Click on the description to visit the link to that item)	Quantity in Model	Price	SKU# (Click on 3D viewing)
7	Relay	1	47.00	GP90-66
4	Complete Run Bank Assembly - Prewired	1	490.00	*
3	3 Pole Contactor 75 amp - 230V	1	182.90	C375C
1	9 Bank Start and Run Capacitor Holder Only with Base	1	239.00	CB409HO
2	3 Phase Power Block	1	535.00	GPB1003
5	630 MFD 220V Start Capacitor	3	24.14	PTMJ630
6	100 MFD 370V Run Capacitor	1	26.00	TRC100
*	Complete Capacitor Start Bank Assembly - Prewired	1	490.00	CB30230
*	Complete Back Plate Assembly - Prewired PL Model. (with Start and Stop Button)	1	4421.00	CBA75PL
*	Complete Panel with NEMA 4 Enclosure - Prewired PL Model (with Start and Stop Button)	1	4532.00	GP75PLPO
*	Idler Motor	1	4732.00	*
*	Complete Unit Phase Converter Panel (PL Model) and Idler/Generator Motor	1	9486.00	GP75PL

