



MASTECH MS6208BCBGLO Non-contact Type Tachometer User Guide

[Home](#) » [MASTECH](#) » MASTECH MS6208BCBGLO Non-contact Type Tachometer User Guide 

MASTECH®



700019245 July 2021 Rev. 2.0

Specifications are subject to change without notification.

Quick Start Guide

MS6208B

Non-contact Type Tachometers

CAT III 600V

1 YEAR
LIMITED WARRANTY



The special attention should be paid when using the test and measurement instrument because the improper usage may cause electric shock and damage the equipment.

- Use proper measurement category (CAT), voltage, and amperage rated probes, test leads, and adapters for the measurement.
- Do not use or store the device around explosive gas, vapor, or under high temperature and humidity.
- When handling the test probes and crocodile clips, keep your fingers behind the physical guard.
- Examine the measuring test leads (if present) before use. Any element of which the insulation deteriorates (even partially), replace them with proper functional test leads.
- Connect the common test lead before the live test lead and remove the live test lead before the common test lead.
- Before measuring current, make sure the instrument fuses available and disconnect the power supply to the circuit test
- Remove the batteries if the device is not used for an extended period of time, or if stored in temperatures above 45 °C. If the batteries are not removed, battery leakage can damage the device.

Contents

- [1 Contents](#)
- [2 Specifications](#)
- [3 Data Storage](#)
- [4 Measurement](#)
- [5 Documents / Resources](#)
- [6 Related Posts](#)


Contents



Specifications

Range	Resolution	Accuracy
-------	------------	----------


Measurement	50~99.99 RPM	0.01 RPM	$\pm(0.03\%+2)$
	100~9999.9 RPM	0.1 RPM	$\pm(0.03\%+2)$
	10000~99999 RPM	1 RPM	$\pm(0.03\%+2)$



Data Storage



Measurement



EMEA MGL EUMAN S.L. C/ Picu Castiellu, Parcelas i1-i4 33163, Argame Morcín, Asturias, Spain Tel: +34 985-08-18-70 Email: cs.emea@mgl-intl.com	MEXICO & LATAM MGL LATAM S.A DE CV Colonia Industrial Vallejo Del. Azcapotzalco 02300, Mexico D.F Tel: +1 833-533-5899 Email: cs.latam@mgl-intl.com
USA MGL AMERICA, INC. 2810 Coliseum Centre Drive, Ste. 100 Charlotte, North Carolina 28217 USA Tel: +1 833-533-5899 Email: cs.na@mgl-intl.com	APAC MGL APPA Corporation Flat 4-1, 4/F, No. 35, Section 3 Minqun East Road. Taipei, Taiwan. Tel +886 2-2508-0877 Email: cs.apac@mgl-intl.com
UNITED KINGDOM MGL GROUP U.K. LIMITED 14 Weller St, London, SE1 1QU, UK Tel: +34 985-08-18-70 Email: cs.uk@mgl-intl.com	

SKU Number: MS6208BCBGLO



<http://www.mastech-group.com/support.php?n=0>



Documents / Resources



[MASTECH MS6208BCBGLO Non-contact Type Tachometer](#) [pdf] User Guide
MS6208BCBGLO, Non-contact Type Tachometer, MS6208BCBGLO Non-Contact Type Tachometer, Type Tachometer, Tachometer

Manuals+.