



Megger MPU690 Proving Unit for Voltage Testers User Guide

[Home](#) » [Megger](#) » Megger MPU690 Proving Unit for Voltage Testers User Guide 

Contents

- [1 Megger MPU690 Proving Unit for Voltage Testers](#)
- [2 Introduction](#)
- [3 Instructions](#)
- [4 Safety Warnings](#)
- [5 End of life disposal](#)
- [6 Specification](#)
- [7 Documents / Resources](#)
 - [7.1 References](#)
- [8 Related Posts](#)

Megger[®]

Megger MPU690 Proving Unit for Voltage Testers



Introduction

The MPU690 Proving Unit safely generates high voltages to energise 2 pole voltage testers thus allowing verification of their correct operation. The unit will also test voltage testers that use a pygmy lamp. Features include automatic power on when voltage tester probes are inserted into the output terminals, 50Hz test voltage to simulate AC mains supply and a magnetic back to the case.

Instructions

To activate the MPU690 firstly insert the voltage tester flying lead probe into the right hand terminal followed by the voltage tester fixed probe into the left hand terminal. Gently apply and maintain pressure to the left hand probe to activate the internal power switch. The test voltage is transmitted to the voltage tester. The test voltage LEDs will automatically ramp up to 690 volts and then slowly ramp back down 690 V – 400 V – 230 V – 100 V – 50 V – OFF (to re-test slightly lift the left-hand probe and re-apply the pressure).

The advantages of the auto test function are:

1. Individual voltages are applied at five key voltage test points with significant battery savings as power is automatically switched off when the test is completed.
2. Once the voltage tester has been proved to be correctly functioning you may carry out testing circuits.
It is recommended that a voltage tester be verified regularly.

Safety Warnings

Safety Warnings must be read and understood before instrument is used. As this unit generates voltages up to

690 volts caution should be exercised, hands should remain behind guards of applied voltage detectors.

- Never connect to installation wiring.
- Only voltage testers should be connected to the proving unit.
- Never insert wire, nails or screwdrivers into either terminal.
- Do not force objects into the left hand terminal to enable permanent operation.
- Ensure the unit is free from moisture, grease and dust; clean unit with a soft dry cloth only.
- Do not use if there is any damage to the MPU690.
- The battery cover must be in place whilst conducting tests.

Note: This instrument must only be used by suitably trained and competent persons.

Safety Warnings cont.

CATIV Measurement category IV: Equipment connected between the origin of the low-voltage mains supply outside the building and the consumer unit.

CATIII Measurement category III: Equipment connected between the consumer unit and the electrical outlets.

CATII Measurement category II: Equipment connected between the electrical outlets and the user's equipment.

End of life disposal

WEEE Directive

- The crossed out wheeled bin symbol on the instrument and on the batteries is a reminder not to dispose of them with general waste at the end of their life. Megger is registered in the UK as a
- Producer of Electrical and Electronic equipment. The registration no is; WEE/DJ2235XR.
- Users of Megger products in the UK may dispose of them at the
- end of their useful life by contacting B2B Compliance at www.b2bcompliance.org.uk or by telephone on 01691 676124.
- Users of Megger products in other parts of the EU should contact their local Megger company or distributor.

Battery Disposal

- Batteries in this product are classified as Portable Batteries under the Batteries Directive. Please contact Megger Ltd for instructions on the safe disposal of these batteries.
- For disposal of batteries in other parts of the EU contact your local distributor.
- Megger is registered in the UK as a producer of batteries. The registration number is BPRN01235. For Further information see www.megger.com

Specification

- Output Voltage:
- Power Supply:
- Operating Conditions:
- Number of tests:
- 50 – 690 volts in five steps
- 6 x AA / LR06 alkaline batteries

- -10 to +40°C, 70%
- RH EN61010
- pollution degree 2
- Approximately 550

Megger Limited Archcliffe Road, Dover, CT17 9EN
United Kingdom Tel +44 (0) 1304 502100
Email sales@megger.com Web www.megger.com

Documents / Resources

<div>Megger</div> <div>MPU690 Proving Unit</div> <div>User Guide</div>	<div>Megger MPU690 Proving Unit for Voltage Testers [pdf] User Guide</div> <div>MPU690, Proving Unit for Voltage Testers, Proving Unit</div>
--	--

References

- [B2B B2B Compliance - The not-for-profit WEEE Compliance scheme](#)
- [M. Electrical test equipment | power station to plug | Megger](#)