



## METER ES-2 INTEGRATOR SENSOR User Guide

[Home](#) » [METER](#) » METER ES-2 INTEGRATOR SENSOR User Guide 



# METER

## Contents

### 1 ES-2 INTEGRATOR GUIDE

#### 1.1 SENSOR DESCRIPTION

#### 1.2 APPLICATIONS

#### 1.3 ADVANTAGES

#### 1.4 PURPOSE OF THIS GUIDE

#### 1.5 COMPATIBLE FIRMWARE VERSIONS

#### 1.6 SPECIFICATIONS

#### 1.7 COMMUNICATION SPECIFICATIONS

#### 1.8 PHYSICAL SPECIFICATIONS

#### 1.9 ELECTRICAL AND TIMING CHARACTERISTICS

#### 1.10 EQUIVALENT CIRCUIT AND CONNECTION TYPES

#### 1.11 PRECAUTIONS

#### 1.12 SURGE CONDITIONS

#### 1.13 POWER AND GROUNDING

#### 1.14 CABLES

#### 1.15 SENSOR COMMUNICATIONS

#### 1.16 SDI-12 INTRODUCTION

#### 1.17 DDI SERIAL INTRODUCTION

#### 1.18 INTERFACING THE SENSOR TO A COMPUTER

#### 1.19 METER SDI-12 IMPLEMENTATION

#### 1.20 SENSOR BUS CONSIDERATIONS

#### 1.21 SDI-12 CONFIGURATION

#### 1.22 SDI-12 TIMING

#### 1.23 COMMON SDI-12 COMMANDS

#### 1.24 IDENTIFICATION COMMAND (a!)

#### 1.25 CHANGE ADDRESS COMMAND (aAB!)

#### 1.26 ADDRESS QUERY COMMAND (?!)

#### 1.27 COMMAND IMPLEMENTATION

#### 1.28 PARAMETERS

#### 1.29 DDI SERIAL COMMUNICATION

#### 1.30 DDI SERIAL TIMING

#### 1.31 DDI SERIAL CHECKSUM

#### 1.32 CUSTOMER SUPPORT

#### 1.33 REVISION HISTORY

### 2 Documents / Resources

#### 2.1 References

### 3 Related Posts

## ES-2 INTEGRATOR GUIDE

### SENSOR DESCRIPTION

The ES-2 sensor is an accurate tool for monitoring electrical conductivity and temperature in a pipe or tank. The ES-2 measures temperature using an onboard thermistor and electrical conductivity using a stainless steel electrode array. The integrated 4-probe electrical conductivity transducer accurately senses EC up to 120 dS/m. The electronic circuitry is encapsulated in a marine-grade epoxy to protect the sensor in corrosive environments.

For a more detailed description of how this sensor makes measurements, refer to the [ES-2 User Manual](#).


### APPLICATIONS

- Tank monitoring
- Pipe monitoring

- Salt management

## ADVANTAGES

- Three-wire sensor interface: power, ground, and data
- Digital sensor communicates multiple measurements over a serial interface
- Robust thermistor for accurate temperature measurements
- Low-input voltage requirements
- Low-power design supports battery-operated data loggers
- Robust epoxy encapsulation resists corrosive environments
- Supports SDI-12 or DDI serial communications protocols
- Modern design optimized for low-cost sensing



**Figure 1 ES-2 sensor**

## PURPOSE OF THIS GUIDE

METER provides the information in this integrator guide to help ES-2 customers establish communication between these sensors and their data acquisition equipment or field data loggers. Customers using data loggers that support SDI-12 sensor communications should consult the data logger user manual. METER sensors are fully integrated into the METER system of plug-and-play sensors, cellular-enabled data loggers, and data analysis software.

## COMPATIBLE FIRMWARE VERSIONS

This guide is compatible with firmware versions 3.89 or newer.

### **METER Group, Inc. USA**

2365 NE Hopkins Court, Pullman, WA 99163

T +1.509.332.2756 F +1.509.332.5158

E [info@metergroup.com](mailto:info@metergroup.com) W [metergroup.com](http://metergroup.com)

## SPECIFICATIONS

### MEASUREMENT SPECIFICATIONS

<b>Temperature</b>	
Range	-40 to 60 °C
Resolution	0.1 °C
Accuracy	±1 °C
<b>Bulk EC</b>	
Range	0–120 dS/m
Resolution	0.001 dS/m
Accuracy	±0.01 dS/m or ±10% (whichever is greater)

## COMMUNICATION SPECIFICATIONS

<b>Output</b>
DDI serial or SDI-12 communication protocol
<b>Data Logger Compatibility</b>
METER ZL6 data loggers and any data acquisition system capable of 3.6- to 15-VDC power and serial or SDI-12 communication

## PHYSICAL SPECIFICATIONS

<b>Dimensions</b>	
Length	10.9 cm (4.3 in)
Diameter	2.4 cm (0.95 in)
Thread	1/2-in National Pipe Thread
<b>Operating Temperature Range</b>	
Minimum	−40 °C
Maximum	60 °C
NOTE: Sensors may be used at higher temperatures under certain conditions; contact Customer Support for assistance.	
<b>In-Line Pipe Connector Type</b>	
1-in Tee socket pipe fitting	
<b>Cable Length</b>	
5 m (standard) 75 m (maximum custom cable length)NOTE: Contact Customer Support if a nonstandard cable length is needed.	
<b>Connector Types</b>	
3.5-mm stereo plug connector or stripped and tinned wires	

#### ELECTRICAL AND TIMING CHARACTERISTICS


<b>Supply Voltage (VCC to GND)</b>	
Minimum	3.6 V
Typical	NA
Maximum	15.0 V
<b>Digital Input Voltage (logic high)</b>	

Minimum	2.8 V
Typical	3.6 V
Maximum	5.0 V
<b>Digital Input Voltage (logic low)</b>	
Minimum	-0.3 V
Typical	0.0 V
Maximum	0.8 V
<b>Digital Output Voltage (logic high)</b>	
Minimum	NA
Typical	3.6 V
Maximum	NA
<b>Power Up Time (SDI-12)</b>	
Minimum	100 ms
Typical	200 ms
Maximum	250 ms
<b>Power Up Time (SDI-12, DDI disabled)</b>	
Minimum	NA
Typical	125 ms
Maximum	NA
<b>Power Line Slew Rate</b>	
Minimum	1.0 V/ms
Typical	NA
Maximum	NA
<b>Current Drain (during measurement)</b>	
Minimum	20 mA
Typical	20 mA
Maximum	28 mA
<b>Current Drain (while asleep)</b>	

Minimum	NA
Typical	0.03 mA
Maximum	NA
<b>Power Up Time (DDI serial)</b>	
Minimum	NA
Typical	NA
Maximum	100 ms
<b>Measurement Duration</b>	
Minimum	NA
Typical	25 ms
Maximum	50 ms
<b>COMPLIANCE</b>	
Manufactured under ISO 9001:2015	
EM ISO/IEC 17050:2010 (CE Mark)	

#### EQUIVALENT CIRCUIT AND CONNECTION TYPES

Refer to **Figure 2** and **Figure 3** to connect the ES-2 to a data logger. **Figure 2** provides a low-impedance variant of the recommended SDI-12 specification.



**Figure 2** Equivalent circuit diagram

#### PIGTAIL CABLE



- 1 Power (brown)
- 2 Ground (bare)
- 3 Digital communication (orange)

## STEREO CABLE



- 1 Ground
- 2 Digital communication
- 3 Power

**Figure 3 Connection types**



### PRECAUTIONS

METER sensors are built to the highest standards, but misuse, improper protection, or improper installation may damage the sensor and possibly void the warranty. Before integrating sensors into a sensor network, follow the recommended installation instructions and implement safeguards to protect the sensor from damaging interference.

### SURGE CONDITIONS

Sensors have built-in circuitry that protects them against common surge conditions. Installations in lightning-prone areas, however, require special precautions, especially when sensors are connected to a well-grounded third-party logger.

Read the application note [Lightning surge and grounding practices](#) on the METER website for more information.

### POWER AND GROUNDING

Ensure there is sufficient power to simultaneously support the maximum sensor current drain for all the sensors on the bus. The sensor protection circuitry may be insufficient if the data logger is improperly powered or grounded. Refer to the data logger installation instructions. Improper grounding may affect the sensor output as well as sensor performance.

Read the application note [Lightning surge and grounding practices](#) on the METER website for more information.

### CABLES

Improperly protected cables can lead to severed cables or disconnected sensors. Cabling issues can be caused by many factors, including rodent damage, driving over sensor cables, tripping over the cable, not leaving enough cable slack during installation, or poor sensor wiring connections. To relieve strain on the connections and prevent loose cabling from being inadvertently snagged, gather and secure the cable travelling between the ATMOS 41 and the data acquisition device to the mounting mast in one or more places. Install cables in conduit or plastic cladding when near the ground to avoid rodent damage. Tie excess cable to the data logger mast to ensure cable weight does not cause sensor to unplug.

## SENSOR COMMUNICATIONS

METER digital sensors feature a serial interface with shared receive and transmit signals for communicating sensor measurements on the data wire (**Figure 3**). The sensor supports two different protocols: SDI-12 and DDI serial. Each protocol has implementation advantages and challenges. Please contact **Customer Support** if the protocol choice for the desired application is not obvious.

### SDI-12 INTRODUCTION

SDI-12 is a standards-based protocol for interfacing sensors to data loggers and data acquisition equipment. Multiple sensors with unique addresses can share a common 3-wire bus (power, ground, and data). Two-way communication between the sensor and logger is possible by sharing the data line for transmit and receive as defined by the standard. Sensor measurements are triggered by protocol command. The SDI-12 protocol requires a unique alphanumeric sensor address for each sensor on the bus so that a data logger can send commands to and receive readings from specific sensors.

Download the [SDI-12 Specification v1.3](#) to learn more about the SDI-12 protocol.

### DDI SERIAL INTRODUCTION

The DDI serial protocol is the method used by the METER data loggers for collecting data from the sensor. This protocol uses the data line configured to transmit data from the sensor to the receiver only (simplex). Typically, the receive side is a microprocessor UART or a general-purpose I/O pin using a bitbang method to receive data. Sensor measurements are triggered by applying power to the sensor.

### INTERFACING THE SENSOR TO A COMPUTER

The serial signals and protocols supported by the sensor require some type of interface hardware to be compatible with the serial port found on most computers (or USB-to-serial adapters). There are several SDI-12 interface adapters available in the marketplace; however, METER has not tested any of these interfaces and cannot make a recommendation as to which adapters work with METER sensors. METER data loggers and the ProCheck hand-held device can operate as a computer-to-sensor interface for making on-demand sensor measurements. For more information, please contact **Customer Support**.

### METER SDI-12 IMPLEMENTATION

METER sensors use a low-impedance variant of the SDI-12 standard sensor circuit (**Figure 2**). During the power-up time, sensors output some sensor diagnostic information and should not be communicated with until the power-up time has passed. After the power-up time, the sensors are fully compatible with all commands listed in the [SDI-12 Specification v1.3](#) except for the continuous measurement commands (aR3 and aRC3). M, R, and C command implementations are found on page 7. The aR3 commands are used by METER systems and as a result uses a space delimiter, instead of a sign delimiter as required by the SDI-12 standard.

Out of the factory, all METER sensors start with SDI-12 address 0 and print out the DDI serial startup string during the power-up time. This can be interpreted by non-METER SDI-12 sensors as a pseudo-break condition followed by a random series of bits.

The ES-2 will omit the DDI serial startup string when the SDI-12 address is nonzero. Changing the address to a nonzero address is recommended for this reason.

### SENSOR BUS CONSIDERATIONS

SDI-12 sensor buses require regular checking, sensor upkeep, and sensor troubleshooting. If one sensor goes down, that may take down the whole bus even if the remaining sensors are functioning normally. Power cycling

the SDI-12 bus when a sensor is failing is acceptable, but METER does not recommend scheduling power cycling events on an SDI-12 bus more than once or twice per day. Many factors influence the effectiveness of the bus configuration. Visit [metergroup.com](http://metergroup.com) for articles and virtual seminars containing more information.

SDI-12 CONFIGURATION

Table 1 lists the SDI-12 communication configuration.

Table 1 SDI-12 communication configuration


Baud Rate	1,200 bps
Start Bits	1
Data Bits	7 (LSB first)
Parity Bits	1 (even)
Stop Bits	1
Logic	Inverted (active low)

SDI-12 TIMING

All SDI-12 commands and responses must adhere to the format in **Figure 4** on the data line. Both the command and response are preceded by an address and terminated by a carriage return and line feed combination (<CR> <LF>) and follow the timing shown in **Figure 5**.



Figure 4 Example SDI-12 transmission of the character 1 (0x31)



\*Maximum time is dependent upon the amount of data returned for the command sent.

Figure 5 Example data logger and sensor communication

COMMON SDI-12 COMMANDS

This section includes tables of common SDI-12 commands that are often used in an SDI-12 system and the corresponding responses from METER sensors.

IDENTIFICATION COMMAND (a!)

The Identification command can be used to obtain a variety of detailed information about the connected sensor. An example of the command and response is shown in **Example 1**, where the command is in **bold** and the response follows the command.

**Example 1** 1!113DECAGON\_ES-2389631800001

Parameter	Fixed Character Length	Description
1!	3	Data logger command. Request to the sensor for information from sensor address 1.
1	1	Sensor address. Prepended on all responses, this indicates which sensor on the bus is returning the following information.
13	2	Indicates that the target sensor supports <a href="#">SDI-12 Specification v1.3</a> .
DECAGON_	8	Vendor identification string. (DECAGON and one space_ )
ES-2_	6	Sensor model string. This string is specific to the sensor type. For the ES-2, the string is ES-2.

389	3	Sensor version. This number divided by 100 is the METER sensor version (e.g., 389 is version 3.89).
631800001	≤13, variable	Sensor serial number. This is a variable length field. It may be omitted for older sensors.

#### CHANGE ADDRESS COMMAND (aAB!)

The Change Address command is used to change the sensor address to a new address. All other commands support the wildcard character as the target sensor address except for this command. All METER sensors have a default address of 0 (zero) out of the factory. Supported addresses are alphanumeric (i.e., az, AZ, and 09). An example output from a METER sensor is shown in **Example 2**, where the command is in **bold** and the response follows the command.

#### Example 2 1A0!0

Parameter	Fixed Character Length	Description
1A0!	4	Data logger command. Request to the sensor to change its address from 1 to a new address of 0.
0	1	New sensor address. For all subsequent commands, this new address will be used by the target sensor.

#### ADDRESS QUERY COMMAND (?!)

While disconnected from a bus, the Address Query command can be used to determine which sensors are currently being communicated with. Sending this command over a bus will cause a bus contention where all the

sensors will respond simultaneously and corrupt the data line. This command is helpful when trying to isolate a failed sensor. **Example 3** shows an example of the command and response, where the command is in **bold** and the response follows the command. The question mark (?) is a wildcard character that can be used in place of the address with any command except the Change Address command.

### Example 3 **?!**0

Parameter	Fixed Character Length	Description
<b>?!</b>	2	Data logger command. Request for a response from any sensor listening on the data line.
0	1	Sensor address. Returns the sensor address to the currently connected sensor.

## COMMAND IMPLEMENTATION

The following tables list the relevant Measurement (M), Continuous (R), and Concurrent (C) commands and subsequent Data (D) commands, when necessary.

### MEASUREMENT COMMANDS IMPLEMENTATION

Measurement (M) commands are sent to a single sensor on the SDI-12 bus and require that subsequent Data (D) commands are sent to that sensor to retrieve the sensor output data before initiating communication with another sensor on the bus.

Please refer to **Table 2** and for an explanation of the command sequence and to **Table 6** for an explanation of response parameters.

**Table 2 aM! command sequence**

Command	Response
aM!	Attn
aD0!	a+<electricalConductivity>±<temperature>

NOTE: The measurement and corresponding data commands are intended to be used back to back. After a measurement command is processed by the sensor, a service request a <CR><LF> is sent from the sensor signaling the measurement is ready. Either wait until ttt seconds have passed or wait until the service request is received before sending the data commands. See the [SDI-12 Specifications v1.3](#) document for more information.

## CONCURRENT MEASUREMENT COMMANDS IMPLEMENTATION

Concurrent Measurement (C) commands are typically used with sensors connected to a bus. C commands for this sensor deviate from the standard C command implementation. First, send the C command, wait the specified amount of time detailed in the C command response, and then use D commands to read its response prior to communicating with another sensor.

Please refer to **Table 3** for an explanation of the command sequence and to **Table 6** for an explanation of response parameters.

**Table 3 aC! measurement command sequence**

Command	Response
aC!	Atttnn
aD0!	a+<electricalConductivity>±<temperature>

NOTE: Please see the [SDI-12 Specifications v1.3](#) document for more information.

## CONTINUOUS MEASUREMENT COMMANDS IMPLEMENTATION

Continuous Measurement (R) commands trigger a sensor measurement and return the data automatically after the readings are completed without needing to send a D command.

Please refer to **Table 4** through **Table 5** for an explanation of the command sequence and see **Table 6** for an explanation of response parameters.

**Table 4 aR0! measurement command sequence**

Command	Response
aR0!	a+<electricalConductivity>±<temperature>

**Table 5 aR3! measurement command sequence**

Command	Response
aR3!	a<TAB><electricalConductivity> <temperature><CR><sensorType><Checksum>

NOTE: This command does not adhere to the SDI-12 response format or timing. See **METER SDI-12**

**Implementation** for more information. The values in this command are space delimited. As such, a + sign is not assigned between values and a - sign is only present if the value is negative.

## PARAMETERS

**Table 6** lists the parameters, unit measurement, and a description of the parameters returned in command responses for ES-2.

**Table 6 Parameter Descriptions**

Parameter	Unit	Description
±	—	Positive or negative sign denoting sign of the next value
a	—	SDI-12 address
n	—	Number of measurements (fixed width of 1)
nn	—	Number of measurements with leading zero if necessary (fixed width of 2)
ttt	s	Maximum time measurement will take (fixed width of 3)
<TAB>	—	Tab character
<CR>	—	Carriage return character
<LF>	—	Line feed character
<electricalConductivity>	µS/cm	Electrical conductivity
<temperature>	°C	Temperature
<sensorType>	—	ASCII character denoting the sensor type For ES-2, the character is q
<Checksum>	—	METER serial checksum

## DDI SERIAL COMMUNICATION

The DDI serial communications protocol is ideal for systems that have dedicated serial signaling lines for each sensor or use a multiplexer to handle multiple sensors. The serial communications are compatible with many TTL serial implementations that support active-high logic levels using 0-3.6 V signal levels. When the sensor is first powered, it automatically makes measurements of the integrated transducers then outputs a response over the data line. Systems using this protocol control the sensor excitation to initiate data transfers from the sensor. This protocol is subject to change as METER improves and expands the line of digital sensors and data loggers.

The ES-2 will omit the DDI serial startup string when the SDI-12 address is nonzero. Changing the address to a nonzero address is recommended for this reason.

NOTE: Out of the factory, all METER sensors start with SDI-12 address 0 and print out the startup string when power cycled.

DDI SERIAL TIMING

Table 7 lists the DDI serial communication configuration.

Table 7 DDI serial communication configuration

Baud Rate	1,200 bps
Start Bits	1
Data Bits	8 (LSB first)
Parity Bits	0 (none)
Stop Bits	1
Logic	Standard (active high)

At power up, the sensor will pull the data line high within 100 ms to indicate that the sensor is taking a reading (Figure 6). When the reading is complete, the sensor begins sending the serial signal out the data line adhering to the format shown in Figure 7. Once the data is transmitted, the sensor goes into SDI-12 communication mode. To get another serial signal, the sensor must be power cycled.

NOTE: Sometimes the signaling from the sensor can confuse typical microprocessor UARTs. The sensor holds the data line low while taking measurements. The sensor raises the line high to signal the logger that it will send a measurement. Then the sensor may take some additional measurements before starting to clock out the first data byte starting with a typical start bit (low). Once the first start bit is sent, typical serial timing is valid; however, the signal transitions before this point are not serial signaling and may be misinterpreted by the UART.



Figure 6 Data line DDI serial timing




Figure 7 Example DDI serial transmission of the character 9 (0x39)

DDI SERIAL RESPONSE

Table 8 details the DDI serial response.

Table 8 DDI serial response

COMMAND	RESPONSE
NA	<TAB><electricalConductivity> <temperature><CR><sensorType><Checksum>

NOTE: There is no actual command. The response is returned automatically upon power up. The values in this command are space delimited. As such, a + sign is not assigned between values and a sign is only present if the value is negative.

## DDI SERIAL CHECKSUM

These checksums are used in the continuous commands R3 as well as the DDI serial response. The legacy checksum is computed from the start of the transmission to the sensor identification character, excluding the sensor address.

Example input is <TAB>5423 22.3<CR>q and the resulting checksum output is Z (capital z).

```
uint8_t LegacyChecksum(const char * response)
{
    uint16_t length;
    uint16_t i;
    uint16_t sum = 0;

    // Finding the length of the response string
    length = strlen(response);

    // Adding characters in the response together
    for( i = 0; i < length; i++ )
    {
        sum += response[i];
        if(response[i] == '\r')
        {
            // Found the beginning of the metadata section of the response
            break;
        }
    }

    // Include the sensor type into the checksum
    sum += response[++i];

    // Convert checksum to a printable character
    sum = sum % 64 + 32;

    return sum;
}
```

## CUSTOMER SUPPORT

### NORTH AMERICA

Customer service representatives are available for questions, problems, or feedback Monday through Friday, 7:00 am to 5:00 pm Pacific time.

#### Email:

[support.environment@metergroup.com](mailto:support.environment@metergroup.com)

[sales.environment@metergroup.com](mailto:sales.environment@metergroup.com)

**Phone:** +1.509.332.5600

**Fax:** +1.509.332.5158

**Website:** [metergroup.com](http://metergroup.com)

### EUROPE

Customer service representatives are available for questions, problems, or feedback Monday through Friday, 8:00 to 17:00 Central European time.

#### Email:

[support.europe@metergroup.com](mailto:support.europe@metergroup.com)  
[sales.europe@metergroup.com](mailto:sales.europe@metergroup.com)

**Phone:** +49 89 12 66 52 0

**Fax:** +49 89 12 66 52 20

**Website:** [metergroup.de](http://metergroup.de)

If contacting METER by email, please include the following information:

Name	Email address
Address	Instrument serial number
Phone number	Description of problem


NOTE: For products purchased through a distributor, please contact the distributor directly for assistance.

## REVISION HISTORY

The following table lists document revisions.

Revision	Date	Compatible Firmware	Description
01	11.13.2020	3.89	Updated sensor design and SDI specifications.
00	4.30.2020	3.89	Rebranded document for METER.

## Documents / Resources

	<a href="#">METER ES-2 INTEGRATOR SENSOR</a> [pdf] User Guide METER, ES-2, INTEGRATOR, SENSOR
-------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------

## References

- [Home of METER | METER Group, Inc. USA](#)
- [Home of METER | METER Group, Inc. USA](#)